



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Feb 11, 2026                      **Inspection Result:**     **PARTIAL PASS**

**Permit Number:** PRMU20230881

**Property Address:** 707 39TH AVE SE, Unit: D, PUYALLUP, WA 98374;

**Contractor:** Anthony Mizin 315 fifth Ave S. Suite 600 Seattle, WA 98104 WALSH CONSTRUCTION CO. 315 FIFTH AVE S, SUITE 600 SEATTLE, WA 98104- (206) 547-4008

**To construct:** As part of the Phase 2 development of Wesley Bradley Park, - Group R2 w/ 3 stories Type VA over Type 1A concrete garage. This project has 67 dwelling units. - WESLEY HOMES BRADLEY PARK PH 2 - BROWNSTONE \* REVISION (1) - 6/24/2025 - ENERGY CODE CALS, EV CAR LOCATION AND GARAGE AND DAS SYSTEM LOCATION.

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Level two units, 2025, 2024 and 2021 soffits approved

**Corrections:**

- 1
- 2 Inspection at Level 2 Club Room
  - 1 ; fix electrical outside of wall above door opening of restroom.
  - 2 ; complete framing at restroom ceiling not to exceed 24" o.c. as discussed with contractor.
  - 3 ; strap top plate to beam at beam in club room.Room 1043
  - 1 ; provide positive connection of top plate to wall.ok to insulate both rooms

Sincerely,



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)



James LaVergne

[JLaVergne@PuyallupWA.gov](mailto:JLaVergne@PuyallupWA.gov)

(253) 841-5590