



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Feb 11, 2026

Inspection Result: NOT READY

Permit Number: PRRNTH20250328

Property Address: 1200 7TH AVE SE, PUYALLUP, WA 98372;

Contractor:

To construct: CONSTRUCT (3) TOWNHOUSE DWELLING UNITS (BLDG A) ~ 1200 7th AVE TOWNHOUSES

On this day we have inspected your construction for **Energy (Insulation) Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1. Inspection was for 1 hour fire wall partition between units. Dens glass sheetrock must cover all wood with no gaps in-between sheets.
2. Discussed with contractor on how to proceed.

Corrections:

1. Inspection was for 1 hour fire wall partition between units. Dens glass sheetrock must cover all wood with no gaps in-between sheets.
2. Discussed with contractor on how to proceed.

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org



James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590