



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Feb 12, 2026

**Inspection Result:** NOT READY

**Permit Number:** PRCTI20251295

**Property Address:** 2323 7TH ST SE, PUYALLUP, WA 98374;

**Contractor:** SAGEWATER, LLC. 1319 POWHATAN ST ALEXANDRIA, VA 22314 (888) 584-9900

**To construct:** Replace hot and cold water lines for all 155 units at property - BRADLEY PARK APARTMENTS

On this day we have inspected your construction for **Plumbing Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 1. Finish all fire caulking as needed.  
2. Leave shower valve exposed on fire wall applications.  
3. Provide a minimum of 2" overlap at two-layer drywall applications.

**Corrections:**

- 1 1. Finish all fire caulking as needed.
2. Leave shower valve exposed on fire wall applications.
3. Provide a minimum of 2" overlap at two-layer drywall applications.

Sincerely,



City of Puyallup


---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)



James LaVergne

[JLaVergne@PuyallupWA.gov](mailto:JLaVergne@PuyallupWA.gov)

(253) 841-5590