



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Feb 26, 2026 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCNC20240424

Property Address: 707 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: WALSH CONSTRUCTION CO/WASH 83 Columbia St Ste 400 SEATTLE, WA 98104

To construct: UPDATED SCOPE OF WORK - Wesley Bradley Park PH2 Care Center which is being built adjacent to the existing Lodge Building. This project will be a licensed Care Center with 36 beds in 35 sleeping units all on Level 1. The lower level will include a swimming pool and Physical Therapy Area with other staff support and building operation spaces for the nursing home above. CARE CENTER * REVISION (1) - 1/23/2024 - ENERGY CODE CALCS & ASSOCIATED DRAWINGS * REVISION (2) - 1/30/2025 - DEFERRED ROOF TRUSS SUBMITTAL

On this day we have inspected your construction for **Plumbing Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Underground plumbing care center approved

Corrections:

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org



James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590