



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Feb 27, 2026 **Inspection Result:** **FAILED**

Permit Number: PRCCP20240845

Property Address: 202 27TH AVE SE, Unit: 1, PUYALLUP, WA 98374;

Contractor: RUSH COMMERCIAL CONSTRUCTION INC 6622 WOLLOCHET DR NW
GIG HARBOR, WA 98335-8325

To construct: Site development improvements, including clearing, grading, retaining walls, parking lot, storm drainage, sanitary sewer main, water main for 236-unit multi-family development. - 206 27TH AVE SE - BRADLEY HEIGHTS APARTMENTS * REVISION (1) - 1/29/2026 - PHASING PLAN

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Large amount of track out today. This is due to not having a rock path for the concrete trucks onsite. A sweeper has been working in the ROW all day cleaning up the mess. Failure to stop the track out will result in a stop work order of the project.

Corrections:

Sincerely,

Jeff Hill
Development Engineering Inspector
Jhill@PuyallupWA.gov
(253) 204-5633