



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Mar 03, 2026                      **Inspection Result:**     **FAILED**

**Permit Number:** PRCTI20251295

**Property Address:** 2323 7TH ST SE, PUYALLUP, WA 98374;

**Contractor:** SAGEWATER, LLC. 1319 POWHATAN ST ALEXANDRIA, VA 22314 (888) 584-9900

**To construct:** Replace hot and cold water lines for all 155 units at property - BRADLEY PARK APARTMENTS

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 Building A - Units 201,102 and 202
  - 1 ; complete drywall at garage ceiling.
  - 2 ; seal all penetrations in garage ceilings.
  - 3 ; insulate water supply lines at hot water heater in garage.
  - 3 ; complete install of hammer arrestor at icemaker, clothes washing machine, and dishwasher as discussed with contractor. (not ready)

Sincerely,

Shannon King  
Building Inspector 2



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)

(253) 840-6684