



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 03, 2026 **Inspection Result:** **FAILED**

Permit Number: PRCTI20251295

Property Address: 2323 7TH ST SE, PUYALLUP, WA 98374;

Contractor: SAGEWATER, LLC. 1319 POWHATAN ST ALEXANDRIA, VA 22314 (888) 584-9900

To construct: Replace hot and cold water lines for all 155 units at property - BRADLEY PARK APARTMENTS

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 Building A - Units 201,102 and 202
 - 1 ; complete drywall at garage ceiling.
 - 2 ; seal all penetrations in garage ceilings.
 - 3 ; insulate water supply lines at hot water heater in garage.
 - 3 ; complete install of hammer arrestor at icemaker, clothes washing machine, and dishwasher as discussed with contractor. (not ready)

Sincerely,

Shannon King
Building Inspector 2



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

ShannonK@PuyallupWA.gov

(253) 840-6684