



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 03, 2026 **Inspection Result:** **NOT READY**

Permit Number: PRCTI20251416

Property Address: 3500 S MERIDIAN, Unit: 305, PUYALLUP, WA 98373;

Contractor: NATIONAL CONTRACTORS INC 2500 Orchard Lane EXCELSIOR, MN 55331 (952) 881-6123

To construct: Tenant remodel in existing tenant space INTERIOR REMODEL OF EXISTING TENANT SPACE FOR USE BY JEWELRY STORE (MERCANTILE - NO CHANGE IN USE), INCLUDING NEW WALLS, DOORS, CEILINGS, LIGHTING, FINISHES, DISPLAY FIXTURES, PLUMBING FIXTURES AND ASSOCIATED MODIFICATIONS TO EXISTING ELECTRICAL, MECHANICAL, FIRE SPRINKLER, AND FIRE ALARM SYSTEMS. ~ PANDORA, UNIT 305

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1. Add perimeter wires to exposed ceiling grid.
2. Provide fire test and inspection.
3. Grease duct light test approved. Provide first layer wrap and start second layer for over lap.

Corrections:

- 1 1. Add perimeter wires to exposed ceiling grid.
2. Provide fire test and inspection.
3. Grease duct light test approved. Provide first layer wrap and start second layer for over lap.

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org



James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590