



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 09, 2026 **Inspection Result:** **NOT READY**

Permit Number: PRCTI20250324

Property Address: 1015 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: JTM CONSTRUCTION 5900 AIRPORT WAY SOUTH, #110 SEATTLE, WA 98108 (206) 773-3360

To construct: Commercial tenant improvement to existing 50,767 sf space - COP ~ PUBLIC SAFETY BUILDING * REVISION (1) - 8/21/2025 - GENERATOR DEFERRED SUBMITTAL * REVISION (2) - 10/30/2025 - EXTERIOR CANOPY CONNECTIONS

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

- Comments:**
1. Discussed with plumbing contractor on final requirements for final inspection.
 2. Set of plumbing prints to follow along with.
 3. All backflow test reports.
 4. Providing RPBA at the dog wash.
 5. Removing garbage disposal at breakroom sink.

Corrections:

- 1 1. Discussed with plumbing contractor on final requirements for final inspection.
2. Set of plumbing prints to follow along with.
3. All backflow test reports.
4. Providing RPBA at the dog wash.
5. Removing garbage disposal at breakroom sink.

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org



James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590