



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Mar 13, 2026                      **Inspection Result:**     **PARTIAL PASS**

**Permit Number:** PRCTI20260347

**Property Address:** 2323 7TH ST SE, PUYALLUP, WA 98374; 2323 7TH ST SE, Unit: C101,  
PUYALLUP, WA 98374;

**Contractor:** SAGEWATER, LLC. 1319 POWHATAN ST ALEXANDRIA, VA 22314 (888)  
584-9900

**To construct:** Replace hot and cold water lines for all 155 units at property - BRADLEY  
PARK APARTMENTS - BLDG C

On this day we have inspected your construction for **Combination Frame And Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 1. Unit D 101 need fire caulk touch up. Rockwool draft stop touch up in bathroom. Add Insulation where needed call for reinspection this unit.  
2. Unit C203 no entry to unit.  
3. Units C102, 202, 204 approved for cover.

**Corrections:**

- 1 1. Unit D 101 need fire caulk touch up. Rockwool draft stop touch up in bathroom. Add Insulation where needed call for reinspection this unit.
2. Unit C203 no entry to unit.

Sincerely,



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)



James LaVergne

[JLaVergne@PuyallupWA.gov](mailto:JLaVergne@PuyallupWA.gov)

(253) 841-5590