



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 17, 2026

Inspection Result: NOT READY

Permit Number: PRRNTH20250328

Property Address: 1200 7TH AVE SE, PUYALLUP, WA 98372;

Contractor:

To construct: CONSTRUCT (3) TOWNHOUSE DWELLING UNITS (BLDG A) ~ 1200 7th AVE TOWNHOUSES

On this day we have inspected your construction for **Shear Wall Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1 ; re nail all over driven nails as discussed with contractor.
2 ; complete strap at window at n.w . corner of 2nd floor.
3 ; complete all nailing as per city approved plans.
not ready.

Corrections:

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org