



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Mar 18, 2026                      **Inspection Result:**     **PARTIAL PASS**

**Permit Number:** PRMU20240286

**Property Address:** 206 27TH AVE SE, PUYALLUP, WA 98374;

**Contractor:** RUSH COMMERCIAL CONSTRUCTION INC 6622 WOLLOCHET DR NW  
GIG HARBOR, WA 98335-8325

**To construct:** SUBMITTED AS BLDG A - BRADLEY HEIGHTS APARTMENTS - ISSUED AS  
206 27TH AVE SE, BLDG J

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 1 ; inspection of pre-rock to insulate for tubs and breezeway rim for pre-rock 2 hour rating.

2 ; complete all nail plates and firestop at top and bottom plates.

3 ; complete firestop at bottom plates of party wall at back of showers.

(will check at energy inspection as discussed with contractor.)

**Corrections:**

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)