



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 19, 2026 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCTI20251295

Property Address: 2323 7TH ST SE, PUYALLUP, WA 98374;

Contractor: SAGEWATER, LLC. 1319 POWHATAN ST ALEXANDRIA, VA 22314 (888) 584-9900

To construct: Replace hot and cold water lines for all 155 units at property - BRADLEY PARK APARTMENTS - BLDG A

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: unit 101 final approved

Corrections:

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org



James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590