



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 19, 2026 **Inspection Result:** **NOT READY**

Permit Number: PRMH20251523

Property Address: 1601 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: ELITE MECHANICAL SERVICES, LLC 2625 REINHARDT LN NE, SUTIE F LACEY, WA 98516 (360) 489-0717

To construct: Demo: HP-1, HP-2, HP-3 Disconnect comm wiring Disconnect heat pump's from existing curbs Crane heat pump's off roof Haul off equipment and dispose of per EPA standards Furnish and Install New: Daikin Heat Pump RTU's 460v/3ph Electric back up heat Crane curb adapters to roof Secure curb adapters to existing roof curbs Crane heat pump's on to curb adapters Connect comm wiring Condensate p traps Economizers Start and test heat pump's Mechanical permit Alt 1: Replace HP-4,5,6 - CHILD DEVELOPMENT CENTER PIERCE COLLEGE

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: inspection canceled due to no fire inspector available for duct test inspection.

Corrections:

- 1 1. Duct detector inspection and test required.
2. Fire inspection required.
3. Provide approved plans on site for inspection as to scope of work being performed.

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

A handwritten signature in black ink that reads "Shannon King". The signature is written in a cursive style.

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684