



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Nathan L Miller  
1645 NW Hoyt  
Portland, OR 97209

March 23, 2026

## Development Submittal Notice

### Permit Application Number PRMU20260283

Dear Nathan L Miller,

Thank you for submitting your permit application documents to the City of Puyallup. The Permit Center reviewed your submission on February 27, 2026 and determined that it is insufficient.

#### Missing or Insufficient Submittal Documents

Please submit the following items through the [permitting portal](#).

#### Completeness Check Comments

As a courtesy to our customers, the plan reviewers have conducted a completeness check to verify that the contents of the permit submission are adequate to complete a thorough first review. Even though all the minimum submittal documents were received, the plan reviewers have deemed your submittal as incomplete and compiled the completeness check comments below based on the scope and details of your project. Please address any comments below by updating your permit submittals and resubmitting them through the [permitting portal](#).

<i>Building Completeness Check</i>		
<i>Brian Snowden</i>	<i>(253)435-3618</i>	<i>BSnowden@puyallupwa.gov</i>



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

- The majority of items listed under Deferred Submittals on sheet G000 cannot be deferred and must be submitted with the application:

- Storefront Window System
- MEP Equipment Bracing
- Roof Trusses
- Suspended Soffits and Ceilings, Including Bracing
- Rooftop Anchorage
- Guardrails and Handrails

If you have any questions regarding these submittal items, please contact Brian Snowden, as listed above.

*Planning Completeness Check*

*Chris Beale*

*(253)841-5418*

*CBeale@PuyallupWA.gov*

Other / Miscellaneous

Condition from the Preliminary Site Plan: "Provide a parking management plan prior to building permit, per the conditions of the Development Agreement." Please provide

Other / Miscellaneous

Condition from the Preliminary Site Plan: "Provide a parking management plan prior to building permit, per the conditions of the Development Agreement." Please provide the parking management plan with the first submittal for staff review.

If you have any questions regarding these submittal items, please contact Chris Beale, as listed above.

The submittal shall only be considered complete if the information requested above is received by the City of Puyallup within 90 days of the date of this letter and deemed satisfactory by the Permit Center. Otherwise, your permit application will be canceled, and you will need to apply for a new permit. Once your submission is accepted, deemed complete, and any outstanding fees are paid, your submittal will proceed to plan review.

For questions or assistance, please contact the Permit Center.

Always in Season,



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

**Puyallup's Permit Center**

333 S Meridian, 2nd Floor

Puyallup, WA 98371

(253) 864-4165, option 1

[PermitCenter@PuyallupWA.gov](mailto:PermitCenter@PuyallupWA.gov)