



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Mar 24, 2026

**Inspection Result:** NOT READY

**Permit Number:** PRCTI20260398

**Property Address:** 2323 7TH ST SE, Unit: I101, PUYALLUP, WA 98374;

**Contractor:** SAGEWATER, LLC. 1319 POWHATAN ST ALEXANDRIA, VA 22314 (888) 584-9900

**To construct:** Replace hot and cold water lines for all 155 units at property - BRADLEY PARK APARTMENTS - BLDG I

On this day we have inspected your construction for **Combination Frame And Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Unit I 101

1. Missing framing for toilet patch work.
2. Missing fire caulking in laundry room wall.
3. Missing pipe insulation in bathroom.
4. Drywall screws to deep.

**Corrections:**

- 1 Unit I 101
  1. Missing framing for toilet patch work.
  2. Missing fire caulking in laundry room wall.
  3. Missing pipe insulation in bathroom.
  4. Drywall screws to deep.

Sincerely,



City of Puyallup


---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)



James LaVergne

[JLaVergne@PuyallupWA.gov](mailto:JLaVergne@PuyallupWA.gov)

(253) 841-5590