



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Mar 24, 2026                      **Inspection Result:**     **PARTIAL PASS**

**Permit Number:** PRFUP20250685

**Property Address:** 3500 S MERIDIAN, Unit: 115, PUYALLUP, WA 98373;

**Contractor:** MASTEC NORTH AMERICA INC 806 Douglas Rd #1100 Coral Gables, FL 33134

**To construct:** JB0002054752 OSP DE - Comcast proposes to overlash 48ct fiber, proof and pull 48ct fiber thru conduit and riser, bore and place 2" hdpe sch, 40 conduits w/ 48ct fiber, overset proposed 24"x36" vault, repair and restore sidewalk and landscape bore pit, tie into existing aerial , and underground splice cases

On this day we have inspected your construction for **Comment Engineering Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Per MasTec, night work was completed Monday night. Contractor to coordinate with city inspectors for ROW work. Some pits are still covered.

Corrections:

- Vault near Applebee's needs to be raised to match existing grade, then clean up the sidewalk to remove debris. I did not inspect the other vault locations.
- Soft surface restoration adding 4-8" of topsoil and seed, raking and grading to match existing
- Remove construction debris including rock, concrete, caution tape, etc.
- Core drill restoration on 37th Ave SW
- Pick up road work sign left in the parking lot near Chase Bank

**Corrections:**

Sincerely,



City of Puyallup

---

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

*Cheryl Trimble*

Cheryl Trimble

Engineer Technician III

[CTrimble@PuyallupWA.gov](mailto:CTrimble@PuyallupWA.gov)

(253) 290-9834