



**Date:** 3/25/26

**Subject:** Correction Response Letter for pending permit: PRFUP20251607

**To:** City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

**From:** CableCom, LLC

Permitting

1429 Avenue D, #339 Snohomish, WA 98290

(720) 787-7459

<b>Engineering Review</b>	<b>Correction Response</b>
CURRENT REVIEW CORRECTION: The established right-of-way limits should not be shifted or exaggerated to accommodate an existing, noncompliant pedestal location. Return the right-of-way limits to those depicted on the last submittal. Then consider removing pedestal upgrade from scope of City permit, obtaining a retroactive easement for utilities previously installed on private property, or replacing the pedestal upgrade on the site plan with a note that says the work will continue on private property as permitted by the private property owner.	Removed Vault work along 1510 S MERIDIAN from SOW - Submitting TCP showing lane shift for this location.