



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 25, 2026 **Inspection Result:** **FAILED**

Permit Number: PRCTI20260398

Property Address: 2323 7TH ST SE, Unit: I101, PUYALLUP, WA 98374;

Contractor: SAGEWATER, LLC. 1319 POWHATAN ST ALEXANDRIA, VA 22314 (888) 584-9900

To construct: Replace hot and cold water lines for all 155 units at property - BRADLEY PARK APARTMENTS - BLDG I

On this day we have inspected your construction for **Combination Frame And Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Unit I 101

1. Missing framing for toilet patch work.
2. Missing fire caulking in laundry room wall.
3. Missing pipe insulation in bathroom.
4. Drywall screws to deep.

Corrections:

- 2 Unit I101
 - 1 ; complete nail plates at water supply lines.
 - 2 ; complete firestop as discussed with contractor.

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

A handwritten signature in black ink that reads "Shannon King". The signature is written in a cursive style.

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684