



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Mar 25, 2026                      **Inspection Result:**     **PARTIAL PASS**

**Permit Number:** PRCCP20251419

**Property Address:** 320 TODD RD NE, PUYALLUP, WA 98372; 302 TODD RD NE, PUYALLUP, WA 98372; 212 TODD RD NE, PUYALLUP, WA 98372;

**Contractor:** Advanced Underground Utilities, Inc. PO Box 309 Sumner, WA 98390  
(253) 988-2449

**To construct:** The Todd Rd Sewer Extension project proposes a private sewer main extension from the existing City of Puyallup Sewer stub located on 212 Todd Rd NE. Existing residential buildings will be disconnected from the existing septic systems and reconnected to new side sewers along the new private main.

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Note: This is not a punch list.  
Any plumbing work needs a plumbing permit.

**Corrections:**

- 1 - Stop ground water penetration from SSMH#1 & #2.
- Install concrete collars around all three SSMH's.
- Install sewer c/o castings over c/o's in a driving surface. These need to have an 8" pvc sleeve and concrete collar.
- Install sewer carson boxes on all c/o's in a landscape area.

Sincerely,



City of Puyallup

---

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Jason Little

Development Engineering Inspector

[JLittle@PuyallupWA.gov](mailto:JLittle@PuyallupWA.gov)

(253) 244-0387