

TANK PUMPING REPORT

PRSC20260385

Site Name:

Location: 320 TODD RD NE
Puyallup
Tax ID: 0420222005
Use:

Service Company:

Drain-Pro, Inc.
PO Box 100
Puyallup, WA 98372
253-926-5586

Serviced:03/26/2026 by: Brandon Lewis

Submitted 03/30/2026 by:Dana Malarcher

Dump Location: King County Metro Wastewater Treatment Plant

Jurisdiction ID:ON0146882

COMMENTS

Pump for demo.

TANK: Septic Tank - 1 Compartment, Manufacturer= Local Manufacturer - Concrete

Tank Pumped:	YES	
Total Gallons pumped from tank (Number only, no text):	1000	
Tank Size (Gallons)(Number only, no text):	1000	
Tank depth below grade (inches):	6	
Effluent level within operational limits (if NO explain in comments):	YES	
Effluent returning back into tank after pumping:	NO	
Access Risers installed to grade (N/A if not present):	N/A	
Tank Construction Material:	Concrete	
Tank Condition Good:	YES	
Baffles in good condition (N/A if not present):	YES	
Effluent screen cleaned (N/A if not present):	N/A	
Effluent surfacing around site components (N/A if not checked):	NO	
Tank abandoned after pumping:	YES	
Were repairs made to the Tank or Tank Components? (if YES explain in comments):	NO	
Compartment 1 Scum accumulation (Inches, if other specify):	0	
Compartment 1 Sludge accumulation (Inches, if other specify):	4	

This report indicates certain characteristics of the onsite sewage system at the time of visit. In no way is this report a guarantee of operation or future performance.