



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Apr 02, 2026

Inspection Result: **FAILED**

Permit Number: PRCTI20260393

Property Address: 2323 7TH ST SE, Unit: F101, PUYALLUP, WA 98374;

Contractor: SAGEWATER, LLC. 1319 POWHATAN ST ALEXANDRIA, VA 22314 (888) 584-9900

To construct: Replace hot and cold water lines for all 155 units at property - BRADLEY PARK APARTMENTS - BLDG F

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 Unit 102
 - 1 ; complete nail plates at hot and cold water supply lines.
 - 2 ; complete insulation at hot water supply lines.
 - 3 ; seal penetrations in top and bottom plates, (not ready)

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org