

RED HAWK FIRE PROTECTION, LLC

801 Valley Ave NW, Suite D
Puyallup, WA 98371
(253) 840-9900

REDHAHF901QP





Ever Vigilant[®]

HYDRAULIC CALCULATIONS

FOR

Wesley Bradley Park – Care Center
Puyallup, WA

RHFP JOB NO. 70120

 Expires DEC 31, 26	WASHINGTON STATE CERTIFICATE OF COMPETENCY FIRE SPRINKLER SYSTEMS
Travis Clifton Kinne 0835-1021-C Level 3 Red Hawk Fire Protection, LLC REDHAHF901QP	
	04/10/2026
Signature	Date

MEMORANDUM

TO: BRIAN JOHNSON, WATER SYSTEM SPECIALIST
 FROM: MAYA VITA, E.I.T.
 KERRI SIDEBOTTOM, P.E.
 DATE: MARCH 6, 2025
 SUBJECT: WESLEY HOMES FIRE FLOW AVAILABILITY – 707 39TH AVENUE SE
 CITY OF PUYALLUP, PIERCE COUNTY, WASHINGTON
 G&O #21415.23

Per your request, we have analyzed the available fire flow at the Wesley Homes site located at 707 39th Avenue SE. The following assumptions used to determine the static pressure and available fire flow are noted as follows.

- The available fire flows and pressures are measured at six nodes, corresponding to five existing hydrants within the Wesley Homes site, as shown in the attached figure.
- Water system demands are based on projected 2038 demands and reservoirs are depleted of fire suppression and equalizing storage, as established in the *2019 Water System Plan (WSP)*, approved by the Washington State Department of Health (DOH). The City’s water model was updated in 2021 to reflect additional system improvements since the WSP was developed.
- All pump stations are idle, and the Salmon Springs source is operating at 1,100 gallons per minute (gpm).

The site is located in Zone 4, which is supplied by the 39th Avenue SE Reservoir 1. The system was modeled with the piping indicated on the attached figure.

The available pressure under 2038 peak hour demands at the hydrants is included in Table 1.

TABLE 1

Modeled Fire Flow Availability

Node	Hydrant	Elevation, feet	Peak Hour Pressure, psi
J1832	SE 903	462	82
J1834	SE 905	473	77
J2434	SE 902	474	77
J2436	SE 901	472	78
J2438	SE 900	465	81
J2440	SE 904	470	78



Available fire flow was modeled at six existing hydrants around the Wesley Homes site. All site piping is 12-inch ductile iron. The results of this modeling are included in Table 2. The modeled fire flow is available at either hydrant individually, but not simultaneously.

TABLE 2
Modeled Fire Flow Availability


Node	Hydrant	Modeled Fire Flow, gpm	Residual Pressure at Modeled Fire Flow, psi	Minimum System Pressure at Modeled Fire Flow, psi
J1832	SE 903	3,320 ⁽¹⁾	24	20
J1834	SE 905	3,250 ⁽¹⁾	20	20
J2434	SE 902	3,330 ⁽¹⁾	20	20
J2436	SE 901	3,350 ⁽¹⁾	21	20
J2438	SE 900	3,390 ⁽¹⁾	24	20
J2440	SE 904	3,340 ⁽¹⁾	21	20

(1) Limited by the minimum system-wide pressure requirement of 20 psi at all service locations.

Fire flow to the hydrants is limited by the 20-psi minimum system pressure.

The Department of Health and City Standards for water distribution systems are to meet the peak hourly demand of the system while providing a minimum pressure of 30 psi, system-wide. Under peak daily demand with a fire flow, the system is designed to maintain a minimum pressure of 20 psi, system-wide. Although the peak hourly demand pressure may currently be higher than these standards, the Developer must recognize that the City may not provide pressure higher than 30 psi in the future. The flows and pressures determined in this memo are based on the approximate hydrant elevation at ground level. The Developer may design their sprinkler system for whatever pressure they wish; however, they must recognize and be responsible for conditions when the pressure may be less than currently exists.

MV/sr




SE 509

THE MAP FEATURES ARE APPROXIMATE AND ARE INTENDED ONLY TO PROVIDE AN INDICATION OF SAID FEATURE. THIS IS NOT A SURVEY. THE CITY ASSUMES NO LIABILITY FOR VARIATIONS ASCERTAINED BY ACTUAL SURVEY. ALL DATA IS EXPRESSLY PROVIDED 'AS IS' AND 'WITH ALL FAULTS'. THE CITY MAKES NO WARRANTY OF FITNESS FOR A PARTICULAR PURPOSE.

SE 508

3511



CITY OF PUYALLUP
PUBLIC WORKS
WATER DIVISION

HYDRAULIC MODEL FOR WESLEY HOMES AT 707 39TH AVE SE

SCALE AS SHOWN

02/19/2025

COP\PW\WATER\S_MAINT\PDF\QSEC\
PG011\MODEL FOR 707 39TH AVE SE

Hydraulic Calculations

for

Project Name: BRADLEY PARK CARE CENTER: (70120)

Location: 707 39TH AVE SE, BLDG B, , PUYALLUP, WA 98374

Drawing Name: 70120 WBP Care Center R01 Level 0 Basement

Calculation Date: 4/10/2026

Design

Remote Area Number: L0A1
Remote Area Location: SPA 0108B
Occupancy Classification: Light Hazard

Density: 0.100gpm/ft²
Area of Application: 1950.00ft² (Actual 911.35ft²)
Coverage per Sprinkler: 100.00ft²
Type of sprinklers calculated: Upright, Pendent
No. of sprinklers calculated: 12
No. of nozzles calculated: 0

In-rack Demand: N/A gpm at Node: N/A
Hose Streams: 100.00 at Node: 1 Type: Allowance at Source

Total Water Required (including Hose Streams where applicable):
From Water Supply at Node 1: 300.67 @ 77.731 (Safety Margin = 3.587)

Type of System: DRY
Volume of Dry/PreAction/Antifreeze/OtherAgent System: 411.42gal

Name of Contractor: RED HAWK FIRE PROTECTION, LLC
Address: 801 VALLEY AVE NW, SUITE D, PUYALLUP, WA 98371
Phone Number: 253-604-7311
Name of designer: BROOKE MCDANIELS
Authority Having Jurisdiction: : CITY OF PUYALLUP


Notes:

Summary Notes:

Water Supply at Node 1

1 System Demand
3 Available Water Supply

Job Name: BRADLEY PARK CARE CENTER
 Job Number: 70120 - REMOTE AREA L0A1
 Report Description: Light Hazard (L0A1)
 Remote Area Number: L0A1



Curve	Data Point	Hydraulic Calculation Results	Additional Data
1	1B	Required Pressure at System Demand: 77.731 @ 200.67	Available Flow @ 20 PSI: 3441.74
	1C	Required Pressure at System Demand (Including Hose Allowance at Source): 77.731 @ 300.67	
3	3A	Available Static Pressure at Water Supply at Node 1: 82.000	
	3B	Available Residual Pressure at System Demand: 81.318 @ 300.67	
	3C	Available Residual Pressure & Flow at Water Supply at Node 1: 24.000 @ 3320.00	



Summary Of Outflowing Devices

Job Number: 70120 - REMOTE AREA L0A1
Report Description: Light Hazard (L0A1)

Device	Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)			
Sprinkler 1000	15.29	10.00	5.6	7.455			
Sprinkler 1001	15.87	10.00	5.6	8.029			
Sprinkler 1003	16.34	10.00	5.6	8.510			
Sprinkler 1004	16.81	10.00	5.6	9.010			
⇒ Sprinkler 1005	14.82	10.00	5.6	7.000			
Sprinkler 1006	14.83	10.00	5.6	7.010			
Sprinkler 1008	15.77	10.00	5.6	7.929			
Sprinkler 1009	16.35	10.00	5.6	8.529			
Sprinkler 1010	16.46	10.00	5.6	8.635			
Sprinkler 1011	17.01	10.00	5.6	9.230			
Sprinkler 1103	26.00	10.00	5.6	21.560			
Sprinkler 1107	15.13	10.00	5.6	7.303			

⇒ Most Demanding Sprinkler Data

Supply Analysis							
Node	Name	Static (psi)	Residual (psi)	@ Flow (gpm)	Available (psi)	@ Total Demand (gpm)	Required Pressure (psi)
1	Water Supply	82.000	24.000	3320.00	81.318	300.67	77.731

Node Analysis					
Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1	7-0	Supply	77.731	200.67	
1000	10-0½	Sprinkler	7.455	15.29	
1001	10-1	Sprinkler	8.029	15.87	
1003	10-1½	Sprinkler	8.510	16.34	
1004	10-2	Sprinkler	9.010	16.81	
1005	17-6	Sprinkler	7.000	14.82	
1006	17-6	Sprinkler	7.010	14.83	
1008	10-0½	Sprinkler	7.929	15.77	
1009	10-1	Sprinkler	8.529	16.35	
1010	6-6½	Sprinkler	8.635	16.46	
1011	6-7½	Sprinkler	9.230	17.01	
1103	10-6	Sprinkler	21.560	26.00	
1107	17-5	Sprinkler	7.303	15.13	
2	7-0		77.261	0.00	
3	3-0½	Gauge	78.920	0.00	BOR, BFP(-1.999)
4	3-0½		76.919	0.00	
109	10-2		9.616	0.00	
121	7-9½		62.310	0.00	

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1050	10-0½		7.963	0.00	
1051	10-2		9.745	0.00	
1052	17-6		8.963	0.00	
1053	18-0½		7.908	0.00	
1054	18-0		8.010	0.00	
1055	17-11½		8.326	0.00	
1056	17-8½		8.907	0.00	
1057	17-6		9.218	0.00	
1058	10-0½		8.466	0.00	
1059	10-1½		8.928	0.00	
1060	10-2		9.657	0.00	
1061	17-6		9.971	0.00	
1062	17-6		10.397	0.00	

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
1005	17-6	5.6	14.82	1	(See Notes)	2-4½	100	7.000	••••• Route 1 ••••• Sprinkler, T(3-7), E(1-5), PO(3-7)
1053	18-0½		14.82	1.0490		8-6½	0.104671	-0.235	
						10-11		1.144	
1053	18-0½			1½		9-3	100	7.908	
1054	18-0		14.82	1.7280		9-3	0.009208	0.017	
								0.085	
1054	18-0		14.83	1½		9-0	100	8.010	Flow (q) from Route 2
1055	17-11½		29.64	1.7280		9-0	0.033216	0.017	
								0.299	
1055	17-11½		15.13	1½	(See Notes)	2-8	100	8.326	Flow (q) from Route 3 E(4-0½)
1056	17-8½		44.78	1.7280		4-0½	0.071242	0.104	
						6-8½		0.477	
1056	17-8½			2	(See Notes)	0-0	100	8.907	T(8-9½)
1057	17-6		44.78	2.1570		8-9½	0.024195	0.099	
						8-9½		0.212	
1057	17-6		64.30	2	(See Notes)	1-11	100	9.218	Flow (q) from Route 4 T(7-5½)
1062	17-6		109.08	2.1570		7-5½	0.125635		
						9-4½		1.179	
1062	17-6		65.59	2	(See Notes)	14-9½	100	10.397	Flow (q) from Route 5 4fE(3-1)
1103	10-6		174.67	2.1570		12-3½	0.300194	3.037	
						27-1		8.126	
1103	10-6	5.6	26.00	2	(See Notes)	86-7½	100	21.560	Sprinkler, 5fE(3-1)
121	7-9½		200.67	2.1570		15-4½	0.388059	1.179	
						101-11½		39.571	
121	7-9½			3	(See Notes)	174-10	100	62.310	PO(14-4½) fE(4-9½), T(12-5½), E(6-8½), DPV(4-8½), BV(9-7), PO(14-4½)
4	3-0½		200.67	3.2600		67-0	0.051925	2.053	
						241-10		12.556	
4	3-0½			6	(See Notes)	2-5½	150	76.919	BOR, BFP(-1.999)
3	3-0½		200.67	6.3570		2-5½	0.000949	2.001	
3	3-0½			6	(See Notes)	7-0	150	78.920	2E(26-7)
2	7-0		200.67	6.3570		53-2	0.000949	-1.716	
						60-2		0.057	

Pipe Information										
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)		
						Total (Foot)		Friction(Pf)		
2	7-0			6	Supply (See Notes)	263-10	140	77.261	Avl. Pressure @ Supply: 81.318 4E(20-1), EE(10-0½), S	
1	7-0		200.67	6.1600		110-5½	0.001256			
						374-3½				0.470
			100.00					77.731	Hose Allowance At Source	
1			300.67						Total(Pt) Route 1	
1006	17-6	5.6	14.83	1	(See Notes)	3-1	100	7.010	••••• Route 2 ••••• Sprinkler, T(3-7), E(1-5), PO(3-7)	
						8-6½	0.104805			-0.220
1054	18-0		14.83	1.0490		11-8				1.221
								8.010	Total(Pt) Route 2	
1107	17-5	5.6	15.13	1	(See Notes)	3-0½	100	7.303	••••• Route 3 ••••• Sprinkler, T(3-7), E(1-5), PO(3-7)	
						8-6½	0.108855			-0.240
1055	17-11½		15.13	1.0490		11-7				1.262
								8.326	Total(Pt) Route 3	
1000	10-0½	5.6	15.29	1	(See Notes)	1-0	100	7.455	••••• Route 4 ••••• Sprinkler, PO(3-7)	
						3-7	0.110943			
1050	10-0½		15.29	1.0490		4-7				0.508
1050	10-0½			1½	(See Notes)	8-3½	100	7.963	Sprinkler, T(8-0½)	
							0.009760			-0.015
1001	10-1		15.29	1.7280		8-3½				0.081
1001	10-1	5.6	15.87	1½	(See Notes)	13-11	100	8.029	Sprinkler	
							0.036424			-0.025
1003	10-1½		31.16	1.7280		13-11				0.507
1003	10-1½	5.6	16.34	1½	(See Notes)	7-8	100	8.510	Sprinkler, T(8-0½)	
						8-0½	0.079448			-0.014
1051	10-2		47.49	1.7280		15-8½				1.248
1051	10-2		16.81	1½	(See Notes)	9-2	100	9.745	Flow (q) from Route 7 2E(4-0½)	
						8-0½	0.139165			-3.179
1052	17-6		64.30	1.7280		17-2½				2.397
1052	17-6			2	(See Notes)	5-5	100	8.963	Flow (q) from Route 7 2E(4-0½)	
							0.047263			
1057	17-6		64.30	2.1570		5-5				0.255
								9.218	Total(Pt) Route 4	

Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
										Node 2
1008	10-0½	5.6	15.77	1	(See Notes)	1-0	100	7.929		
1058	10-0½		15.77	1.0490		3-7	0.117463			
						4-7		0.537		
1058	10-0½			1½		7-3½	100	8.466		
1009	10-1		15.77	1.7280			0.010333	-0.013		
						7-3½		0.075		
1009	10-1	5.6	16.35	1½	(See Notes)	10-10½	100	8.529	Sprinkler	
1059	10-1½		32.12	1.7280			0.038540	-0.020		
						10-10½		0.419		
1059	10-1½		16.46	1½		9-0	100	8.928	Flow (q) from Route 6	
1060	10-2		48.58	1.7280			0.082839	-0.016		
						9-0		0.746		
1060	10-2		17.01	1½	(See Notes)	12-2	100	9.657	Flow (q) from Route 8 3E(4-0½)	
1061	17-6		65.59	1.7280		12-1	0.144373	-3.184		
						24-2½		3.497		
1061	17-6			2	(See Notes)	1-3	100	9.971	T(7-5½)	
1062	17-6		65.59	2.1570		7-5½	0.049031			
						8-8½		0.426		
								10.397	Total(Pt) Route 5	
1010	6-6½	5.6	16.46	1	(See Notes)	5-11½	100	8.635	••••• Route 6 ••••• Sprinkler, T(3-7), E(1-5), PO(3-7)	
1059	10-1½		16.46	1.0490		8-6½	0.127106	-1.550		
						14-6		1.843		
								8.928	Total(Pt) Route 6	
1004	10-2	5.6	16.81	1	(See Notes)	1-0	100	9.010	••••• Route 7 ••••• Sprinkler, PO(3-7)	
109	10-2		16.81	1.0490		3-7	0.132199			
						4-7		0.606		
109	10-2			1½	(See Notes)	2-8	100	9.616	T(8-0½)	
1051	10-2		16.81	1.7280		8-0½	0.011630	0.005		
						10-8½		0.125		
								9.745	Total(Pt) Route 7	
1011	6-7½	5.6	17.01	1	(See Notes)	5-11½	100	9.230	••••• Route 8 ••••• Sprinkler, T(3-7), E(1-5), PO(3-7)	
1060	10-2		17.01	1.0490		8-6½	0.135187	-1.535		
						14-6		1.962		

Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)			
								9.657	Total(Pt) Route 8

Equivalent Pipe Lengths of Valves and Fittings (C=120 only)

C Value Multiplier

$$\left(\frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

Fittings Legend

ALV Alarm Valve	AngV Angle Valve	b Bushing
BaIV Ball Valve	BFP Backflow Preventer	BV Butterfly Valve
C Cross Flow Turn 90°	cplg Coupling	Cr Cross Run
CV Check Valve	DelV Deluge Valve	DPV Dry Pipe Valve
E 90° Elbow	EE 45° Elbow	Ee1 11¼° Elbow
Ee2 22½° Elbow	f Flow Device	fd Flex Drop
FDC Fire Department Connection	fE 90° FireLock(TM) Elbow	fEE 45° FireLock(TM) Elbow
flg Flange	FN Floating Node	fT FireLock(TM) Tee
g Gauge	GloV Globe Valve	GV Gate Valve
Ho Hose	Hose Hose	HV Hose Valve
Hyd Hydrant	LtE Long Turn Elbow	mecT Mechanical Tee
Noz Nozzle	P1 Pump In	P2 Pump Out
PIV Post Indicating Valve	PO Pipe Outlet	PrV Pressure Relief Valve
PRV I Pressure Reducing Valve In	PRV C Pressure Reducing Valve Out	red Reducer/Adapter
S Supply	sCV Swing Check Valve	SFx Seismic Flex
Spr Sprinkler	St Strainer	T Tee Flow Turn 90°
Tr Tee Run	U Union	WirF Wirsbo
WMV Water Meter Valve	Z Cap	



Check Point Gauge Data

Job Number: 70120 - REMOTE AREA L0A1
Report Description: Light Hazard (L0A1)

Gauge	Available Static Pressure (psi)	Available Residual Pressure (psi)	Required Residual Pressure (nsi)	K-Factor(K)	Flow(gpm)	Elevation(Foot)
BOR (3)	83.716	82.507	78.920	22.59	200.67	3-0½

Hydraulic Calculations

for

Project Name: BRADLEY PARK CARE CENTER: (70120)

Location: 707 39TH AVE SE, BLDG B, , PUYALLUP, WA 98374

Drawing Name: 70120 WBP Care Center R01 Level 0 Basement

Calculation Date: 4/10/2026

Design

Remote Area Number: LOA2
Remote Area Location: POOL MECH. 0116
Occupancy Classification: Light Hazard
Commodity Classification: N/A

Density: 0.100gpm/ft²
Area of Application: 1500.00ft² (Actual 193.60ft²)
Coverage per Sprinkler: 130.00ft²
Type of sprinklers calculated: Upright
No. of sprinklers calculated: 5
No. of nozzles calculated: 0

In-rack Demand: N/A gpm at Node: N/A
Hose Streams: 100.00 at Node: 1 Type: Allowance at Source

Total Water Required (including Hose Streams where applicable):
From Water Supply at Node 1: 177.34 @ 20.271 (Safety Margin = 61.472)

Type of System: WET
Volume of Dry/PreAction/Antifreeze/OtherAgent System: N/A

Name of Contractor: RED HAWK FIRE PROTECTION, LLC
Address: 801 VALLEY AVE NW, SUITE D, PUYALLUP, WA 98371
Phone Number: 253-604-7311
Name of designer: BROOKE MCDANIELS
Authority Having Jurisdiction: : CITY OF PUYALLUP


Notes:

Summary Notes:

Water Supply at Node 1

1 System Demand
3 Available Water Supply

Job Name: BRADLEY PARK CARE CENTER
 Job Number: 70120 - REMOTE AREA L0A2
 Report Description: Light Hazard (LOA2)
 Remote Area Number: LOA2



Curve	Data Point	Hydraulic Calculation Results	Additional Data
1	1B	Required Pressure at System Demand: 20.271 @ 77.34	Available Flow @ 20 PSI: 3441.74
	1C	Required Pressure at System Demand (Including Hose Allowance at Source): 20.271 @ 177.34	
3	3A	Available Static Pressure at Water Supply at Node 1: 82.000	
	3B	Available Residual Pressure at System Demand: 81.743 @ 177.34	
	3C	Available Residual Pressure & Flow at Water Supply at Node 1: 24.000 @ 3320.00	



Summary Of Outflowing Devices

Job Number: 70120 - REMOTE AREA LOA2
Report Description: Light Hazard (LOA2)

Device	Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)			
Sprinkler 1100	16.17	13.00	5.6	8.336			
⇒ Sprinkler 1101	14.82	13.00	5.6	7.000			
Sprinkler 1102	15.74	13.00	5.6	7.896			
Sprinkler 1104	14.85	13.00	5.6	7.029			
Sprinkler 1105	15.77	13.00	5.6	7.929			

⇒ Most Demanding Sprinkler Data

Supply Analysis							
Node	Name	Static (psi)	Residual (psi)	@ Flow (gpm)	Available (psi)	@ Total Demand (gpm)	Required Pressure (psi)
1	Water Supply	82.000	24.000	3320.00	81.743	177.34	20.271

Node Analysis					
Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1	7-0	Supply	20.271	77.34	
1100	10-0	Sprinkler	8.336	16.17	
1101	10-0	Sprinkler	7.000	14.82	
1102	10-0	Sprinkler	7.896	15.74	
1104	10-0	Sprinkler	7.029	14.85	
1105	10-0	Sprinkler	7.929	15.77	
2	7-0		20.191	0.00	
3	3-0½	Gauge	21.897	0.00	BOR, BFP(-4.114)
5	3-0½		17.782	0.00	
1150	10-0		8.534	0.00	
1151	10-0		8.540	0.00	
1152	10-0		8.575	0.00	
1153	8-6		9.833	0.00	
1260	8-6		15.258	0.00	

Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
										Node 2
1101	10-0	5.6	14.82	1	(See Notes)	12-0	120	7.000		
1102	10-0		14.82	1.0490		12-0	0.074703	0.896		
1102	10-0	5.6	15.74	1¼	(See Notes)	2-7	120	7.896	Sprinkler, PO(6-0)	
1151	10-0		30.55	1.3800		6-0	0.074951	0.644		
1151	10-0		16.17	2½		4-11	120	8.540	Flow (q) from Route 3	
1152	10-0		46.72	2.6350		4-11	0.007048	0.035		
1152	10-0		30.62	2½	(See Notes)	5-8	120	8.575	Flow (q) from Route 2 T(16-5½), 2fE(5-11)	
1153	8-6		77.34	2.6350		28-3½	0.017904	0.650		
1153	8-6			2½	(See Notes)	33-11½		0.608		
1260	8-6		77.34	2.4230		194-4	150	9.833	2cplg(2-0), 3E(12-0), T(12-0), 29Tr(2-0)	
1260	8-6			4	(See Notes)	110-0	0.017827	5.425		
5	3-0½		77.34	4.3100		304-4				
1260	8-6			4	(See Notes)	10-1	120	15.258	2fE(9-5½), sCV(4-2), BV(7-8), PO(27-10½), C(27-10½)	
5	3-0½		77.34	4.3100		86-6½	0.001630	2.366		
5	3-0½			6	(See Notes)	96-7½		0.158		
5	3-0½			6	(See Notes)	4-6½	150	17.782	BOR, BFP(-4.114)	
3	3-0½		77.34	6.3570		4-6½	0.000163	4.115		
3	3-0½			6	(See Notes)	7-0	150	21.897	2E(26-7)	
2	7-0		77.34	6.3570		53-2	0.000163	-1.716		
2	7-0			6	(See Notes)	60-2		0.010		
2	7-0			6	Supply (See Notes)	263-10	140	20.191	Avl.Pressure @ Supply: 81.743 4E(20-1), EE(10-0½), S	
1	7-0		77.34	6.1600		110-5½	0.000215			
1	7-0			6	(See Notes)	374-3½		0.081		
			100.00					20.271	Hose Allowance At Source	
1			177.34						Total(Pt) Route 1	
1104	10-0	5.6	14.85	1	(See Notes)	12-0	120	7.029Route 2..... Sprinkler	
1105	10-0		14.85	1.0490		12-0	0.074988	0.900		

Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
1105	10-0	5.6	15.77	1¼	(See Notes)	2-7	120	7.929	Sprinkler, PO(6-0)
1152	10-0		30.62	1.3800		6-0	0.075236		
						8-7		0.646	
								8.575	Total(Pt) Route 2
1100	10-0	5.6	16.17	1¼	(See Notes)	2-7	120	8.336 Route 3 Sprinkler, PO(6-0)
1150	10-0		16.17	1.3800		6-0	0.023093		
						8-7		0.198	
1150	10-0			2½		5-9	120	8.534	
1151	10-0		16.17	2.6350		5-9	0.000990	0.006	
								8.540	Total(Pt) Route 3

Equivalent Pipe Lengths of Valves and Fittings (C=120 only)

C Value Multiplier

$$\left(\frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

Fittings Legend

ALV Alarm Valve	AngV Angle Valve	b Bushing
BaIV Ball Valve	BFP Backflow Preventer	BV Butterfly Valve
C Cross Flow Turn 90°	cplg Coupling	Cr Cross Run
CV Check Valve	DelV Deluge Valve	DPV Dry Pipe Valve
E 90° Elbow	EE 45° Elbow	Ee1 11¼° Elbow
Ee2 22½° Elbow	f Flow Device	fd Flex Drop
FDC Fire Department Connection	fE 90° FireLock(TM) Elbow	fEE 45° FireLock(TM) Elbow
flg Flange	FN Floating Node	fT FireLock(TM) Tee
g Gauge	GloV Globe Valve	GV Gate Valve
Ho Hose	Hose Hose	HV Hose Valve
Hyd Hydrant	LtE Long Turn Elbow	mecT Mechanical Tee
Noz Nozzle	P1 Pump In	P2 Pump Out
PIV Post Indicating Valve	PO Pipe Outlet	PrV Pressure Relief Valve
PRV I Pressure Reducing Valve In	PRV C Pressure Reducing Valve Out	red Reducer/Adapter
S Supply	sCV Swing Check Valve	SFx Seismic Flex
Spr Sprinkler	St Strainer	T Tee Flow Turn 90°
Tr Tee Run	U Union	WirF Wirsbo
WMV Water Meter Valve	Z Cap	



Check Point Gauge Data

Job Number: 70120 - REMOTE AREA LOA2
Report Description: Light Hazard (LOA2)

Gauge	Available Static Pressure (psi)	Available Residual Pressure (psi)	Required Residual Pressure (nsi)	K-Factor(K)	Flow(gpm)	Elevation(Foot)
BOR (3)	83.716	83.369	21.897	16.53	77.34	3-0½

Hydraulic Calculations

for

Project Name: BRADLEY PARK CARE CENTER: (70120)

Location: 707 39TH AVE SE, BLDG B, , PUYALLUP, WA 98374

Drawing Name: 70120 WBP Care Center R01 Level 0 Basement

Calculation Date: 4/10/2026

Design

Remote Area Number: L0A3
Remote Area Location: POOL MECH 0116
Occupancy Classification: Light Hazard

Density: 0.100gpm/ft²
Area of Application: 1500.00ft² (Actual 985.82ft²)
Coverage per Sprinkler: 196.00ft²
Type of sprinklers calculated: Upright, Pendent
No. of sprinklers calculated: 12
No. of nozzles calculated: 0

In-rack Demand: N/A gpm at Node: N/A
Hose Streams: 100.00 at Node: 1 Type: Allowance at Source

Total Water Required (including Hose Streams where applicable):
From Water Supply at Node 1: 374.98 @ 70.452 (Safety Margin = 10.522)

Type of System: WET
Volume of Dry/PreAction/Antifreeze/OtherAgent System: N/A

Name of Contractor: RED HAWK FIRE PROTECTION, LLC
Address: 801 VALLEY AVE NW, SUITE D, PUYALLUP, WA 98371
Phone Number: 253-604-7311
Name of designer: BROOKE MCDANIELS
Authority Having Jurisdiction: : CITY OF PUYALLUP


Notes:

Summary Notes:

Water Supply at Node 1

1 System Demand
3 Available Water Supply

Job Name: BRADLEY PARK CARE CENTER
 Job Number: 70120 - REMOTE AREA L0A3
 Report Description: Light Hazard (L0A3)
 Remote Area Number: L0A3



Curve	Data Point	Hydraulic Calculation Results	Additional Data
1	1B	Required Pressure at System Demand: 70.452 @ 274.98	Available Flow @ 20 PSI: 3441.74
	1C	Required Pressure at System Demand (Including Hose Allowance at Source): 70.452 @ 374.98	
3	3A	Available Static Pressure at Water Supply at Node 1: 82.000	
	3B	Available Residual Pressure at System Demand: 80.974 @ 374.98	
	3C	Available Residual Pressure & Flow at Water Supply at Node 1: 24.000 @ 3320.00	



Summary Of Outflowing Devices

Job Number: 70120 - REMOTE AREA L0A3
Report Description: Light Hazard (L0A3)

Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)			
Sprinkler	862	27.82	19.60	5.6	24.680			
Sprinkler	1200	20.60	19.60	5.6	13.537			
Sprinkler	1201	22.38	19.60	5.6	15.971			
Sprinkler	1202	22.31	19.60	5.6	15.879			
Sprinkler	1203	24.50	19.60	5.6	19.137			
➡ Sprinkler	1204	19.60	19.60	5.6	12.250			
Sprinkler	1205	20.77	19.60	5.6	13.754			
Sprinkler	1206	24.72	19.60	5.6	19.480			
Sprinkler	1207	19.87	19.60	5.6	12.587			
Sprinkler	1208	21.05	19.60	5.6	14.130			
Sprinkler	1209	25.04	19.60	5.6	20.001			
Sprinkler	1210	26.32	19.60	5.6	22.085			

➡ Most Demanding Sprinkler Data

Supply Analysis							
Node	Name	Static (psi)	Residual (psi)	@ Flow (gpm)	Available (psi)	@ Total Demand (gpm)	Required Pressure (psi)
1	Water Supply	82.000	24.000	3320.00	80.974	374.98	70.452

Node Analysis					
Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1	7-0	Supply	70.452	274.98	
862	10-0	Sprinkler	24.680	27.82	
1200	10-0	Sprinkler	13.537	20.60	
1201	10-0	Sprinkler	15.971	22.38	
1202	6-6½	Sprinkler	15.879	22.31	
1203	6-7	Sprinkler	19.137	24.50	
1204	10-0	Sprinkler	12.250	19.60	
1205	10-0	Sprinkler	13.754	20.77	
1206	10-0	Sprinkler	19.480	24.72	
1207	10-0	Sprinkler	12.587	19.87	
1208	10-0	Sprinkler	14.130	21.05	
1209	10-0	Sprinkler	20.001	25.04	
1210	10-0	Sprinkler	22.085	26.32	
2	7-0		69.609	0.00	
3	3-0½	Gauge	71.223	0.00	BOR, BFP(-1.846)
5	3-0½		69.369	0.00	
1250	10-0		17.022	0.00	
1251	10-0		17.525	0.00	

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1252	10-0		19.234	0.00	
1253	8-8½		29.573	0.00	
1254	10-0		26.581	0.00	
1255	8-6		30.289	0.00	
1256	10-0		27.280	0.00	
1257	8-6		31.064	0.00	
1258	10-0		29.731	0.00	
1259	8-6		32.556	0.00	
1260	8-6		65.356	0.00	

Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
	Node 2		Elev 2 (Foot)	Total Flow (Q)		Actual ID	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	
		Total (Foot)			Friction(Pf)				
1204	10-0	5.6	19.60	1	(See Notes)	12-0	120	12.250	
1205	10-0		19.60	1.0490		12-0	0.125357	1.504	
1205	10-0	5.6	20.77	1	(See Notes)	12-0	120	13.754	Sprinkler
1206	10-0		40.37	1.0490		12-0	0.477153	5.726	
1206	10-0	5.6	24.72	1¼	(See Notes)	23-4½	120	19.480	Sprinkler
1254	10-0		65.08	1.3800		23-4½	0.303655	7.101	
1254	10-0			1¼	(See Notes)	2-0	150	26.581	E(8-0), T(6-0)
1255	8-6		65.08	1.3940		14-0	0.191315	0.650	
						16-0		3.057	
1255	8-6		89.80	2½	(See Notes)	8-0½	150	30.289	Flow (q) from Route 3 2Tr(2-0)
1257	8-6		154.88	2.4230		4-0	0.064426		
						12-0½		0.776	
1257	8-6		65.96	2½	(See Notes)	8-0	150	31.064	Flow (q) from Route 2 2Tr(2-0)
1259	8-6		220.84	2.4230		4-0	0.124201		
						12-0		1.491	
1259	8-6		54.14	2½	(See Notes)	114-0½	150	32.556	Flow (q) from Route 6 18Tr(2-0), 2E(12-0), cplg(2-0)
1260	8-6		274.98	2.4230		62-0	0.186329		
						176-0½		32.800	
1260	8-6			4	(See Notes)	10-1	120	65.356	2fE(9-5½), sCV(4-2), BV(7-8), PO(27-10½), C(27-10½)
5	3-0½		274.98	4.3100		86-6½	0.017040	2.366	
						96-7½		1.647	
5	3-0½			6	(See Notes)	4-6½	150	69.369	BOR, BFP(-1.846)
3	3-0½		274.98	6.3570		4-6½	0.001699	1.854	
3	3-0½			6	(See Notes)	7-0	150	71.223	2E(26-7)
2	7-0		274.98	6.3570		53-2	0.001699	-1.716	
						60-2		0.102	
2	7-0			6	Supply (See Notes)	263-10	140	69.609	Avl. Pressure @ Supply: 80.974 4E(20-1), EE(10-0½), S
1	7-0		274.98	6.1600		110-5½	0.002250		
						374-3½		0.842	

Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
					Total (Foot)			Friction(Pf)	
			100.00					70.452	Hose Allowance At Source
1			374.98						Total(Pt) Route 1
1207	10-0	5.6	19.87	1	(See Notes)	12-0	120	12.587	••••• Route 2 ••••• Sprinkler
1208	10-0		19.87	1.0490		12-0	0.128548	1.543	
1208	10-0	5.6	21.05	1	(See Notes)	12-0	120	14.130	Sprinkler
1209	10-0		40.92	1.0490		12-0	0.489245	5.871	
1209	10-0	5.6	25.04	1¼	(See Notes)	23-4½	120	20.001	Sprinkler
1256	10-0		65.96	1.3800		23-4½	0.311277	7.279	
1256	10-0			1¼	(See Notes)	2-0	150	27.280	E(8-0), T(6-0)
1257	8-6		65.96	1.3940		14-0	0.196117	0.650	
						16-0		3.134	
								31.064	Total(Pt) Route 2
1200	10-0	5.6	20.60	1	(See Notes)	13-8½	120	13.537	••••• Route 3 ••••• Sprinkler,
1201	10-0		20.60	1.0490		4-0	0.137491		2E(2-0)
						17-8½		2.434	
1201	10-0	5.6	22.38	1¼	(See Notes)	7-5½	120	15.971	Sprinkler
1250	10-0		42.98	1.3800		7-5½	0.140943	1.052	
1250	10-0			1¼	(See Notes)	4-8	150	17.022	Tr(1-0)
1251	10-0		42.98	1.3940		1-0	0.088800		
						5-8		0.503	
1251	10-0		22.31	1¼	(See Notes)	7-10½	150	17.525	Flow (q) from Route 4
1252	10-0		65.30	1.3940		1-0	0.192476		Tr(1-0)
						8-10½		1.709	
1252	10-0		24.50	1¼	(See Notes)	18-2	150	19.234	Flow (q) from Route 5
1253	8-8½		89.80	1.3940		10-0	0.347004	0.562	Tr(1-0), E(8-0), b(1-0)
						28-2		9.777	
1253	8-8½			2½	(See Notes)	10-8½	150	29.573	T(12-0), 2Tr(2-0)
1255	8-6		89.80	2.4230		16-0	0.023501	0.088	
						26-8½		0.627	

Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
								30.289	Total(Pt) Route 3
1202	6-6½	5.6	22.31	1	(See Notes)	1-9	150	15.879	••••• Route 4 ••••• Sprinkler, T(5-0), fd(31-0)
1251	10-0		22.31	1.1010		36-0	0.083324	-1.499	
						37-9		3.146	
								17.525	Total(Pt) Route 4
1203	6-7	5.6	24.50	1	(See Notes)	3-11	150	19.137	••••• Route 5 ••••• Sprinkler, E(7-0), T(5-0)
1252	10-0		24.50	1.1010		12-0	0.099026	-1.480	
						15-11		1.577	
								19.234	Total(Pt) Route 5
1210	10-0	5.6	26.32	1	(See Notes)	12-0	120	22.085	••••• Route 6 ••••• Sprinkler
862	10-0		26.32	1.0490		12-0	0.216233	2.595	
862	10-0	5.6	27.82	1¼	(See Notes)	23-4½	120	24.680	Sprinkler
1258	10-0		54.14	1.3800		23-4½	0.215981	5.051	
1258	10-0			1¼	(See Notes)	2-0	150	29.731	E(8-0), T(6-0)
1259	8-6		54.14	1.3940		14-0	0.136077	0.650	
						16-0		2.175	
								32.556	Total(Pt) Route 6

Equivalent Pipe Lengths of Valves and Fittings (C=120 only)

C Value Multiplier

$$\left(\frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

Fittings Legend

ALV Alarm Valve	AngV Angle Valve	b Bushing
BaIV Ball Valve	BFP Backflow Preventer	BV Butterfly Valve
C Cross Flow Turn 90°	cplg Coupling	Cr Cross Run
CV Check Valve	DelV Deluge Valve	DPV Dry Pipe Valve
E 90° Elbow	EE 45° Elbow	Ee1 11¼° Elbow
Ee2 22½° Elbow	f Flow Device	fd Flex Drop
FDC Fire Department Connection	fE 90° FireLock(TM) Elbow	fEE 45° FireLock(TM) Elbow
flg Flange	FN Floating Node	fT FireLock(TM) Tee
g Gauge	GloV Globe Valve	GV Gate Valve
Ho Hose	Hose Hose	HV Hose Valve
Hyd Hydrant	LtE Long Turn Elbow	mecT Mechanical Tee
Noz Nozzle	P1 Pump In	P2 Pump Out
PIV Post Indicating Valve	PO Pipe Outlet	PrV Pressure Relief Valve
PRV I Pressure Reducing Valve In	PRV C Pressure Reducing Valve Out	red Reducer/Adapter
S Supply	sCV Swing Check Valve	SFx Seismic Flex
Spr Sprinkler	St Strainer	T Tee Flow Turn 90°
Tr Tee Run	U Union	WirF Wirsbo
WMV Water Meter Valve	Z Cap	



Check Point Gauge Data

Job Number: 70120 - REMOTE AREA L0A3
Report Description: Light Hazard (L0A3)

Gauge	Available Static Pressure (psi)	Available Residual Pressure (psi)	Required Residual Pressure (nsi)	K-Factor(K)	Flow(gpm)	Elevation(Foot)
BOR (3)	83.716	81.745	71.223	32.58	274.98	3-0½

Hydraulic Calculations

for

Project Name: BRADLEY PARK CARE CENTER: (70120)

Location: 707 39TH AVE SE, BLDG B, , PUYALLUP, WA 98374

Drawing Name: 70120 WBP Care Center R01 Level 0 Basement

Calculation Date: 4/10/2026

Design

Remote Area Number: L0A4
Remote Area Location: CRAWL SPACE CS01
Occupancy Classification: Light Hazard
Commodity Classification: N/A

Density: 0.100gpm/ft²
Area of Application: 1950.00ft² (Actual 1956.21ft²)
Coverage per Sprinkler: 130.00ft²
Type of sprinklers calculated: Upright
No. of sprinklers calculated: 21
No. of nozzles calculated: 0

In-rack Demand: N/A gpm at Node: N/A
Hose Streams: 100.00 at Node: 1 Type: Allowance at Source

Total Water Required (including Hose Streams where applicable):
From Water Supply at Node 1: 452.96 @ 62.265 (Safety Margin = 18.279)

Type of System: DRY
Volume of Dry/PreAction/Antifreeze/OtherAgent System: 411.42gal

Name of Contractor: RED HAWK FIRE PROTECTION, LLC
Address: 801 VALLEY AVE NW, SUITE D, PUYALLUP, WA 98371
Phone Number: 253-604-7311
Name of designer: BROOKE MCDANIELS
Authority Having Jurisdiction: : CITY OF PUYALLUP


Notes:

Summary Notes:

Water Supply at Node 1

■ 1 System Demand
■ 3 Available Water Supply

Job Name: BRADLEY PARK CARE CENTER
 Job Number: 70120 - REMOTE AREA L0A4
 Report Description: Light Hazard (L0A4)
 Remote Area Number: L0A4



Curve	Data Point	Hydraulic Calculation Results	Additional Data
1	1B	Required Pressure at System Demand: 62.265 @ 352.96	Available Flow @ 20 PSI: 3441.74
	1C	Required Pressure at System Demand (Including Hose Allowance at Source): 62.265 @ 452.96	
3	3A	Available Static Pressure at Water Supply at Node 1: 82.000	
	3B	Available Residual Pressure at System Demand: 80.544 @ 452.96	
	3C	Available Residual Pressure & Flow at Water Supply at Node 1: 24.000 @ 3320.00	



Summary Of Outflowing Devices

Device	Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)			
⇒ Sprinkler 1300	14.82	13.00	5.6	7.000			
Sprinkler 1301	15.09	13.00	5.6	7.264			
Sprinkler 1302	16.03	13.00	5.6	8.191			
Sprinkler 1303	17.99	13.00	5.6	10.325			
Sprinkler 1304	15.04	13.00	5.6	7.210			
Sprinkler 1305	15.10	13.00	5.6	7.273			
Sprinkler 1306	16.05	13.00	5.6	8.213			
Sprinkler 1307	18.03	13.00	5.6	10.369			
Sprinkler 1308	15.19	13.00	5.6	7.358			
Sprinkler 1309	15.26	13.00	5.6	7.423			
Sprinkler 1310	16.21	13.00	5.6	8.380			
Sprinkler 1311	18.21	13.00	5.6	10.576			
Sprinkler 1312	16.13	13.00	5.6	8.298			
Sprinkler 1313	16.27	13.00	5.6	8.446			
Sprinkler 1314	17.09	13.00	5.6	9.318			
Sprinkler 1315	18.73	13.00	5.6	11.185			
Sprinkler 1316	16.51	13.00	5.6	8.692			
Sprinkler 1317	16.65	13.00	5.6	8.845			
Sprinkler 1318	17.49	13.00	5.6	9.755			
Sprinkler 1319	19.16	13.00	5.6	11.703			
Sprinkler 1320	21.90	13.00	5.6	15.290			

⇒ Most Demanding Sprinkler Data

Supply Analysis							
Node	Name	Static (psi)	Residual (psi)	@ Flow (gpm)	Available (psi)	@ Total Demand (gpm)	Required Pressure (psi)
1	Water Supply	82.000	24.000	3320.00	80.544	452.96	62.265

Node Analysis					
Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1	7-0	Supply	62.265	352.96	
1300	10-1	Sprinkler	7.000	14.82	
1301	10-0½	Sprinkler	7.264	15.09	
1302	10-0	Sprinkler	8.191	16.03	
1303	9-11½	Sprinkler	10.325	17.99	
1304	10-0½	Sprinkler	7.210	15.04	
1305	10-0	Sprinkler	7.273	15.10	
1306	9-11½	Sprinkler	8.213	16.05	
1307	9-11	Sprinkler	10.369	18.03	
1308	10-0	Sprinkler	7.358	15.19	
1309	9-11½	Sprinkler	7.423	15.26	
1310	9-11	Sprinkler	8.380	16.21	
1311	9-10½	Sprinkler	10.576	18.21	
1312	10-0	Sprinkler	8.298	16.13	
1313	9-11½	Sprinkler	8.446	16.27	
1314	9-11	Sprinkler	9.318	17.09	
1315	9-10½	Sprinkler	11.185	18.73	
1316	9-11½	Sprinkler	8.692	16.51	

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1317	9-11	Sprinkler	8.845	16.65	
1318	9-10½	Sprinkler	9.755	17.49	
1319	9-10	Sprinkler	11.703	19.16	
1320	9-10	Sprinkler	15.290	21.90	
2	7-0		60.929	0.00	
3	3-0½	Gauge	62.483	0.00	BOR, BFP(-1.643)
4	3-0½		60.833	0.00	
1350	8-1½		8.671	0.00	
1351	8-1		8.965	0.00	
1352	8-0½		9.993	0.00	
1354	8-0		12.356	0.00	
1355	8-0		15.144	0.00	
1356	8-1½		8.674	0.00	
1357	8-1		8.975	0.00	
1358	8-0½		10.017	0.00	
1359	8-0		12.405	0.00	
1360	7-11½		15.215	0.00	
1361	8-1		8.834	0.00	
1362	8-0½		9.140	0.00	
1363	8-0		10.202	0.00	
1364	7-11½		12.634	0.00	
1365	7-11½		15.498	0.00	

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1366	8-0½		9.849	0.00	
1367	8-0		10.275	0.00	
1368	7-11½		11.241	0.00	
1369	7-11		13.307	0.00	
1370	7-11		15.892	0.00	
1371	8-0½		10.274	0.00	
1372	8-0		10.717	0.00	
1373	7-11½		11.725	0.00	
1374	7-11		13.880	0.00	
1375	7-11		16.577	0.00	
1376	7-10½		17.843	0.00	
1377	7-10½		18.160	0.00	

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
1300	10-1	5.6	14.82	1	(See Notes)	2-11½	100	7.000	••••• Route 1 ••••• Sprinkler, E(1-5), T(3-7)
1350	8-1½		14.82	1.0490		5-0	0.104671	0.840	
						7-11½		0.831	
1350	8-1½			1¼		10-0	100	8.671	
1351	8-1		14.82	1.3800		10-0	0.027529	0.018	
								0.275	
1351	8-1		15.09	1¼		10-0	100	8.965	Flow (q) from Route 3
1352	8-0½		29.91	1.3800		10-0	0.100966	0.018	
								1.010	
1352	8-0½		16.03	1¼		10-6	100	9.993	Flow (q) from Route 7
1354	8-0		45.94	1.3800		10-6	0.223318	0.019	
								2.345	
1354	8-0		17.99	1¼	(See Notes)	2-6	100	12.356	Flow (q) from Route 16 PO(4-3½)
1355	8-0		63.93	1.3800		4-3½	0.411619	0.004	
						6-9		2.783	
1355	8-0			3		10-0	100	15.144	
1360	7-11½		63.93	3.2600		10-0	0.006257	0.009	
								0.063	
1360	7-11½		64.22	3		12-0	100	15.215	Flow (q) from Route 2
1365	7-11½		128.15	3.2600		12-0	0.022649	0.011	
								0.272	
1365	7-11½		64.87	3		8-0	100	15.498	Flow (q) from Route 5
1370	7-11		193.02	3.2600		8-0	0.048321	0.007	
								0.387	
1370	7-11		68.23	3		8-0	100	15.892	Flow (q) from Route 9
1375	7-11		261.25	3.2600		8-0	0.084591	0.007	
								0.678	
1375	7-11		69.81	3		12-0	100	16.577	Flow (q) from Route 12
1377	7-10½		331.06	3.2600		12-0	0.131099	0.011	
								1.573	
1377	7-10½		21.90	3	(See Notes)	227-1	100	18.160	Flow (q) from Route 21 T(12-5½), E(6-8½), DPV(4-8½), BV(9-7), PO(14-4½)
4	3-0½		352.96	3.2600		47-10	0.147590	2.100	
						274-11		40.572	

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
4	3-0½			6	(See Notes)	2-5½	150	60.833	BOR, BFP(-1.643)
3	3-0½		352.96	6.3570		2-5½	0.002697	1.650	
3	3-0½			6	(See Notes)	7-0	150	62.483	2E(26-7)
2	7-0		352.96	6.3570		53-2	0.002697	-1.716	
						60-2		0.162	
2	7-0			6	Supply (See Notes)	263-10	140	60.929	Avl.Pressure @ Supply: 80.544 4E(20-1), EE(10-0½), S
1	7-0		352.96	6.1600		110-5½	0.003571		
						374-3½		1.337	
			100.00					62.265	Hose Allowance At Source
1			452.96						Total(Pt) Route 1
1304	10-0½	5.6	15.04	1	(See Notes)	2-11½	100	7.210	••••• Route 2 ••••• Sprinkler, 2E(1-5)
1356	8-1½		15.04	1.0490		2-10	0.107566	0.840	
						5-9½		0.624	
1356	8-1½			1¼		10-0	100	8.674	Flow (q) from Route 4
								0.018	
1357	8-1		15.04	1.3800		10-0	0.028290	0.283	
1357	8-1		15.10	1¼		10-0	100	8.975	Flow (q) from Route 8
								0.018	
1358	8-0½		30.14	1.3800		10-0	0.102404	1.024	Flow (q) from Route 17 PO(4-3½)
1358	8-0½		16.05	1¼		10-6	100	10.017	
								0.019	
1359	8-0		46.19	1.3800		10-6	0.225582	2.369	
1359	8-0		18.03	1¼	(See Notes)	2-6	100	12.405	Flow (q) from Route 17 PO(4-3½)
						4-3½	0.415068	0.004	
1360	7-11½		64.22	1.3800		6-9		2.806	
								15.215	Total(Pt) Route 2
1301	10-0½	5.6	15.09	1	(See Notes)	2-11½	100	7.264	••••• Route 3 ••••• Sprinkler, E(1-5), T(3-7)
1351	8-1		15.09	1.0490		5-0	0.108322	0.840	
						7-11½		0.860	
								8.965	Total(Pt) Route 3

Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
										Node 2
1305	10-0	5.6	15.10	1	(See Notes)	2-11½	100	7.273		
1357	8-1		15.10	1.0490		5-0	0.108447	0.840		
						7-11½		0.861		
								8.975	Total(Pt) Route 4	
1308	10-0	5.6	15.19	1	(See Notes)	2-11½	100	7.358	••••• Route 5 ••••• Sprinkler, 2E(1-5)	
1361	8-1		15.19	1.0490		2-10	0.109610	0.840		
						5-9½		0.636		
1361	8-1			1¼		10-0	100	8.834	Flow (q) from Route 6	
1362	8-0½		15.19	1.3800		10-0	0.028828	0.018		
								0.288		
1362	8-0½		15.26	1¼		10-0	100	9.140		Flow (q) from Route 6
1363	8-0		30.45	1.3800		10-0	0.104348	0.018		
								1.043		
1363	8-0		16.21	1¼		10-6	100	10.202	Flow (q) from Route 10	
1364	7-11½		46.66	1.3800		10-6	0.229847	0.019		
								2.413		
1364	7-11½		18.21	1¼	(See Notes)	2-6	100	12.634		Flow (q) from Route 18 PO(4-3½)
1365	7-11½		64.87	1.3800		4-3½	0.422869	0.004		
						6-9		2.859		
								15.498	Total(Pt) Route 5	
1309	9-11½	5.6	15.26	1	(See Notes)	2-11½	100	7.423	••••• Route 6 ••••• Sprinkler, E(1-5), T(3-7)	
1362	8-0½		15.26	1.0490		5-0	0.110503	0.840		
						7-11½		0.878		
								9.140		Total(Pt) Route 6
1302	10-0	5.6	16.03	1	(See Notes)	2-11½	100	8.191	••••• Route 7 ••••• Sprinkler, E(1-5), T(3-7)	
1352	8-0½		16.03	1.0490		5-0	0.121045	0.840		
						7-11½		0.961		
								9.993		Total(Pt) Route 7
1306	9-11½	5.6	16.05	1	(See Notes)	2-11½	100	8.213	••••• Route 8 ••••• Sprinkler, E(1-5), T(3-7)	
1358	8-0½		16.05	1.0490		5-0	0.121347	0.840		
						7-11½		0.964		
								10.017		Total(Pt) Route 8

Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
	Node 2		Elev 2 (Foot)	Total Flow (Q)		Actual ID	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	
		Total (Foot)			Friction(Pf)				
1312	10-0	5.6	16.13	1	(See Notes)	2-11½	100	8.298	
1366	8-0½		16.13	1.0490		2-10	0.122512	0.840	
						5-9½		0.711	
1366	8-0½			1¼		12-6	100	9.849	
1367	8-0		16.13	1.3800		12-6	0.032221	0.023	
								0.403	
1367	8-0		16.27	1¼		8-1½	100	10.275	Flow (q) from Route 11
1368	7-11½		32.41	1.3800		8-1½	0.117109	0.015	
								0.952	
1368	7-11½		17.09	1¼		8-0	100	11.241	Flow (q) from Route 14
1369	7-11		49.50	1.3800		8-0	0.256422	0.014	
								2.051	
1369	7-11		18.73	1¼	(See Notes)	1-3½	100	13.307	Flow (q) from Route 19 PO(4-3½)
1370	7-11		68.23	1.3800		4-3½	0.464266	0.002	
						2.583			
								15.892	
1310	9-11	5.6	16.21	1	(See Notes)	2-11½	100	8.380 Route 10 Sprinkler, E(1-5), T(3-7)
1363	8-0		16.21	1.0490		5-0	0.123625	0.840	
						7-11½		0.982	
								10.202	
1313	9-11½	5.6	16.27	1	(See Notes)	2-11½	100	8.446 Route 11 Sprinkler, E(1-5), T(3-7)
1367	8-0		16.27	1.0490		5-0	0.124522	0.840	
						7-11½		0.989	
								10.275	
1316	9-11½	5.6	16.51	1	(See Notes)	2-11½	100	8.692 Route 12 Sprinkler, 2E(1-5)
1371	8-0½		16.51	1.0490		2-10	0.127873	0.840	
						5-9½		0.742	
1371	8-0½			1¼		12-6	100	10.274	
1372	8-0		16.51	1.3800		12-6	0.033631	0.023	
								0.420	
1372	8-0		16.65	1¼		8-1½	100	10.717	Flow (q) from Route 13
1373	7-11½		33.16	1.3800		8-1½	0.122225	0.015	
								0.993	

Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
										Node 2
1373	7-11½		17.49	1¼		8-0	100	11.725		
1374	7-11		50.65	1.3800		8-0	0.267588	0.014		
1374	7-11		19.16	1¼	(See Notes)	1-3½	100	13.880	Flow (q) from Route 20 PO(4-3½)	
1375	7-11		69.81	1.3800		4-3½	0.484385	0.002		
						5-7		2.695		
								16.577	Total(Pt) Route 12	
1317	9-11	5.6	16.65	1	(See Notes)	2-11½	100	8.845	***** Route 13 ***** Sprinkler, E(1-5), T(3-7)	
1372	8-0		16.65	1.0490		5-0	0.129953	0.840		
						7-11½		1.032		
								10.717	Total(Pt) Route 13	
1314	9-11	5.6	17.09	1	(See Notes)	2-11½	100	9.318	***** Route 14 ***** Sprinkler, E(1-5), T(3-7)	
1368	7-11½		17.09	1.0490		5-0	0.136375	0.840		
						7-11½		1.083		
								11.241	Total(Pt) Route 14	
1318	9-10½	5.6	17.49	1	(See Notes)	2-11½	100	9.755	***** Route 15 ***** Sprinkler, E(1-5), T(3-7)	
1373	7-11½		17.49	1.0490		5-0	0.142277	0.840		
						7-11½		1.130		
								11.725	Total(Pt) Route 15	
1303	9-11½	5.6	17.99	1	(See Notes)	2-11½	100	10.325	***** Route 16 ***** Sprinkler, E(1-5), T(3-7)	
1354	8-0		17.99	1.0490		5-0	0.149957	0.840		
						7-11½		1.191		
								12.356	Total(Pt) Route 16	
1307	9-11	5.6	18.03	1	(See Notes)	2-11½	100	10.369	***** Route 17 ***** Sprinkler, E(1-5), T(3-7)	
1359	8-0		18.03	1.0490		5-0	0.150542	0.840		
						7-11½		1.196		
								12.405	Total(Pt) Route 17	
1311	9-10½	5.6	18.21	1	(See Notes)	2-11½	100	10.576	***** Route 18 ***** Sprinkler, E(1-5), T(3-7)	
1364	7-11½		18.21	1.0490		5-0	0.153327	0.840		
						7-11½		1.218		
								12.634	Total(Pt) Route 18	

Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
										Node 2
1315	9-10½	5.6	18.73	1	(See Notes)	2-11½	100	11.185		
1369	7-11		18.73	1.0490		5-0	0.161466	0.840		
						7-11½		1.282		
								13.307	Total(Pt) Route 19	
1319	9-10	5.6	19.16	1	(See Notes)	2-11½	100	11.703	••••• Route 20 ••••• Sprinkler, E(1-5), T(3-7)	
1374	7-11		19.16	1.0490		5-0	0.168373	0.840		
						7-11½		1.337		
								13.880	Total(Pt) Route 20	
1320	9-10	5.6	21.90	1	(See Notes)	2-11½	100	15.290	••••• Route 21 ••••• Sprinkler, E(1-5), T(3-7)	
1376	7-10½		21.90	1.0490		5-0	0.215619	0.840		
						7-11½		1.712		
1376	7-10½			1¼	(See Notes)	1-3½	100	17.843	PO(4-3½)	
1377	7-10½		21.90	1.3800		4-3½	0.056709	0.002		
						5-7		0.315		
								18.160	Total(Pt) Route 21	

Equivalent Pipe Lengths of Valves and Fittings (C=120 only)

C Value Multiplier

$$\left(\frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

Fittings Legend

ALV Alarm Valve	AngV Angle Valve	b Bushing
BaIV Ball Valve	BFP Backflow Preventer	BV Butterfly Valve
C Cross Flow Turn 90°	cplg Coupling	Cr Cross Run
CV Check Valve	DelV Deluge Valve	DPV Dry Pipe Valve
E 90° Elbow	EE 45° Elbow	Ee1 11¼° Elbow
Ee2 22½° Elbow	f Flow Device	fd Flex Drop
FDC Fire Department Connection	fE 90° FireLock(TM) Elbow	fEE 45° FireLock(TM) Elbow
flg Flange	FN Floating Node	fT FireLock(TM) Tee
g Gauge	GloV Globe Valve	GV Gate Valve
Ho Hose	Hose Hose	HV Hose Valve
Hyd Hydrant	LtE Long Turn Elbow	mecT Mechanical Tee
Noz Nozzle	P1 Pump In	P2 Pump Out
PIV Post Indicating Valve	PO Pipe Outlet	PrV Pressure Relief Valve
PRV I Pressure Reducing Valve In	PRV C Pressure Reducing Valve Out	red Reducer/Adapter
S Supply	sCV Swing Check Valve	SFx Seismic Flex
Spr Sprinkler	St Strainer	T Tee Flow Turn 90°
Tr Tee Run	U Union	WirF Wirsbo
WMV Water Meter Valve	Z Cap	



Check Point Gauge Data

Job Number: 70120 - REMOTE AREA L0A4
Report Description: Light Hazard (L0A4)

Gauge	Available Static Pressure (psi)	Available Residual Pressure (psi)	Required Residual Pressure (nsi)	K-Factor(K)	Flow(gpm)	Elevation(Foot)
BOR (3)	83.716	80.762	62.483	44.65	352.96	3-0½

Hydraulic Calculations

for

Project Name: BRADLEY PARK CARE CENTER: (70120)

Location: 707 39TH AVE SE, BLDG B, , PUYALLUP, WA 98374

Drawing Name: 70120 WBP Care Center R01 Level 1 & Attic.cad

Calculation Date: 4/10/2026

Design

Remote Area Number: L1A1
Remote Area Location: CC UNIT 1 1036
Occupancy Classification: Residential

Density: 0.100gpm/ft²
Area of Application: 900.00ft² (Actual 597.89ft²)
Coverage per Sprinkler: 400.00ft²
Type of sprinklers calculated: Pendent
No. of sprinklers calculated: 8
No. of nozzles calculated: 0

In-rack Demand: N/A gpm at Node: N/A
Hose Streams: 100.00 at Node: 1 Type: Allowance at Source

Total Water Required (including Hose Streams where applicable):
From Water Supply at Node 1: 266.61 @ 60.880 (Safety Margin = 20.574)

Type of System: WET
Volume of Dry/PreAction/Antifreeze/OtherAgent System: N/A

Name of Contractor: RED HAWK FIRE PROTECTION, LLC
Address: 801 VALLEY AVE NW, SUITE D, PUYALLUP, WA 98371
Phone Number: 253-604-7311
Name of designer: BROOKE MCDANIELS
Authority Having Jurisdiction: : CITY OF PUYALLUP


Notes:

Summary Notes:

Water Supply at Node 1

1 System Demand
3 Available Water Supply

Job Name: BRADLEY PARK CARE CENTER
 Job Number: 70120
 Report Description: Residential (L1A1)
 Remote Area Number: L1A1



Curve	Data Point	Hydraulic Calculation Results	Additional Data
1	1B	Required Pressure at System Demand: 60.880 @ 166.61	Available Flow @ 20 PSI: 3441.74
	1C	Required Pressure at System Demand (Including Hose Allowance at Source): 60.880 @ 266.61	
3	3A	Available Static Pressure at Water Supply at Node 1: 82.000	
	3B	Available Residual Pressure at System Demand: 81.454 @ 266.61	
	3C	Available Residual Pressure & Flow at Water Supply at Node 1: 24.000 @ 3320.00	



Summary Of Outflowing Devices

Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)			
⇒ Sprinkler	2000	20.01	20.01	5.8	11.900			
Sprinkler	2001	20.39	20.01	5.8	12.354			
Sprinkler	2002	20.52	20.01	5.8	12.522			
Sprinkler	2003	20.62	20.01	5.8	12.637			
Sprinkler	2004	20.93	20.01	5.8	13.018			
Sprinkler	2005	21.37	20.01	5.8	13.577			
Sprinkler	2006	21.38	20.01	5.8	13.583			
Sprinkler	2007	21.40	20.01	5.8	13.614			

⇒ Most Demanding Sprinkler Data

Supply Analysis							
Node	Name	Static (psi)	Residual (psi)	@ Flow (gpm)	Available (psi)	@ Total Demand (gpm)	Required Pressure (psi)
1	Water Supply	82.000	24.000	3320.00	81.454	266.61	60.880

Node Analysis					
Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1	-4-0	Supply	60.880	166.61	
2000	10-0½	Sprinkler	11.900	20.01	
2001	10-0½	Sprinkler	12.354	20.39	
2002	10-0½	Sprinkler	12.522	20.52	
2003	8-10½	Sprinkler	12.637	20.62	
2004	8-2	Sprinkler	13.018	20.93	
2005	8-10½	Sprinkler	13.577	21.37	
2006	8-10½	Sprinkler	13.583	21.38	
2007	8-10½	Sprinkler	13.614	21.40	
2	-4-0		60.532	0.00	
3	-7-11½	Gauge	62.187	0.00	BOR, BFP(-2.733)
4	-7-11½		59.452	0.00	
5	-7-11½		59.450	0.00	
8	-3-7		59.452	0.00	
200	10-5		13.159	0.00	
201	10-5		13.294	0.00	
202	10-5		14.069	0.00	
203	10-5		17.272	0.00	

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
204	9-9½		38.298	0.00	
205	9-1		45.705	0.00	
206	9-1		50.956	0.00	
208	10-5		14.088	0.00	
209	10-5		14.100	0.00	
210	10-5		14.165	0.00	
211	10-5		14.794	0.00	

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
2000	10-0½	5.8	20.01	1	(See Notes)	7-10½	150	11.900	••••• Route 1 ••••• Sprinkler, E(7-0), T(5-0), Tr(1-0)
200	10-5		20.01	1.1010		13-0	0.068091	-0.161	
						20-10½		1.421	
200	10-5		20.62	1½	(See Notes)	2-3½	150	13.159	Flow (q) from Route 4 Tr(1-0)
201	10-5		40.63	1.5980		1-0	0.041137	0.000	
						3-3½		0.135	
201	10-5		20.39	1½	(See Notes)	6-10½	150	13.294	Flow (q) from Route 2 2Tr(1-0)
202	10-5		61.01	1.5980		2-0	0.087290		
						8-10½		0.774	
202	10-5		21.38	1½	(See Notes)	11-0½	150	14.069	Flow (q) from Route 7 E(9-0), Tr(1-0)
203	10-5		82.39	1.5980		10-0	0.152159	0.000	
						21-0½		3.203	
203	10-5		84.22	1½	(See Notes)	24-1	150	17.272	Flow (q) from Route 3 5Tr(1-0), T(8-0)
204	9-9½		166.61	1.5980		13-0	0.559883	0.272	
						37-1		20.754	
204	9-9½			1½	(See Notes)	0-8½	120	38.298	PO(8-0)
205	9-1		166.61	1.6100		8-0	0.815750	0.306	
						8-8½		7.101	
205	9-1			3	(See Notes)	167-10	120	45.705	3fE(7-6), T(22-6), fE(10-2½)
206	9-1		166.61	3.3340		55-2	0.023548	0.000	
						223-0		5.251	
206	9-1			4	(See Notes)	21-8	120	50.956	T(27-10½), 2C(27-10½), 2fE(9-5½), sCV(4-2), BV(7-8), PO(27-10½)
5	-7-11½		166.61	4.3100		142-3½	0.006744	7.388	
						163-11½		1.106	
5	-7-11½			6		2-1	120	59.450	BOR, BFP(-2.733)
4	-7-11½		166.61	6.3570			0.001016		
						2-1		0.002	
4	-7-11½			6	(See Notes)	2-5½	120	59.452	BOR, BFP(-2.733)
3	-7-11½		166.61	6.3570			0.001016		
						2-5½		2.735	
3	-7-11½			6	(See Notes)	7-0	120	62.187	3E(17-7)
2	-4-0		166.61	6.3570		52-9½	0.001016	-1.716	
						59-9½		0.061	

Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
		Total (Foot)	Friction(Pf)						
2	-4-0					6	Supply (See Notes)	263-10	
1	-4-0		166.61	6.3570		79-2½	0.001016		
						343-0½			0.349
								60.880	Hose Allowance At Source
1			266.61						Total(Pt) Route 1
2001	10-0½	5.8	20.39	1	(See Notes)	3-7½	150	12.354	••••• Route 2 ••••• Sprinkler, E(7-0), T(5-0)
201	10-5		20.39	1.1010		12-0	0.070490	-0.161	
						15-7½			
								13.294	Total(Pt) Route 2
2002	10-0½	5.8	20.52	1	(See Notes)	8-2½	150	12.522	••••• Route 3 ••••• Sprinkler, 2E(7-0), Tr(1-0), b(1-0)
208	10-5		20.52	1.1010		16-0	0.071376	-0.161	
						24-2½			
208	10-5			1½	(See Notes)	0-0	150	14.088	Tr(1-0)
209	10-5		20.52	1.5980		1-0	0.011631	0.000	
						1-0			
209	10-5		21.40	1½	(See Notes)	0-6	150	14.100	Flow (q) from Route 8 Tr(1-0)
210	10-5		41.92	1.5980		1-0	0.043603	-0.000	
						1-6			
210	10-5		21.37	1½	(See Notes)	5-9	150	14.165	Flow (q) from Route 6 Tr(1-0)
211	10-5		63.30	1.5980		1-0	0.093430		
						6-9			
211	10-5		20.93	1½	(See Notes)	6-7½	150	14.794	Flow (q) from Route 5 Tr(1-0), T(8-0)
203	10-5		84.22	1.5980		9-0	0.158485		
						15-7½			
								17.272	Total(Pt) Route 3
2003	8-10½	5.8	20.62	1	(See Notes)	4-6½	150	12.637	••••• Route 4 ••••• Sprinkler, E(7-0), T(5-0)
200	10-5		20.62	1.1010		12-0	0.071981	-0.667	
						16-6½			
								13.159	Total(Pt) Route 4
2004	8-2	5.8	20.93	1	(See Notes)	1-2	150	13.018	••••• Route 5 ••••• Sprinkler, T(5-0), fd(31-0)
211	10-5		20.93	1.1010		36-0	0.073989	-0.975	
						37-2			

Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
								Elev(Pe)	
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Total (Foot)	Pf Friction Loss Per Unit (psi)	Friction(Pf)	
								14.794	Total(Pt) Route 5
2005	8-10½	5.8	21.37	1	(See Notes)	4-4	150	13.577	••••• Route 6 ••••• Sprinkler, E(7-0), T(5-0)
210	10-5		21.37	1.1010		12-0	0.076920	-0.667	
						16-4		1.256	
								14.165	Total(Pt) Route 6
2006	8-10½	5.8	21.38	1	(See Notes)	3-0	150	13.583	••••• Route 7 ••••• Sprinkler, E(7-0), T(5-0)
202	10-5		21.38	1.1010		12-0	0.076953	-0.667	
						15-0		1.153	
								14.069	Total(Pt) Route 7
2007	8-10½	5.8	21.40	1	(See Notes)	2-11½	150	13.614	••••• Route 8 ••••• Sprinkler, E(7-0), T(5-0)
209	10-5		21.40	1.1010		12-0	0.077116	-0.667	
						14-11½		1.153	
								14.100	Total(Pt) Route 8

Equivalent Pipe Lengths of Valves and Fittings (C=120 only)

C Value Multiplier

$$\left(\frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

Fittings Legend

ALV Alarm Valve	AngV Angle Valve	b Bushing
BaIV Ball Valve	BFP Backflow Preventer	BV Butterfly Valve
C Cross Flow Turn 90°	cplg Coupling	Cr Cross Run
CV Check Valve	DelV Deluge Valve	DPV Dry Pipe Valve
E 90° Elbow	EE 45° Elbow	Ee1 11¼° Elbow
Ee2 22½° Elbow	f Flow Device	fd Flex Drop
FDC Fire Department Connection	fE 90° FireLock(TM) Elbow	fEE 45° FireLock(TM) Elbow
flg Flange	FN Floating Node	fT FireLock(TM) Tee
g Gauge	GloV Globe Valve	GV Gate Valve
Ho Hose	Hose Hose	HV Hose Valve
Hyd Hydrant	LtE Long Turn Elbow	mecT Mechanical Tee
Noz Nozzle	P1 Pump In	P2 Pump Out
PIV Post Indicating Valve	PO Pipe Outlet	PrV Pressure Relief Valve
PRV I Pressure Reducing Valve In	PRV C Pressure Reducing Valve Out	red Reducer/Adapter
S Supply	sCV Swing Check Valve	SFx Seismic Flex
Spr Sprinkler	St Strainer	T Tee Flow Turn 90°
Tr Tee Run	U Union	WirF Wirsbo
WMV Water Meter Valve	Z Cap	

Hydraulic Calculations

for

Project Name: BRADLEY PARK CARE CENTER: (70120)

Location: 707 39TH AVE SE, BLDG B, , PUYALLUP, WA 98374

Drawing Name: 70120 WBP Care Center R01 Level 1 & Attic.cad

Calculation Date: 4/10/2026

Design

Remote Area Number: L1A2
Remote Area Location: NORTH CORRIDOR 1171
Occupancy Classification: CORRIDOR

Density: 0.100gpm/ft²
Area of Application: 674.57ft² (Actual 918.51ft²)
Coverage per Sprinkler: 280.00ft²
Type of sprinklers calculated: Pendent
No. of sprinklers calculated: 8
No. of nozzles calculated: 0

In-rack Demand: N/A gpm at Node: N/A
Hose Streams: 100.00 at Node: 1 Type: Allowance at Source

Total Water Required (including Hose Streams where applicable):
From Water Supply at Node 1: 342.41 @ 55.485 (Safety Margin = 25.647)

Type of System:
Volume of Dry/PreAction/Antifreeze/OtherAgent System: N/A

Name of Contractor: RED HAWK FIRE PROTECTION, LLC
Address: 801 VALLEY AVE NW, SUITE D, PUYALLUP, WA 98371
Phone Number: 253-604-7311
Name of designer: BROOKE MCDANIELS
Authority Having Jurisdiction: : CITY OF PUYALLUP


Notes:

Summary Notes:

Water Supply at Node 1

1 System Demand
3 Available Water Supply

Job Name: BRADLEY PARK CARE CENTER
 Job Number: 70120
 Report Description: CORRIDOR (L1A2)
 Remote Area Number: L1A2



Curve	Data Point	Hydraulic Calculation Results	Additional Data
1	1B	Required Pressure at System Demand: 55.485 @ 242.41	Available Flow @ 20 PSI: 3441.74
	1C	Required Pressure at System Demand (Including Hose Allowance at Source): 55.485 @ 342.41	
3	3A	Available Static Pressure at Water Supply at Node 1: 82.000	
	3B	Available Residual Pressure at System Demand: 81.133 @ 342.41	
	3C	Available Residual Pressure & Flow at Water Supply at Node 1: 24.000 @ 3320.00	



Summary Of Outflowing Devices

Job Number: 70120
Report Description: CORRIDOR (L1A2)

Device	Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)			
⇒ Sprinkler 2100	28.00	28.00	5.6	25.000			
Sprinkler 2101	28.95	28.00	5.6	26.731			
Sprinkler 2102	29.15	28.00	5.6	27.105			
Sprinkler 2103	29.39	28.00	5.6	27.546			
Sprinkler 2104	30.14	28.00	5.6	28.963			
Sprinkler 2105	30.44	28.00	5.6	29.556			
Sprinkler 2106	33.14	28.00	5.6	35.031			
Sprinkler 2107	33.19	28.00	5.6	35.124			

⇒ Most Demanding Sprinkler Data

Supply Analysis							
Node	Name	Static (psi)	Residual (psi)	@ Flow (gpm)	Available (psi)	@ Total Demand (gpm)	Required Pressure (psi)
1	Water Supply	82.000	24.000	3320.00	81.133	342.41	55.485

Node Analysis					
Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1	-4-0	Supply	55.485	242.41	
2100	6-6	Sprinkler	25.000	28.00	
2101	6-6	Sprinkler	26.731	28.95	
2102	6-6	Sprinkler	27.105	29.15	
2103	6-6	Sprinkler	27.546	29.39	
2104	7-10½	Sprinkler	28.963	30.14	
2105	7-10	Sprinkler	29.556	30.44	
2106	5-10½	Sprinkler	35.031	33.14	
2107	5-10½	Sprinkler	35.124	33.19	
2	-4-0		54.788	0.00	
3	-7-11½	Gauge	56.382	0.00	BOR, BFP(-1.918)
4	-7-11½		54.459	0.00	
5	-7-11½		54.455	0.00	
8	-3-7		54.459	0.00	
204	9-9½		31.388	0.00	
205	9-1		35.418	0.00	
206	9-1		44.854	0.00	
212	10-5		29.028	0.00	

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
213	10-5		30.931	0.00	
214	9-1		35.545	0.00	
215	9-1		35.946	0.00	
216	9-1		36.049	0.00	
217	9-1		36.130	0.00	
218	10-3½		29.648	0.00	
220	10-5		29.763	0.00	
221	10-3½		28.417	0.00	
222	10-3½		29.007	0.00	
223	10-3½		34.060	0.00	
224	9-9½		35.282	0.00	
225	10-3½		34.155	0.00	
226	9-9½		35.385	0.00	

Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
										Node 2
2100	6-6	5.6	28.00	1	(See Notes)	4-2	150	25.000		
212	10-5		28.00	1.1010		41-0	0.126797	-1.698		
						45-2		5.726		
212	10-5		30.14	1½	(See Notes)	12-10	150	29.028	Flow (q) from Route 5 3Tr(1-0), T(8-0)	
213	10-5		58.14	1.5980		11-0	0.079836	-0.000		
						23-10		1.903		
213	10-5		59.40	1½		0-7½	150	30.931	Flow (q) from Route 2	
204	9-9½		117.54	1.5980			0.293604	0.272		
						0-7½		0.184		
204	9-9½			1½	(See Notes)	0-8½	120	31.388	PO(8-0)	
205	9-1		117.54	1.6100		8-0	0.427783	0.306		
						8-8½		3.724		
205	9-1			3		10-4½	120	35.418		
214	9-1		117.54	3.3340			0.012349			
						10-4½		0.128		
214	9-1		29.15	3		21-6½	120	35.545	Flow (q) from Route 3	
215	9-1		146.69	3.3340			0.018606			
						21-6½		0.400		
215	9-1		33.14	3		3-9½	120	35.946	Flow (q) from Route 7	
216	9-1		179.84	3.3340			0.027122			
						3-9½		0.103		
216	9-1		33.19	3		2-2	120	36.049	Flow (q) from Route 8	
217	9-1		213.02	3.3340			0.037102			
						2-2		0.081		
217	9-1		29.39	3	(See Notes)	129-11½	120	36.130	Flow (q) from Route 4 3fE(7-6), T(22-6), fE(10-2½)	
206	9-1		242.41	3.3340		55-2	0.047124	0.000		
						185-1½		8.724		
206	9-1			4	(See Notes)	21-8	120	44.854	T(27-10½), 2C(27-10½), 2fE(9-5½), sCV(4-2), BV(7-8), PO(27-10½)	
5	-7-11½		242.41	4.3100		142-3½	0.013495	7.388		
						163-11½		2.213		
5	-7-11½			6		2-1	120	54.455		
4	-7-11½		242.41	6.3570			0.002034			
						2-1		0.004		

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
4	-7-11½			6	(See Notes)	2-5½	120	54.459	BOR, BFP(-1.918)
3	-7-11½		242.41	6.3570		2-5½	0.002034	1.923	
3	-7-11½			6	(See Notes)	7-0	120	56.382	3E(17-7)
2	-4-0		242.41	6.3570		52-9½	0.002034	-1.716	
						59-9½		0.122	
2	-4-0			6	Supply (See Notes)	263-10	120	54.788	Avl. Pressure @ Supply: 81.133 4E(17-7), EE(8-9½), S
1	-4-0		242.41	6.3570		79-2½	0.002034		
						343-0½		0.698	
			100.00					55.485	Hose Allowance At Source
1			342.41						Total(Pt) Route 1
2101	6-6	5.6	28.95	1	(See Notes)	1-9	150	26.731	••••• Route 2 ••••• Sprinkler, b(1-0), fd(31-0)
218	10-3½		28.95	1.1010		32-0	0.134897	-1.636	
						33-9		4.554	
218	10-3½			1½	(See Notes)	0-0	150	29.648	T(8-0)
220	10-5		28.95	1.5980		8-0	0.021983	-0.062	
						8-0		0.176	
220	10-5		30.44	1½	(See Notes)	6-1	150	29.763	Flow (q) from Route 6 T(8-0)
213	10-5		59.40	1.5980		8-0	0.083066	-0.000	
						14-1		1.168	
								30.931	Total(Pt) Route 2
2102	6-6	5.6	29.15	1	(See Notes)	0-7	120	27.105	••••• Route 3 ••••• Sprinkler, PO(5-0), fd(31-0)
214	9-1		29.15	1.0490		36-0	0.261333	-1.120	
						36-7		9.560	
								35.545	Total(Pt) Route 3
2103	6-6	5.6	29.39	1	(See Notes)	0-7	120	27.546	••••• Route 4 ••••• Sprinkler, PO(5-0), fd(31-0)
217	9-1		29.39	1.0490		36-0	0.265260	-1.120	
						36-7		9.704	
								36.130	Total(Pt) Route 4
2104	7-10½	5.6	30.14	1	(See Notes)	2-5	150	28.963	••••• Route 5 ••••• Sprinkler, b(1-0)
221	10-3½		30.14	1.1010		1-0	0.145285	-1.039	
						3-5		0.494	

Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
	Node 2		Elev 2 (Foot)	Total Flow (Q)		Actual ID	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	
		Total (Foot)			Friction(Pf)				
221	10-3½			1½	(See Notes)	9-5	150	28.417	
212	10-5		30.14	1.5980		19-0	0.023676	-0.062	
						28-5		0.672	
								29.028	Total(Pt) Route 5
2105	7-10	5.6	30.44	1	(See Notes)	2-5½	150	29.556	••••• Route 6 ••••• Sprinkler, b(1-0)
222	10-3½		30.44	1.1010		1-0	0.148032	-1.058	
						3-5½		0.509	
222	10-3½			1½	(See Notes)	13-10½		150	
220	10-5		30.44	1.5980		20-0	0.024124	-0.062	
						33-10½		0.818	
								29.763	Total(Pt) Route 6
2106	5-10½	5.6	33.14	1	(See Notes)	4-5	150	35.031	••••• Route 7 ••••• Sprinkler, b(1-0)
223	10-3½		33.14	1.1010		1-0	0.173235	-1.906	
						5-5		0.935	
223	10-3½			1½	(See Notes)	9-10		150	
224	9-9½		33.14	1.5980		26-0	0.028231	0.211	
						35-10		1.011	
224	9-9½			1½	(See Notes)	0-8½		120	35.282
215	9-1		33.14	1.6100		8-0	0.041132	0.306	
						8-8½		0.358	
								35.946	Total(Pt) Route 7
2107	5-10½	5.6	33.19	1	(See Notes)	4-5	150	35.124	••••• Route 8 ••••• Sprinkler, b(1-0)
225	10-3½		33.19	1.1010		1-0	0.173658	-1.906	
						5-5		0.937	
225	10-3½			1½	(See Notes)	11-0		150	
226	9-9½		33.19	1.5980		25-0	0.028300	0.211	
						36-0		1.019	
226	9-9½			1½	(See Notes)	0-8½		120	35.385
216	9-1		33.19	1.6100		8-0	0.041233	0.306	
						8-8½		0.359	
								36.049	Total(Pt) Route 8

Equivalent Pipe Lengths of Valves and Fittings (C=120 only)

C Value Multiplier

$$\left(\frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

Fittings Legend

ALV Alarm Valve	AngV Angle Valve	b Bushing
BaIV Ball Valve	BFP Backflow Preventer	BV Butterfly Valve
C Cross Flow Turn 90°	cplg Coupling	Cr Cross Run
CV Check Valve	DelV Deluge Valve	DPV Dry Pipe Valve
E 90° Elbow	EE 45° Elbow	Ee1 11¼° Elbow
Ee2 22½° Elbow	f Flow Device	fd Flex Drop
FDC Fire Department Connection	fE 90° FireLock(TM) Elbow	fEE 45° FireLock(TM) Elbow
flg Flange	FN Floating Node	fT FireLock(TM) Tee
g Gauge	GloV Globe Valve	GV Gate Valve
Ho Hose	Hose Hose	HV Hose Valve
Hyd Hydrant	LtE Long Turn Elbow	mecT Mechanical Tee
Noz Nozzle	P1 Pump In	P2 Pump Out
PIV Post Indicating Valve	PO Pipe Outlet	PrV Pressure Relief Valve
PRV I Pressure Reducing Valve In	PRV C Pressure Reducing Valve Out	red Reducer/Adapter
S Supply	sCV Swing Check Valve	SFx Seismic Flex
Spr Sprinkler	St Strainer	T Tee Flow Turn 90°
Tr Tee Run	U Union	WirF Wirsbo
WMV Water Meter Valve	Z Cap	

Hydraulic Calculations

for

Project Name: BRADLEY PARK CARE CENTER: (70120)

Location: 707 39TH AVE SE, BLDG B, , PUYALLUP, WA 98374

Drawing Name: 70120 WBP Care Center R01 Level 1 & Attic.cad

Calculation Date: 4/10/2026

Design

Remote Area Number: L1A3
Remote Area Location: CC UNIT 1039
Occupancy Classification: Concealed Combustible Space

Density: 0.100gpm/ft²
Area of Application: 1000.00ft² (Actual 1057.80ft²)
Coverage per Sprinkler: 225.00ft²
Type of sprinklers calculated: Upright
No. of sprinklers calculated: 7
No. of nozzles calculated: 0

In-rack Demand: N/A gpm at Node: N/A
Hose Streams: 100.00 at Node: 1 Type: Allowance at Source

Total Water Required (including Hose Streams where applicable):
From Water Supply at Node 1: 268.00 @ 66.794 (Safety Margin = 14.654)

Type of System: WET
Volume of Dry/PreAction/Antifreeze/OtherAgent System: N/A

Name of Contractor: RED HAWK FIRE PROTECTION, LLC
Address: 801 VALLEY AVE NW, SUITE D, PUYALLUP, WA 98371
Phone Number: 253-604-7311
Name of designer: BROOKE MCDANIELS
Authority Having Jurisdiction: : CITY OF PUYALLUP

Notes:

Summary Notes:

Water Supply at Node 1


■ 1 System Demand
■ 3 Available Water Supply

Job Name: BRADLEY PARK CARE CENTER

Job Number: 70120

Report Description: Concealed Combustible Space (L1A3)

Remote Area Number: L1A3



Curve	Data Point	Hydraulic Calculation Results	Additional Data
1	1B	Required Pressure at System Demand: 66.794 @ 168.00	Available Flow @ 20 PSI: 3441.74
	1C	Required Pressure at System Demand (Including Hose Allowance at Source): 66.794 @ 268.00	
3	3A	Available Static Pressure at Water Supply at Node 1: 82.000	
	3B	Available Residual Pressure at System Demand: 81.449 @ 268.00	
	3C	Available Residual Pressure & Flow at Water Supply at Node 1: 24.000 @ 3320.00	



Summary Of Outflowing Devices

Job Number: 70120

Report Description: Concealed Combustible Space (L1A3)

Device	Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)			
⇒ Sprinkler 2200	22.50	22.50	5.6	16.143			
Sprinkler 2201	22.51	22.50	5.6	16.158			
Sprinkler 2202	22.90	22.50	5.6	16.716			
Sprinkler 2203	23.31	22.50	5.6	17.319			
Sprinkler 2204	23.55	22.50	5.6	17.691			
Sprinkler 2205	23.99	22.50	5.6	18.348			
Sprinkler 2206	29.24	22.50	5.6	27.272			

⇒ Most Demanding Sprinkler Data

Supply Analysis							
Node	Name	Static (psi)	Residual (psi)	@ Flow (gpm)	Available (psi)	@ Total Demand (gpm)	Required Pressure (psi)
1	Water Supply	82.000	24.000	3320.00	81.449	268.00	66.794

Node Analysis					
Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1	-4-0	Supply	66.794	168.00	
2200	10-10½	Sprinkler	16.143	22.50	
2201	10-10½	Sprinkler	16.158	22.51	
2202	10-10½	Sprinkler	16.716	22.90	
2203	10-10½	Sprinkler	17.319	23.31	
2204	10-10½	Sprinkler	17.691	23.55	
2205	10-10½	Sprinkler	18.348	23.99	
2206	10-10½	Sprinkler	27.272	29.24	
2	-4-0		66.440	0.00	
3	-7-11½	Gauge	68.095	0.00	BOR, BFP(-2.704)
4	-7-11½		65.388	0.00	
5	-7-11½		65.386	0.00	
8	-3-7		65.388	0.00	
204	9-9½		44.026	0.00	
205	9-1		51.543	0.00	
206	9-1		56.875	0.00	
212	10-5		29.846	0.00	
227	10-5		19.339	0.00	

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
228	10-5		21.296	0.00	
229	10-5		22.713	0.00	
230	10-5		18.691	0.00	
231	10-5		18.793	0.00	
232	10-5		20.178	0.00	
233	10-5		19.272	0.00	
234	10-5		19.406	0.00	

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
2200	10-10½	5.6	22.50	1	(See Notes)	15-5	150	16.143	••••• Route 1 ••••• Sprinkler, 2E(7-0), Tr(1-0), T(5-0)
227	10-5		22.50	1.1010		20-0	0.084606	0.198	
						35-5		2.998	
227	10-5		23.99	1	(See Notes)	4-0½	150	19.339	Flow (q) from Route 6 Tr(1-0), b(1-0)
228	10-5		46.49	1.1010		2-0	0.323918		
						6-0½		1.957	
228	10-5			1½	(See Notes)	6-10½	150	21.296	2E(9-0), 2Tr(1-0)
229	10-5		46.49	1.5980		20-0	0.052786		
						26-10½		1.418	
229	10-5		92.27	1½	(See Notes)	7-10½	150	22.713	Flow (q) from Route 2 E(9-0), Tr(1-0)
212	10-5		138.75	1.5980		10-0	0.399114		
						17-10½		7.133	
212	10-5		29.24	1½	(See Notes)	13-5½	150	29.846	Flow (q) from Route 7 3Tr(1-0), T(8-0)
204	9-9½		168.00	1.5980		11-0	0.568537	0.272	
						24-5½		13.908	
204	9-9½			1½	(See Notes)	0-8½	120	44.026	PO(8-0)
205	9-1		168.00	1.6100		8-0	0.828360	0.306	
						8-8½		7.211	
205	9-1			3	(See Notes)	167-10	120	51.543	3fE(7-6), T(22-6), fE(10-2½)
206	9-1		168.00	3.3340		55-2	0.023912	0.000	
						223-0		5.332	
206	9-1			4	(See Notes)	21-8	120	56.875	T(27-10½), 2C(27-10½), 2fE(9-5½), sCV(4-2), BV(7-8), PO(27-10½)
5	-7-11½		168.00	4.3100		142-3½	0.006848	7.388	
						163-11½		1.123	
5	-7-11½			6		2-1	120	65.386	BOR, BFP(-2.704)
4	-7-11½		168.00	6.3570			0.001032		
						2-1		0.002	
4	-7-11½			6	(See Notes)	2-5½	120	65.388	BOR, BFP(-2.704)
3	-7-11½		168.00	6.3570			0.001032		
						2-5½		2.707	
3	-7-11½			6	(See Notes)	7-0	120	68.095	3E(17-7)
2	-4-0		168.00	6.3570		52-9½	0.001032	-1.716	
						59-9½		0.062	

Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
2	-4-0			6	Supply (See Notes)	263-10	120	66.440	Avl.Pressure @ Supply: 81.449 4E(17-7), EE(8-9½), S
1	-4-0		168.00	6.3570		79-2½	0.001032		
						343-0½		0.354	
			100.00					66.794	Hose Allowance At Source
1			268.00						Total(Pt) Route 1
2201	10-10½	5.6	22.51	1	(See Notes)	11-7	150	16.158	••••• Route 2 ••••• Sprinkler, 2E(7-0), Tr(1-0), b(1-0)
230	10-5		22.51	1.1010		16-0	0.084676	0.198	
						27-7		2.336	
230	10-5			1½	(See Notes)	4-5	150	18.691	3Tr(1-0)
231	10-5		22.51	1.5980		3-0	0.013799	0.000	
						7-5		0.102	
231	10-5		23.31	1½	(See Notes)	15-11½	150	18.793	Flow (q) from Route 4 2Tr(1-0), E(9-0)
232	10-5		45.82	1.5980		11-0	0.051383	0.000	
						26-11½		1.385	
232	10-5		46.45	1½	(See Notes)	5-6	150	20.178	Flow (q) from Route 3 T(8-0)
229	10-5		92.27	1.5980		8-0	0.187616		
						13-6		2.535	
								22.713	Total(Pt) Route 2
2202	10-10½	5.6	22.90	1	(See Notes)	11-0	150	16.716	••••• Route 3 ••••• Sprinkler, 2E(7-0), Tr(1-0), b(1-0)
233	10-5		22.90	1.1010		16-0	0.087382	0.198	
						27-0		2.358	
233	10-5			1½	(See Notes)	6-4½	150	19.272	3Tr(1-0)
234	10-5		22.90	1.5980		3-0	0.014240		
						9-4½		0.133	
234	10-5		23.55	1½	(See Notes)	6-8	150	19.406	Flow (q) from Route 5 T(8-0)
232	10-5		46.45	1.5980		8-0	0.052708		
						14-8		0.773	
								20.178	Total(Pt) Route 3
2203	10-10½	5.6	23.31	1	(See Notes)	2-1½	150	17.319	••••• Route 4 ••••• Sprinkler, E(7-0), T(5-0)
231	10-5		23.31	1.1010		12-0	0.090293	0.198	
						14-1½		1.276	
								18.793	Total(Pt) Route 4

Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
2204	10-10½	5.6	23.55	1	(See Notes)	3-5½	150	17.691	••••• Route 5 ••••• Sprinkler, E(7-0), Tr(1-0), T(5-0)
234	10-5		23.55	1.1010		13-0	0.092083	0.198	
						16-5½		1.517	
								19.406	Total(Pt) Route 5
2205	10-10½	5.6	23.99	1	(See Notes)	2-4	150	18.348	••••• Route 6 ••••• Sprinkler, T(5-0), Tr(1-0)
227	10-5		23.99	1.1010		6-0	0.095243	0.198	
						8-4		0.793	
								19.339	Total(Pt) Route 6
2206	10-10½	5.6	29.24	1	(See Notes)	4-3½	150	27.272	••••• Route 7 ••••• Sprinkler, E(7-0), Tr(1-0), T(5-0)
212	10-5		29.24	1.1010		13-0	0.137419	0.198	
						17-3½		2.377	
								29.846	Total(Pt) Route 7

Equivalent Pipe Lengths of Valves and Fittings (C=120 only)

C Value Multiplier

$$\left(\frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

Fittings Legend

ALV Alarm Valve	AngV Angle Valve	b Bushing
BaIV Ball Valve	BFP Backflow Preventer	BV Butterfly Valve
C Cross Flow Turn 90°	cplg Coupling	Cr Cross Run
CV Check Valve	DelV Deluge Valve	DPV Dry Pipe Valve
E 90° Elbow	EE 45° Elbow	Ee1 11¼° Elbow
Ee2 22½° Elbow	f Flow Device	fd Flex Drop
FDC Fire Department Connection	fE 90° FireLock(TM) Elbow	fEE 45° FireLock(TM) Elbow
flg Flange	FN Floating Node	fT FireLock(TM) Tee
g Gauge	GloV Globe Valve	GV Gate Valve
Ho Hose	Hose Hose	HV Hose Valve
Hyd Hydrant	LtE Long Turn Elbow	mecT Mechanical Tee
Noz Nozzle	P1 Pump In	P2 Pump Out
PIV Post Indicating Valve	PO Pipe Outlet	PrV Pressure Relief Valve
PRV I Pressure Reducing Valve In	PRV C Pressure Reducing Valve Out	red Reducer/Adapter
S Supply	sCV Swing Check Valve	SFx Seismic Flex
Spr Sprinkler	St Strainer	T Tee Flow Turn 90°
Tr Tee Run	U Union	WirF Wirsbo
WMV Water Meter Valve	Z Cap	

Hydraulic Calculations

for

Project Name: BRADLEY PARK CARE CENTER: (70120)

Location: 707 39TH AVE SE, BLDG B, , PUYALLUP, WA 98374

Drawing Name: 70120 WBP Care Center R01 Level 1 & Attic.cad

Calculation Date: 4/10/2026

Design

Remote Area Number: L1A4
Remote Area Location: DAYROOM 1129
Occupancy Classification: Light Hazard

Density: 0.100gpm/ft²
Area of Application: 1500.00ft² (Actual 1057.84ft²)
Coverage per Sprinkler: 120.00ft²
Type of sprinklers calculated: Pendent
No. of sprinklers calculated: 12
No. of nozzles calculated: 0

In-rack Demand: N/A gpm at Node: N/A
Hose Streams: 100.00 at Node: 1 Type: Allowance at Source

Total Water Required (including Hose Streams where applicable):
From Water Supply at Node 1: 366.00 @ 67.153 (Safety Margin = 13.866)

Type of System: WET
Volume of Dry/PreAction/Antifreeze/OtherAgent System: N/A

Name of Contractor: RED HAWK FIRE PROTECTION, LLC
Address: 801 VALLEY AVE NW, SUITE D, PUYALLUP, WA 98371
Phone Number: 253-604-7311
Name of designer: BROOKE MCDANIELS
Authority Having Jurisdiction: : CITY OF PUYALLUP


Notes:

Summary Notes:

Water Supply at Node 1

1 System Demand
3 Available Water Supply

Job Name: BRADLEY PARK CARE CENTER
 Job Number: 70120
 Report Description: Light Hazard (L1A4)
 Remote Area Number: L1A4



Curve	Data Point	Hydraulic Calculation Results	Additional Data
1	1B	Required Pressure at System Demand: 67.153 @ 266.00	Available Flow @ 20 PSI: 3441.74
	1C	Required Pressure at System Demand (Including Hose Allowance at Source): 67.153 @ 366.00	
3	3A	Available Static Pressure at Water Supply at Node 1: 82.000	
	3B	Available Residual Pressure at System Demand: 81.019 @ 366.00	
	3C	Available Residual Pressure & Flow at Water Supply at Node 1: 24.000 @ 3320.00	



Summary Of Outflowing Devices

Job Number: 70120
Report Description: Light Hazard (L1A4)

Device	Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)			
➔ Sprinkler 2300	28.00	28.00	5.6	25.000			
Sprinkler 2301	17.70	12.00	5.6	9.993			
Sprinkler 2302	18.05	12.00	5.6	10.394			
Sprinkler 2303	19.86	12.00	5.6	12.582			
Sprinkler 2304	20.51	12.00	5.6	13.410			
Sprinkler 2305	20.60	12.00	5.6	13.535			
Sprinkler 2306	20.77	12.00	5.6	13.751			
Sprinkler 2307	21.29	12.00	5.6	14.454			
Sprinkler 2308	21.56	12.00	5.6	14.817			
Sprinkler 2309	24.49	12.00	5.6	19.124			
Sprinkler 2310	26.57	12.00	5.6	22.515			
Sprinkler 2311	26.60	12.00	5.6	22.562			

➔ Most Demanding Sprinkler Data

Supply Analysis							
Node	Name	Static (psi)	Residual (psi)	@ Flow (gpm)	Available (psi)	@ Total Demand (gpm)	Required Pressure (psi)
1	Water Supply	82.000	24.000	3320.00	81.019	366.00	67.153

Node Analysis					
Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1	-4-0	Supply	67.153	266.00	
2300	6-6	Sprinkler	25.000	28.00	
2301	11-9	Sprinkler	9.993	17.70	
2302	11-9	Sprinkler	10.394	18.05	
2303	14-0	Sprinkler	12.582	19.86	
2304	14-0	Sprinkler	13.410	20.51	
2305	14-0	Sprinkler	13.535	20.60	
2306	14-0	Sprinkler	13.751	20.77	
2307	14-0	Sprinkler	14.454	21.29	
2308	14-0	Sprinkler	14.817	21.56	
2309	7-0	Sprinkler	19.124	24.49	
2310	8-0½	Sprinkler	22.515	26.57	
2311	7-0½	Sprinkler	22.562	26.60	
2	-4-0		66.324	0.00	
3	-7-11½	Gauge	67.896	0.00	BOR, BFP(-1.867)
4	-7-11½		66.023	0.00	
5	-7-11½		66.018	0.00	
8	-3-7		66.023	0.00	

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
206	9-1		56.003	0.00	
235	9-1		32.752	0.00	
236	16-3		8.904	0.00	
237	16-3		8.956	0.00	
238	15-9		10.449	0.00	
239	10-5		21.344	0.00	
240	9-9½		25.860	0.00	
241	9-1		31.875	0.00	
242	9-1		31.894	0.00	
243	9-1		31.921	0.00	
244	9-1		32.070	0.00	
245	9-1		32.617	0.00	
246	16-3		9.338	0.00	
247	16-3		9.923	0.00	
248	15-9		15.417	0.00	
249	9-9½		29.577	0.00	
250	15-9		16.501	0.00	
251	9-9½		28.686	0.00	
252	15-9		16.930	0.00	
253	9-9½		28.794	0.00	
254	10-5		23.161	0.00	
257	9-9½		27.083	0.00	

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
2300	6-6	5.6	28.00	1	(See Notes)	0-7	120	25.000 Route 1 Sprinkler, PO(5-0), fd(31-0)
235	9-1		28.00	1.0490		36-0	0.242504	-1.120	
						36-7		8.872	
235	9-1		238.00	3	(See Notes)	307-10½	120	32.752	Flow (q) from Route 2 T(22-6), 10fE(7-6), fE(10-2½)
206	9-1		266.00	3.3340		107-7½	0.055957	0.000	
						415-6		23.251	
206	9-1			4	(See Notes)	21-8	120	56.003	T(27-10½), 2C(27-10½), 2fE(9-5½), sCV(4-2), BV(7-8), PO(2-7-10½)
5	-7-11½		266.00	4.3100		142-3½	0.016025	7.388	
						163-11½		2.628	
5	-7-11½			6		2-1	120	66.018	BOR, BFP(-1.867)
4	-7-11½		266.00	6.3570		2-1	0.002415	0.005	
4	-7-11½			6	(See Notes)	2-5½	120	66.023	3E(17-7)
3	-7-11½		266.00	6.3570		2-5½	0.002415	1.873	
3	-7-11½			6	(See Notes)	7-0	120	67.896	Avl.Pressure @ Supply: 81.019 4E(17-7), EE(8-9½), S
2	-4-0		266.00	6.3570		52-9½	0.002415	-1.716	
						59-9½		0.144	
2	-4-0			6	Supply (See Notes)	263-10	120	66.324	Avl.Pressure @ Supply: 81.019 4E(17-7), EE(8-9½), S
1	-4-0		266.00	6.3570		79-2½	0.002415	0.828	
						343-0½			
			100.00					67.153	Hose Allowance At Source
1			366.00						Total(Pt) Route 1
2301	11-9	5.6	17.70	1	(See Notes)	4-6	100	9.993 Route 2 Sprinkler, E(1-5)
236	16-3		17.70	1.0490		1-5	0.145490	-1.951	
						5-11		0.862	
236	16-3			1		0-6	120	8.904	T(5-0) E(7-0), Tr(1-0)
237	16-3		17.70	1.0490		0-6	0.103836	-0.000	
								0.052	
237	16-3			1	(See Notes)	10-6	150	8.956	T(5-0) E(7-0), Tr(1-0)
238	15-9		17.70	1.1010		13-0	0.054292	0.217	
						23-6		1.276	

Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
										Node 2
238	15-9		18.05	1	(See Notes)	14-0½	150	10.449		
239	10-5		35.76	1.1010		29-0	0.199336	2.312		
						43-0½		8.583		
239	10-5		24.49	1	(See Notes)	3-1½	150	21.344	Flow (q) from Route 10 T(5-0)	
240	9-9½		60.25	1.1010		5-0	0.523283	0.272		
						8-1½		4.244		
240	9-9½			1	(See Notes)	0-8½	120	25.860	PO(5-0)	
241	9-1		60.25	1.0490		5-0	1.000802	0.306		
						5-8½		5.710		
241	9-1			3		5-5	120	31.875		
242	9-1		60.25	3.3340			0.003587	-0.000		
						5-5		0.019		
242	9-1		41.80	3		2-9	120	31.894	Flow (q) from Route 5	
243	9-1		102.04	3.3340			0.009507			
						2-9		0.026		
243	9-1		53.17	3		7-3	120	31.921	Flow (q) from Route 11	
244	9-1		155.22	3.3340			0.020656			
						7-3		0.150		
244	9-1		42.32	3	(See Notes)	9-5	120	32.070	Flow (q) from Route 7 fE(7-6)	
245	9-1		197.54	3.3340		7-6	0.032267	0.000		
						16-11		0.546		
245	9-1		40.47	3		2-11½	120	32.617	Flow (q) from Route 4	
235	9-1		238.00	3.3340			0.045551	-0.000		
						2-11½		0.135		
								32.752	Total(Pt) Route 2	
2302	11-9	5.6	18.05	1	(See Notes)	4-6	100	10.394	***** Route 3 ***** Sprinkler, E(1-5)	
246	16-3		18.05	1.0490		1-5	0.150884	-1.951		
						5-11		0.894		
246	16-3			1	(See Notes)	0-5	120	9.338	T(5-0)	
247	16-3		18.05	1.0490		5-0	0.107686	-0.000		
						5-5		0.585		
247	16-3			1	(See Notes)	0-6	150	9.923	T(5-0)	
238	15-9		18.05	1.1010		5-0	0.056305	0.217		
						5-6		0.310		

Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
										Node 2
								10.449		
2303	14-0	5.6	19.86	1	(See Notes)	12-5½	150	12.582		••••• Route 4 ••••• Sprinkler, E(7-0), 3Tr(1-0), fd(31-0)
248	15-9		19.86	1.1010		41-0	0.067188	-0.759		
						53-5½		3.593		
248	15-9		20.60	1	(See Notes)	18-2½	150	15.417	Flow (q) from Route 6 4E(7-0)	
249	9-9½		40.47	1.1010		28-0	0.250606	2.585		
						46-2½		11.575		
249	9-9½			1	(See Notes)	0-8½	120	29.577	PO(5-0)	
245	9-1		40.47	1.0490		5-0	0.479295	0.306		
						5-8½		2.734		
								32.617	Total(Pt) Route 4	
2304	14-0	5.6	20.51	1	(See Notes)	13-0	150	13.410	••••• Route 5 ••••• Sprinkler, E(7-0), 3Tr(1-0), fd(31-0)	
250	15-9		20.51	1.1010		41-0	0.071267	-0.759		
						54-0		3.850		
250	15-9		21.29	1	(See Notes)	15-1	150	16.501	Flow (q) from Route 8 3E(7-0)	
251	9-9½		41.80	1.1010		21-0	0.266068	2.585		
						36-1		9.600		
251	9-9½			1	(See Notes)	0-8½	120	28.686	PO(5-0)	
242	9-1		41.80	1.0490		5-0	0.508867	0.306		
						5-8½		2.903		
								31.894	Total(Pt) Route 5	
2305	14-0	5.6	20.60	1	(See Notes)	0-9	150	13.535	••••• Route 6 ••••• Sprinkler, T(5-0), fd(31-0)	
248	15-9		20.60	1.1010		36-0	0.071881	-0.759		
						36-9		2.640		
								15.417	Total(Pt) Route 6	
2306	14-0	5.6	20.77	1	(See Notes)	12-11½	150	13.751	••••• Route 7 ••••• Sprinkler, E(7-0), 3Tr(1-0), fd(31-0)	
252	15-9		20.77	1.1010		41-0	0.072941	-0.759		
						53-11½		3.937		
252	15-9		21.56	1	(See Notes)	15-1	150	16.930	Flow (q) from Route 9 2E(7-0), T(5-0)	
253	9-9½		42.32	1.1010		19-0	0.272282	2.585		
						34-1		9.280		

Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
253	9-9½			1	(See Notes)	0-8½	120	28.794	PO(5-0)
244	9-1		42.32	1.0490		5-0	0.520752	0.306	
						5-8½		2.971	
								32.070	Total(Pt) Route 7
2307	14-0	5.6	21.29	1	(See Notes)	0-9	150	14.454	••••• Route 8 ••••• Sprinkler, T(5-0), fd(31-0)
250	15-9		21.29	1.1010		36-0	0.076384	-0.759	
						36-9		2.806	
								16.501	Total(Pt) Route 8
2308	14-0	5.6	21.56	1	(See Notes)	0-9	150	14.817	••••• Route 9 ••••• Sprinkler, T(5-0), fd(31-0)
252	15-9		21.56	1.1010		36-0	0.078158	-0.759	
						36-9		2.871	
								16.930	Total(Pt) Route 9
2309	7-0	5.6	24.49	1	(See Notes)	1-5	150	19.124	••••• Route 10 ••••• Sprinkler, T(5-0), fd(31-0)
239	10-5		24.49	1.1010		36-0	0.098962	-1.481	
						37-5		3.701	
								21.344	Total(Pt) Route 10
2310	8-0½	5.6	26.57	1	(See Notes)	6-6½	150	22.515	••••• Route 11 ••••• Sprinkler, E(7-0), Tr(1-0)
254	10-5		26.57	1.1010		8-0	0.115093	-1.028	
						14-6½		1.674	
254	10-5		26.60	1	(See Notes)	1-9½	150	23.161	Flow (q) from Route 12 E(7-0)
257	9-9½		53.17	1.1010		7-0	0.415315	0.272	
						8-9½		3.650	
257	9-9½			1	(See Notes)	0-8½	120	27.083	PO(5-0)
243	9-1		53.17	1.0490		5-0	0.794307	0.306	
						5-8½		4.531	
								31.921	Total(Pt) Route 11
2311	7-0½	5.6	26.60	1	(See Notes)	5-10½	150	22.562	••••• Route 12 ••••• Sprinkler, E(7-0), T(5-0)
254	10-5		26.60	1.1010		12-0	0.115317	-1.462	
						17-10½		2.060	
								23.161	Total(Pt) Route 12

Equivalent Pipe Lengths of Valves and Fittings (C=120 only)

C Value Multiplier

$$\left(\frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

Fittings Legend

ALV Alarm Valve	AngV Angle Valve	b Bushing
BaIV Ball Valve	BFP Backflow Preventer	BV Butterfly Valve
C Cross Flow Turn 90°	cplg Coupling	Cr Cross Run
CV Check Valve	DelV Deluge Valve	DPV Dry Pipe Valve
E 90° Elbow	EE 45° Elbow	Ee1 11¼° Elbow
Ee2 22½° Elbow	f Flow Device	fd Flex Drop
FDC Fire Department Connection	fE 90° FireLock(TM) Elbow	fEE 45° FireLock(TM) Elbow
flg Flange	FN Floating Node	fT FireLock(TM) Tee
g Gauge	GloV Globe Valve	GV Gate Valve
Ho Hose	Hose Hose	HV Hose Valve
Hyd Hydrant	LtE Long Turn Elbow	mecT Mechanical Tee
Noz Nozzle	P1 Pump In	P2 Pump Out
PIV Post Indicating Valve	PO Pipe Outlet	PrV Pressure Relief Valve
PRV I Pressure Reducing Valve In	PRV C Pressure Reducing Valve Out	red Reducer/Adapter
S Supply	sCV Swing Check Valve	SFx Seismic Flex
Spr Sprinkler	St Strainer	T Tee Flow Turn 90°
Tr Tee Run	U Union	WirF Wirsbo
WMV Water Meter Valve	Z Cap	

Hydraulic Calculations

for

Project Name: BRADLEY PARK CARE CENTER: (70120)

Location: 707 39TH AVE SE, BLDG B, , PUYALLUP, WA 98374

Drawing Name: 70120 WBP Care Center R01 Level 1 & Attic.cad

Calculation Date: 4/10/2026

Design

Remote Area Number: L1A5
Remote Area Location: ATTIC
Occupancy Classification: Light Hazard

Density 0.100gpm/ft²
Area of Application: 1950.00ft² (Actual 225.00ft²)
Coverage per Sprinkler: 100.00ft²
Type of sprinklers calculated: Upright
No. of sprinklers calculated: 7
No. of nozzles calculated: 0

In-rack Demand: N/A gpm at Node: N/A
Hose Streams: 100.00 at Node: 1 Type: Allowance at Source

Total Water Required (including Hose Streams where applicable):
From Water Supply at Node 1: 217.53 @ 66.013 (Safety Margin = 15.613)

Type of System: DRY
Volume of Dry/PreAction/Antifreeze/OtherAgent System: 411.13gal

Name of Contractor: RED HAWK FIRE PROTECTION, LLC
Address: 801 VALLEY AVE NW, SUITE D, PUYALLUP, WA 98371
Phone Number: 253-604-7311
Name of designer: BROOKE MCDANIELS
Authority Having Jurisdiction: : CITY OF PUYALLUP

Notes:


Summary Notes:



Water Supply at Node 1

1 System Demand
3 Available Water Supply

Job Name: BRADLEY PARK CARE CENTER
Job Number: 70120
Report Description: Light Hazard (L1A5)
Remote Area Number: L1A5



Curve	Data Point	Hydraulic Calculation Results	Additional Data
1	1B	Required Pressure at System Demand: 66.013 @ 117.53	Available Flow @ 20 PSI: 3441.74
	1C	Required Pressure at System Demand (Including Hose Allowance at Source): 66.013 @ 217.53	
3	3A	Available Static Pressure at Water Supply at Node 1: 82.000	
	3B	Available Residual Pressure at System Demand: 81.625 @ 217.53	
	3C	Available Residual Pressure & Flow at Water Supply at Node 1: 24.000 @ 3320.00	



Summary Of Outflowing Devices

Job Number: 70120
Report Description: Light Hazard (L1A5)

Device	Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)			
⇒ Sprinkler 2400	14.82	10.00	5.6	7.000			
Sprinkler 2401	14.89	10.00	5.6	7.074			
Sprinkler 2402	15.22	10.00	5.6	7.390			
Sprinkler 2403	15.93	10.00	5.6	8.089			
Sprinkler 2404	17.10	10.00	5.6	9.327			
Sprinkler 2405	19.10	10.00	5.6	11.634			
Sprinkler 2406	20.47	10.00	5.6	13.360			

⇒ Most Demanding Sprinkler Data

Supply Analysis							
Node	Name	Static (psi)	Residual (psi)	@ Flow (gpm)	Available (psi)	@ Total Demand (gpm)	Required Pressure (psi)
1	Water Supply	82.000	24.000	3320.00	81.625	217.53	66.013

Node Analysis					
Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1	-4-0	Supply	66.013	117.53	
2400	18-5½	Sprinkler	7.000	14.82	
2401	18-6	Sprinkler	7.074	14.89	
2402	18-6½	Sprinkler	7.390	15.22	
2403	18-7	Sprinkler	8.089	15.93	
2404	18-7½	Sprinkler	9.327	17.10	
2405	19-7½	Sprinkler	11.634	19.10	
2406	22-6	Sprinkler	13.360	20.47	
2	-4-0		65.830	0.00	
3	-7-11½	Gauge	67.514	0.00	BOR, BFP(-3.599)
4	-7-11½		63.914	0.00	
5	-7-11½		63.908	0.00	
8	-3-7		61.197	0.00	
207	25-1		17.153	0.00	

Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
	Node 2		Elev 2 (Foot)	Total Flow (Q)		Actual ID	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	
		Total (Foot)			Friction(Pf)				
2400	18-5½	5.6	14.82	1½	(See Notes)	10-0	100	7.000	
2401	18-6		14.82	1.7280		10-0	0.009208	-0.018	
							0.092		
2401	18-6	5.6	14.89	1½	(See Notes)	10-0	100	7.074	Sprinkler
2402	18-6½		29.71	1.7280		10-0	0.033357	-0.018	
							0.334		
2402	18-6½	5.6	15.22	1½	(See Notes)	10-0	100	7.390	Sprinkler
2403	18-7		44.93	1.7280		10-0	0.071706	-0.018	
							0.717		
2403	18-7	5.6	15.93	1½	(See Notes)	10-0	100	8.089	Sprinkler
2404	18-7½		60.86	1.7280		10-0	0.125694	-0.018	
							1.257		
2404	18-7½	5.6	17.10	1½	(See Notes)	11-1	100	9.327	Sprinkler, fE(2-8)
2405	19-7½		77.96	1.7280		2-8	0.198743	-0.424	
						13-9		2.730	
2405	19-7½	5.6	19.10	1½	(See Notes)	10-0	100	11.634	Sprinkler
2406	22-6		97.06	1.7280		10-0	0.298095	-1.255	
								2.981	
2406	22-6	5.6	20.47	1½	(See Notes)	8-11	100	13.360	Sprinkler, fE(2-8)
207	25-1		117.53	1.7280		2-8	0.424707	-1.120	
						11-7		4.913	
207	25-1			2	(See Notes)	156-0½	100	17.153	2fE(3-1), 5E(4-4½), T(8-9½), 2 C(8-9½), PO(8-9½)
8	-3-7		117.53	2.1570		63-2	0.144237	12.426	
						219-2½		31.618	
8	-3-7			3	(See Notes)	6-11	100	61.197	E(6-8½), DPV(4-8½), BV(9-7), PO(14-4½)
4	-7-11½		117.53	3.2600		35-4½	0.019300	1.901	
						42-3		0.816	
4	-7-11½			6	(See Notes)	2-5½	120	63.914	BOR, BFP(-3.599)
3	-7-11½		117.53	6.3570		2-5½	0.000533	3.600	
3	-7-11½			6	(See Notes)	7-0	120	67.514	3E(17-7)
2	-4-0		117.53	6.3570		52-9½	0.000533	-1.716	
						59-9½		0.032	

Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
2	-4-0			6	Supply (See Notes)	263-10	120	65.830	
1	-4-0		117.53	6.3570		79-2½	0.000533	0.183	
								66.013	Total(Pt) Route 1

Equivalent Pipe Lengths of Valves and Fittings (C=120 only)

C Value Multiplier

$$\left(\frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

Fittings Legend

ALV Alarm Valve	AngV Angle Valve	b Bushing
BaIV Ball Valve	BFP Backflow Preventer	BV Butterfly Valve
C Cross Flow Turn 90°	cplg Coupling	Cr Cross Run
CV Check Valve	DelV Deluge Valve	DPV Dry Pipe Valve
E 90° Elbow	EE 45° Elbow	Ee1 11¼° Elbow
Ee2 22½° Elbow	f Flow Device	fd Flex Drop
FDC Fire Department Connection	fE 90° FireLock(TM) Elbow	fEE 45° FireLock(TM) Elbow
flg Flange	FN Floating Node	fT FireLock(TM) Tee
g Gauge	GloV Globe Valve	GV Gate Valve
Ho Hose	Hose Hose	HV Hose Valve
Hyd Hydrant	LtE Long Turn Elbow	mecT Mechanical Tee
Noz Nozzle	P1 Pump In	P2 Pump Out
PIV Post Indicating Valve	PO Pipe Outlet	PrV Pressure Relief Valve
PRV I Pressure Reducing Valve In	PRV C Pressure Reducing Valve Out	red Reducer/Adapter
S Supply	sCV Swing Check Valve	SFx Seismic Flex
Spr Sprinkler	St Strainer	T Tee Flow Turn 90°
Tr Tee Run	U Union	WirF Wirsbo
WMV Water Meter Valve	Z Cap	

Hydraulic Calculations

for

Project Name: BRADLEY PARK CARE CENTER: (70120)

Location: 707 39TH AVE SE, BLDG B, , PUYALLUP, WA 98374

Drawing Name: 70120 WBP Care Center R01 Level 1 & Attic.cad

Calculation Date: 4/10/2026

Design

Remote Area Number: L1A6
Remote Area Location: ENTRY CANOPY
Occupancy Classification: Light Hazard

Density: 0.100gpm/ft²
Area of Application: 1950.00ft² (Actual 928.73ft²)
Coverage per Sprinkler: 130.00ft²
Type of sprinklers calculated: Upright
No. of sprinklers calculated: 7
No. of nozzles calculated: 0

In-rack Demand: N/A gpm at Node: N/A
Hose Streams: 100.00 at Node: 1 Type: Allowance at Source

Total Water Required (including Hose Streams where applicable):
From Water Supply at Node 1: 242.62 @ 62.825 (Safety Margin = 18.716)

Type of System: DRY
Volume of Dry/PreAction/Antifreeze/OtherAgent System: 411.13gal

Name of Contractor: RED HAWK FIRE PROTECTION, LLC
Address: 801 VALLEY AVE NW, SUITE D, PUYALLUP, WA 98371
Phone Number: 253-604-7311
Name of designer: BROOKE MCDANIELS
Authority Having Jurisdiction: : CITY OF PUYALLUP


Notes:

Summary Notes:

Water Supply at Node 1

1 System Demand
3 Available Water Supply

Job Name: BRADLEY PARK CARE CENTER
 Job Number: 70120
 Report Description: Light Hazard (L1A6)
 Remote Area Number: L1A6



Curve	Data Point	Hydraulic Calculation Results	Additional Data
1	1B	Required Pressure at System Demand: 62.825 @ 142.62	Available Flow @ 20 PSI: 3441.74
	1C	Required Pressure at System Demand (Including Hose Allowance at Source): 62.825 @ 242.62	
3	3A	Available Static Pressure at Water Supply at Node 1: 82.000	
	3B	Available Residual Pressure at System Demand: 81.541 @ 242.62	
	3C	Available Residual Pressure & Flow at Water Supply at Node 1: 24.000 @ 3320.00	



Summary Of Outflowing Devices

Job Number: 70120
Report Description: Light Hazard (L1A6)

Device	Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)			
⇒ Sprinkler 2500	14.82	13.00	5.6	7.000			
Sprinkler 2501	15.10	13.00	5.6	7.275			
Sprinkler 2502	19.98	13.00	5.6	12.725			
Sprinkler 2503	20.66	13.00	5.6	13.613			
Sprinkler 2504	21.89	13.00	5.6	15.284			
Sprinkler 2505	23.78	13.00	5.6	18.026			
Sprinkler 2506	26.39	13.00	5.6	22.204			

⇒ Most Demanding Sprinkler Data

Supply Analysis							
Node	Name	Static (psi)	Residual (psi)	@ Flow (gpm)	Available (psi)	@ Total Demand (gpm)	Required Pressure (psi)
1	Water Supply	82.000	24.000	3320.00	81.541	242.62	62.825

Node Analysis					
Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1	-4-0	Supply	62.825	142.62	
2500	16-2	Sprinkler	7.000	14.82	
2501	16-2	Sprinkler	7.275	15.10	
2502	10-3½	Sprinkler	12.725	19.98	
2503	10-3	Sprinkler	13.613	20.66	
2504	10-2½	Sprinkler	15.284	21.89	
2505	10-2	Sprinkler	18.026	23.78	
2506	10-1½	Sprinkler	22.204	26.39	
2	-4-0		62.564	0.00	
3	-7-11½	Gauge	64.234	0.00	BOR, BFP(-3.188)
4	-7-11½		61.044	0.00	
5	-7-11½		61.039	0.00	
8	-3-7		57.977	0.00	
219	10-9		12.086	0.00	
255	10-4		12.478	0.00	
256	10-1		32.748	0.00	

Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
										Node 2
2500	16-2	5.6	14.82	1¼	(See Notes)	10-0	100	7.000		
2501	16-2		14.82	1.3800		10-0	0.027529	0.275		
2501	16-2	5.6	15.10	1¼	(See Notes)	13-8	100	7.275	Sprinkler, 5E(2-1½)	
219	10-9		29.92	1.3800		10-8½	0.101037	2.348		
						24-4½		2.463		
219	10-9			1½	(See Notes)	1-7	100	12.086	E(2-10)	
255	10-4		29.92	1.6100		2-10	0.047693	0.181		
						4-5		0.211		
255	10-4			1½		6-11½	100	12.478		
2502	10-3½		29.92	1.7280			0.033795	0.013		
						6-11½		0.235		
2502	10-3½	5.6	19.98	1½	(See Notes)	10-0	100	12.725	Sprinkler	
2503	10-3		49.90	1.7280			0.087044	0.018		
						10-0		0.870		
2503	10-3	5.6	20.66	1½	(See Notes)	10-0	100	13.613	Sprinkler	
2504	10-2½		70.56	1.7280			0.165242	0.018		
						10-0		1.652		
2504	10-2½	5.6	21.89	1½	(See Notes)	10-0	100	15.284	Sprinkler	
2505	10-2		92.45	1.7280			0.272423	0.018		
						10-0		2.724		
2505	10-2	5.6	23.78	1½	(See Notes)	10-0	100	18.026	Sprinkler	
2506	10-1½		116.23	1.7280			0.416029	0.018		
						10-0		4.160		
2506	10-1½	5.6	26.39	1½	(See Notes)	9-3½	100	22.204	Sprinkler, T(8-0½)	
256	10-1		142.62	1.7280		8-0½	0.607451	0.017		
						17-4		10.527		
256	10-1			2	(See Notes)	55-4½	100	32.748	2E(4-4½), fE(3-1), 2C(8-9½), PO(8-9½)	
8	-3-7		142.62	2.1570		38-2	0.206300	5.927		
						93-6½		19.301		
8	-3-7			3	(See Notes)	6-11	100	57.977	E(6-8½), DPV(4-8½), BV(9-7), PO(14-4½)	
4	-7-11½		142.62	3.2600		35-4½	0.027604	1.901		
						42-3		1.167		

Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
4	-7-11½			6	(See Notes)	2-5½	120	61.044	
3	-7-11½		142.62	6.3570		2-5½	0.000762	3.190	
BOR, BFP(-3.188)									
3	-7-11½			6	(See Notes)	7-0	120	64.234	
2	-4-0		142.62	6.3570		52-9½	0.000762	-1.716	
3E(17-7)									
2	-4-0			6	Supply (See Notes)	263-10	120	62.564	
1	-4-0		142.62	6.3570		79-2½	0.000762	0.261	
Avl. Pressure @ Supply: 81.541 4E(17-7), EE(8-9½), S									
								62.825	Total(Pt) Route 1

Equivalent Pipe Lengths of Valves and Fittings (C=120 only)

C Value Multiplier

$$\left(\frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

Fittings Legend

ALV Alarm Valve	AngV Angle Valve	b Bushing
BaIV Ball Valve	BFP Backflow Preventer	BV Butterfly Valve
C Cross Flow Turn 90°	cplg Coupling	Cr Cross Run
CV Check Valve	DelV Deluge Valve	DPV Dry Pipe Valve
E 90° Elbow	EE 45° Elbow	Ee1 11¼° Elbow
Ee2 22½° Elbow	f Flow Device	fd Flex Drop
FDC Fire Department Connection	fE 90° FireLock(TM) Elbow	fEE 45° FireLock(TM) Elbow
flg Flange	FN Floating Node	fT FireLock(TM) Tee
g Gauge	GloV Globe Valve	GV Gate Valve
Ho Hose	Hose Hose	HV Hose Valve
Hyd Hydrant	LtE Long Turn Elbow	mecT Mechanical Tee
Noz Nozzle	P1 Pump In	P2 Pump Out
PIV Post Indicating Valve	PO Pipe Outlet	PrV Pressure Relief Valve
PRV I Pressure Reducing Valve In	PRV C Pressure Reducing Valve Out	red Reducer/Adapter
S Supply	sCV Swing Check Valve	SFx Seismic Flex
Spr Sprinkler	St Strainer	T Tee Flow Turn 90°
Tr Tee Run	U Union	WirF Wirsbo
WMV Water Meter Valve	Z Cap	

RED HAWK FIRE PROTECTION, LLC

801 Valley Ave NW, Suite D
Puyallup, WA 98371
(253) 840-9900

REDHAHF901QP





Ever Vigilant[®]

SEISMIC CALCULATIONS

FOR

Wesley Bradley Park – Care Center
Puyallup, WA

RHFP JOB NO. 70120

 Expires DEC 31, 26	WASHINGTON STATE CERTIFICATE OF COMPETENCY FIRE SPRINKLER SYSTEMS
Travis Clifton Kinne 0835-1021-C Level 3 Red Hawk Fire Protection, LLC REDHAHF901QP	
	04/10/2026
Signature	Date

SITE SPECIFIC INFORMATION

APPLIED BUILDING CODE (IBC): **2018**

APPLIED EDITION OF NFPA 13: **2019**

SEISMIC DESIGN CATEGORY: **D**

SITE CLASS: **C**

OCCUPANCY CATEGORY: **II**

S_s : **1.257**

S_1 : **0.434**

S_{DS} : **1.000**

S_{D1} : **0.434**

C_p : **0.61**

(C_p FACTOR DETERMINED BY NFPA 13 (2016) TABLE 9.3.5.9.3 OR NFPA 13 (2019)
TABLE 18.5.9.3)

SITE & BUILDING STRUCTURAL ANALYSIS BY: **AHBL**

NFPA 13 2019 Seismic Bracing Calculations

Project Name: WBP - Care Center
 Address: 707 39th Ave SE
 City, State, Zip: Puyallup, WA 98374
 Prepared By: McDaniels, Brooke

Brace Design: B1
 Contractor Name: Red Hawk Fire Protection
 Address: 801 Valley Ave NW
 City, State, Zip: Puyallup, Washington 98371

Date: 09-Apr-2026

Fax:

Phone: 2538409900

Brace Information	Seismic Brace Attachments
Maximum Length of Brace: 7'-0"	Structure Attachment Fitting: Universal Structural Bracket, EG, 9/16" Hole
Size of Brace (in): 1" - Sch40	Make: CADDY Model: CSBU1
Type of Brace: Sch 40 Pipe	UL Load Rating (lbs): 2000 Adjusted Per 18.5.2.3 (lbs): 1414
Brace Angle Range: 45-59 Degrees	Structure Attachment Adapter: Multi Attachment, 9/16" Hole 1, 9/16" Hole 2
Maximum Brace Spacing (ft): 25.00	Make: CADDY Model: CSBMA050050EG
Least Radius of Gyration* (in): 0.421	UL Load Rating (lbs): 680 Adjusted Per 18.5.2.3 (lbs): 480
<i>kl/r Value</i> : * 200	Sway Brace Fitting: Quick Grip Lateral Sway Brace, 3" Pipe
Maximum Horizontal Load (lbs): 1310	Make: CADDY Model: CSBQG0300EG
	UL Load Rating (lbs): 1300 Adjusted Per 18.5.2.3 (lbs): 919
Fastener Information	
Fastener Orientation: H	
Structure: Wood - Lag Screw	
Fastener Qty: 2	
Fastener Type: Lag Screw	
Fastener Size: 1/2" x 4 1/2"	
Fastener Embedment: 4 1/2"	
Fastener Max. Load (lbs): 460	
Brace Orientation: Lateral	
Brace I.D. (on plan): B1	

Sprinkler System Zone of Influence (ZOI) Load Calculation ($F_{pw} = C_p \times W_p$)

Pipe Size	Pipe Description	Wt/ft (lbs)	15% for Fittings	Total Wt/ft	Length (ft)	Total Wt	$C_p = 0.61$ per NFPA 13 2019 2018 IBC
3"	Sch 10	7.90	1.19	9.09	25.00	227.10	
1 1/4"	Sch 40	2.90	0.44	3.34	86.00	286.81	
1"	Sch 40	2.10	0.32	2.42	27.00	65.21	Sway Brace Attached to 3" Sch10 Pipe Max Fpw Based on 3" Sch10 Pipe
							Horizontal Earthquake Load $F_{pw} = C_p \times W_p$ $F_{pw} = 0.61 \times 579.12$ $F_{pw} = 353.00$ lbs
Weight of Misc. ZOI Valves and Fittings						0.00	
Total Zone of Influence (ZOI) Weight (W_p)						579.12	
Max Fpw per NFPA 13 2019, Section 18.5.5.2 including Section 18.5.5.2.4						773 lbs	

*Excludes tension-only bracing systems



© 2018 nVent All rights reserved

nVent, nVent CADDY, nVent ERICO, nVent ERIFLEX, and nVent LENTON are owned by nVent or its global affiliates. All other trademarks are the property of their respective owners. nVent reserves the right to change specifications without prior notice.

NFPA 13 2019 Seismic Bracing Calculations

Project Name: WBP - Care Center
 Address: 707 39th Ave SE
 City, State, Zip: Puyallup, WA 98374
 Prepared By: McDaniels, Brooke

Brace Design: B3
 Contractor Name: Red Hawk Fire Protection
 Address: 801 Valley Ave NW
 City, State, Zip: Puyallup, Washington 98371

Date: 09-Apr-2026

Fax:

Phone: 2538409900

Brace Information	Seismic Brace Attachments
Maximum Length of Brace: 7'-0"	Structure Attachment Fitting: Universal Structural Bracket, EG, 9/16" Hole
Size of Brace (in): 1" - Sch40	Make: CADDY Model: CSBU1
Type of Brace: Sch 40 Pipe	UL Load Rating (lbs): 2000 Adjusted Per 18.5.2.3 (lbs): 1414
Brace Angle Range: 45-59 Degrees	Structure Attachment Adapter: Multi Attachment, 9/16" Hole 1, 9/16" Hole 2
Maximum Brace Spacing (ft): 30.00	Make: CADDY Model: CSBMA050050EG
Least Radius of Gyration* (in): 0.421	UL Load Rating (lbs): 680 Adjusted Per 18.5.2.3 (lbs): 480
<i>kl/r Value:</i> * 200	Sway Brace Fitting: Quick Grip Lateral Sway Brace, 3" Pipe
Maximum Horizontal Load (lbs): 1310	Make: CADDY Model: CSBQG0300EG
	UL Load Rating (lbs): 1300 Adjusted Per 18.5.2.3 (lbs): 919
Fastener Information	
Fastener Orientation: H	
Structure: Wood - Lag Screw	
Fastener Qty: 2	
Fastener Type: Lag Screw	
Fastener Size: 1/2" x 4 1/2	
Fastener Embedment: 4 1/2"	
Fastener Max. Load (lbs): 460	
Brace Orientation: Lateral	
Brace I.D. (on plan): B3	

Sprinkler System Zone of Influence (ZOI) Load Calculation ($F_{pw} = C_p \times W_p$)

Pipe Size	Pipe Description	Wt/ft (lbs)	15% for Fittings	Total Wt/ft	Length (ft)	Total Wt	Cp = 0.61 per NFPA 13 2019 2018 IBC
3"	EDDY Flow	7.14	1.07	8.21	30.00	246.30	
1 1/2"	CPVC	1.42	0.21	1.63	102.00	166.57	
1"	CPVC	0.68	0.10	0.78	147.00	114.95	Sway Brace Attached to 3" Eddy_Flow Pipe Max Fpw Based on 3" Eddy_Flow Pipe
							Horizontal Earthquake Load $F_{pw} = C_p \times W_p$ $F_{pw} = 0.61 \times 527.82$ Fpw = 322.00 lbs
Weight of Misc. ZOI Valves and Fittings						0.00	
Total Zone of Influence (ZOI) Weight (Wp)						527.82	
Max Fpw per NFPA 13 2019, Section 18.5.5.2 including Section 18.5.5.2.4						531 lbs	

*Excludes tension-only bracing systems



© 2018 nVent All rights reserved

nVent, nVent CADDY, nVent ERICO, nVent ERIFLEX, and nVent LENTON are owned by nVent or its global affiliates. All other trademarks are the property of their respective owners. nVent reserves the right to change specifications without prior notice.

NFPA 13 2019 Seismic Bracing Calculations

Project Name: WBP - Care Center
 Address: 707 39th Ave SE
 City, State, Zip: Puyallup, WA 98374
 Prepared By: McDaniels, Brooke
 Date: 09-Apr-2026

Brace Design: B4
 Contractor Name: Red Hawk Fire Protection
 Address: 801 Valley Ave NW
 City, State, Zip: Puyallup, Washington 98371
 Phone: 2538409900

Fax:

Brace Information	Seismic Brace Attachments
Maximum Length of Brace: 7'-0"	Structure Attachment Fitting: Universal Structural Bracket, EG, 9/16" Hole Make: CADDY Model: CSBU1 UL Load Rating (lbs): 2000 Adjusted Per 18.5.2.3 (lbs): 1414
Size of Brace (in): 1" - Sch40	
Type of Brace: Sch 40 Pipe	
Brace Angle Range: 45-59 Degrees	Structure Attachment Adapter: Multi Attachment, 9/16" Hole 1, 9/16" Hole 2 Make: CADDY Model: CSBMA050050EG UL Load Rating (lbs): 680 Adjusted Per 18.5.2.3 (lbs): 480
Maximum Brace Spacing (ft): 30.00	
Least Radius of Gyration* (in): 0.421	Sway Brace Fitting: Quick Grip Lateral Sway Brace, 2 1/2" Pipe Make: CADDY Model: CSBQG0250EG UL Load Rating (lbs): 1500 Adjusted Per 18.5.2.3 (lbs): 1060
<i>kl/r Value:</i> * 200	
Maximum Horizontal Load (lbs): 1310	
Fastener Information	
Fastener Orientation: H	
Structure: Wood - Lag Screw	
Fastener Qty: 2	
Fastener Type: Lag Screw	
Fastener Size: 1/2" x 4 1/2	
Fastener Embedment: 4 1/2"	
Fastener Max. Load (lbs): 460	
Brace Orientation: Lateral	
Brace I.D. (on plan): B4	

Sprinkler System Zone of Influence (ZOI) Load Calculation ($F_{pw} = C_p \times W_p$)

Pipe Size	Pipe Description	Wt/ft (lbs)	15% for Fittings	Total Wt/ft	Length (ft)	Total Wt	$C_p = 0.61$ per NFPA 13 2019 2018 IBC
2 1/2"	EDDY Flow	5.30	0.80	6.10	30.00	182.90	
1 1/4"	Sch 40	2.90	0.44	3.34	85.00	283.48	
							Sway Brace Attached to 2 1/2" Eddy_Flow Pipe Max Fpw Based on 2 1/2" Eddy_Flow Pipe
							Horizontal Earthquake Load $F_{pw} = C_p \times W_p$ $F_{pw} = 0.61 \times 466.38$ $F_{pw} = 284.00$ lbs
Weight of Misc. ZOI Valves and Fittings						0.00	
Total Zone of Influence (ZOI) Weight (W_p)						466.38	
Max Fpw per NFPA 13 2019, Section 18.5.5.2 including Section 18.5.5.2.4						360 lbs	

*Excludes tension-only bracing systems



© 2018 nVent All rights reserved

nVent, nVent CADDY, nVent ERICO, nVent ERIFLEX, and nVent LENTON are owned by nVent or its global affiliates. All other trademarks are the property of their respective owners. nVent reserves the right to change specifications without prior notice.

NFPA 13 2019 Seismic Bracing Calculations

Project Name: WBP - Care Center
 Address: 707 39th Ave SE
 City, State, Zip: Puyallup, WA 98374
 Prepared By: McDaniels, Brooke

Brace Design: B5
 Contractor Name: Red Hawk Fire Protection
 Address: 801 Valley Ave NW
 City, State, Zip: Puyallup, Washington 98371

Date: 09-Apr-2026

Fax:

Phone: 2538409900

Brace Information	Seismic Brace Attachments
Maximum Length of Brace: 7'-0"	Structure Attachment Fitting: Universal Structural Bracket, EG, 9/16" Hole
Size of Brace (in): 1" - Sch40	Make: CADDY Model: CSBU1
Type of Brace: Sch 40 Pipe	UL Load Rating (lbs): 2000 Adjusted Per 18.5.2.3 (lbs): 1414
Brace Angle Range: 45-59 Degrees	Structure Attachment Adapter: n/a
Maximum Brace Spacing (ft): 80.00	Make: CADDY Model: n/a
Least Radius of Gyration* (in): 0.421	UL Load Rating (lbs): n/a Adjusted Per 18.5.2.3 (lbs): n/a
<i>kl/r Value</i> : * 200	Sway Brace Fitting: Universal Sway Brace, EG, 2 1/2" Pipe
Maximum Horizontal Load (lbs): 1310	Make: CADDY Model: CSB0250
	UL Load Rating (lbs): 1300 Adjusted Per 18.5.2.3 (lbs): 919
Fastener Information	
Fastener Orientation: E	
Structure: Wood - Lag Screw	
Fastener Qty: 1	
Fastener Type: Lag Screw	
Fastener Size: 1/2" x 4 1/2	
Fastener Embedment: 4 1/2"	
Fastener Max. Load (lbs): 400	
Brace Orientation: Longitudinal	
Brace I.D. (on plan): B5	

Sprinkler System Zone of Influence (ZOI) Load Calculation ($F_{pw} = C_p \times W_p$)

Pipe Size	Pipe Description	Wt/ft (lbs)	15% for Fittings	Total Wt/ft	Length (ft)	Total Wt	$C_p = 0.61$ per NFPA 13 2019 2018 IBC
2 1/2"	EDDY Flow	5.30	0.80	6.10	80.00	487.60	
							Sway Brace Attached to 2 1/2" Eddy_Flow Pipe
							Horizontal Earthquake Load $F_{pw} = C_p \times W_p$ $F_{pw} = 0.61 \times 487.60$ $F_{pw} = 297.00$ lbs
Weight of Misc. ZOI Valves and Fittings						0.00	
Total Zone of Influence (ZOI) Weight (W_p)						487.60	

*Excludes tension-only bracing systems



NFPA 13 2019 Seismic Bracing Calculations

Project Name: WBP - Care Center
 Address: 707 39th Ave SE
 City, State, Zip: Puyallup, WA 98374
 Prepared By: McDaniels, Brooke
 Date: 09-Apr-2026

Brace Design: B6
 Contractor Name: Red Hawk Fire Protection
 Address: 801 Valley Ave NW
 City, State, Zip: Puyallup, Washington 98371
 Phone: 2538409900

Fax:

Brace Information	Seismic Brace Attachments
Maximum Length of Brace: 7'-0"	Structure Attachment Fitting: Universal Structural Bracket, EG, 9/16" Hole Make: CADDY Model: CSBU1 UL Load Rating (lbs): 2000 Adjusted Per 18.5.2.3 (lbs): 1414
Size of Brace (in): 1" - Sch40	
Type of Brace: Sch 40 Pipe	
Brace Angle Range: 45-59 Degrees	Structure Attachment Adapter: n/a Make: CADDY Model: n/a UL Load Rating (lbs): n/a Adjusted Per 18.5.2.3 (lbs): n/a
Maximum Brace Spacing (ft): 25.00	
Least Radius of Gyration* (in): 0.421	Sway Brace Fitting: Universal Sway Brace, EG, 2" Pipe Make: CADDY Model: CSB0200 UL Load Rating (lbs): 1800 Adjusted Per 18.5.2.3 (lbs): 1272
<i>kl/r Value:</i> * 200	
Maximum Horizontal Load (lbs): 1310	
Fastener Information	
Fastener Orientation: H	
Structure: Wood - Lag Screw	
Fastener Qty: 1	
Fastener Type: Lag Screw	
Fastener Size: 1/2" x 4 1/2	
Fastener Embedment: 4 1/2"	
Fastener Max. Load (lbs): 230	
Brace Orientation: Lateral	
Brace I.D. (on plan): B6	

Sprinkler System Zone of Influence (ZOI) Load Calculation ($F_{pw} = C_p \times W_p$)

Pipe Size	Pipe Description	Wt/ft (lbs)	15% for Fittings	Total Wt/ft	Length (ft)	Total Wt	Cp = 0.61 per NFPA 13 2019 2018 IBC Sway Brace Attached to 2" Sch10 Pipe Max Fpw Based on 2" Sch10 Pipe
2"	Sch 10	4.20	0.63	4.83	25.00	120.80	
1 1/2"	Sch 10	3.00	0.45	3.45	66.00	227.70	
1"	Sch 40	2.10	0.32	2.42	2.00	4.83	
							Horizontal Earthquake Load $F_{pw} = C_p \times W_p$ $F_{pw} = 0.61 \times 353.33$ Fpw = 216.00 lbs
Weight of Misc. ZOI Valves and Fittings						0.00	
Total Zone of Influence (ZOI) Weight (Wp)						353.33	
Max Fpw per NFPA 13 2019, Section 18.5.5.2 including Section 18.5.5.2.4						312 lbs	

*Excludes tension-only bracing systems



© 2018 nVent All rights reserved

nVent, nVent CADDY, nVent ERICO, nVent ERIFLEX, and nVent LENTON are owned by nVent or its global affiliates. All other trademarks are the property of their respective owners. nVent reserves the right to change specifications without prior notice.

NFPA 13 2019 Seismic Bracing Calculations

Project Name: WBP - Care Center
 Address: 707 39th Ave SE
 City, State, Zip: Puyallup, WA 98374
 Prepared By: McDaniels, Brooke
 Date: 09-Apr-2026

Brace Design: B7
 Contractor Name: Red Hawk Fire Protection
 Address: 801 Valley Ave NW
 City, State, Zip: Puyallup, Washington 98371
 Phone: 2538409900

Fax:

Brace Information	Seismic Brace Attachments
Maximum Length of Brace: 7'-0"	Structure Attachment Fitting: Universal Structural Bracket, EG, 9/16" Hole
Size of Brace (in): 1" - Sch40	Make: CADDY Model: CSBU1
Type of Brace: Sch 40 Pipe	UL Load Rating (lbs): 2000 Adjusted Per 18.5.2.3 (lbs): 1414
Brace Angle Range: 45-59 Degrees	Structure Attachment Adapter: n/a
Maximum Brace Spacing (ft): 80.00	Make: CADDY Model: n/a
Least Radius of Gyration* (in): 0.421	UL Load Rating (lbs): n/a Adjusted Per 18.5.2.3 (lbs): n/a
<i>kl/r Value:</i> * 200	Sway Brace Fitting: Universal Sway Brace, EG, 2" Pipe
Maximum Horizontal Load (lbs): 1310	Make: CADDY Model: CSB0200
	UL Load Rating (lbs): 1300 Adjusted Per 18.5.2.3 (lbs): 919
Fastener Information	
Fastener Orientation: E	
Structure: Wood - Lag Screw	
Fastener Qty: 1	
Fastener Type: Lag Screw	
Fastener Size: 1/2" x 4 1/2	
Fastener Embedment: 4 1/2"	
Fastener Max. Load (lbs): 400	
Brace Orientation: Longitudinal	
Brace I.D. (on plan): B7	

Sprinkler System Zone of Influence (ZOI) Load Calculation ($F_{pw} = C_p \times W_p$)

Pipe Size	Pipe Description	Wt/ft (lbs)	15% for Fittings	Total Wt/ft	Length (ft)	Total Wt	$C_p = 0.61$ per NFPA 13 2019 2018 IBC
2"	Sch 10	4.20	0.63	4.83	80.00	386.40	
							Sway Brace Attached to 2" Sch10 Pipe
							Horizontal Earthquake Load $F_{pw} = C_p \times W_p$ $F_{pw} = 0.61 \times 386.40$ $F_{pw} = 236.00$ lbs
Weight of Misc. ZOI Valves and Fittings						0.00	
Total Zone of Influence (ZOI) Weight (W_p)						386.40	

*Excludes tension-only bracing systems



TOLBrace™ Seismic Bracing Calculations

V8.8.145

Project Address: WBP - Care Center
707 39th Ave SE, BLDG B
Puyallup, WA 98374
Job # 70120

Contractor: Red Hawk Fire Protection
Address: 801 Valley Ave NW, Suite D
Puyallup, WA 98371
Phone: 253-604-7311
License: REDHAHF901QP



Calculations based on 2019 NFPA Pamphlet #13

Brace Information		TOLCO™ Brace Components		
Maximum Brace Length	<u>7' 0" (2.134 m)</u>	TOLCO™ Component	Listed Load	Adjusted Load
Diameter of Brace	<u>1"</u>	Fig. 3000 Clamp	700 lbs (318 kg)	495 lbs (225 kg)
Type of Brace	<u>Sch.40</u>	Fig.909 - 1/2" No-Thread Swivel	1370 lbs (621 kg)	969 lbs (440 kg)
Angle of Brace	<u>45° Min.</u>	See Fastener Information		
Least Rad. of Gyration	<u>0.42" (11 mm)</u>	*Calculation Based on CONCENTRIC Loading		
L/R Value	<u>200</u>	*Please Note: These calculations are for TOLCO™ components only. Use of any other components voids these calculations and the listing of the assembly.		
Max Horizontal Load	<u>1310 lbs (594 kg)</u>			
Seismic Brace Assembly Detail				
Fastener Information		Brace Identification on Plans B8		
Orientation to Connecting Surface	<u>NFPA Type B</u>	Brace Type Lateral [X] Longitudinal [] 4-Way []		
Fastener Type	<u>1/2in. x 2 1/2in. Thru Bolt</u>			
Diameter	<u>1/2in.</u>			
Length	<u>2 1/2in.</u>			
Maximum Load	<u>200 lbs (91 kg)</u>			
Prying Factor	<u>N/A</u>			

Sprinkler System Load Calculation (Fpw = CpWp)					
Cp before reduction =		Reduction factor =		Cp =	
<u>0.59</u>		<u>N/A</u>		<u>0.59</u>	
Diameter	Type	Length	Total Length	Weight Per Unit Length	Total Weight
2.5" (65 mm)	CPVC	30 ft (9.1 m)	30 ft (9.1 m)	3.254449 lb/ft (4.84 kg/m)	98 lbs (44 kg)
1.5" (40 mm)	CPVC	116 ft (35.4 m)	116 ft (35.4 m)	1.41666 lb/ft (2.11 kg/m)	164 lbs (74 kg)
1" (25 mm)	CPVC	23 ft (7 m)	23 ft (7 m)	0.674355 lb/ft (1 kg/m)	16 lbs (7 kg)
Subtotal Weight					278 lbs (126 kg)
Wp (incl. 15%)					320 lbs (145 kg)
Main Size	Type/Sch.	Spacing (ft)	Total (Fpw)		189 lbs (86 kg)
2.5"	CPVC	30	Maximum Fpw per 18.5.5.2 (if applicable)		188 lb (85 kg)

TOLBrace™ Seismic Calculations

WBP - Care Center
707 39th Ave SE, BLDG B

Job # 70120



Brace Identification	B8
Brace Type (Per NFPA#13)	NFPA Type B
Braced Pipe (ft)	2.5" CPVC
Spacing of Brace	30' 0" (9.14 m)
Orientation of Brace	Lateral
Bracing Material	1" Sch.40
Maximum Brace Length	7' 0" (2.13 m)
Slenderness Ratio used for Load Calculation	200
True Angle of Brace for Calculation	45°
Type of Fastener	1/2in. x 2 1/2in. Thru Bolt
Length of Fastener	2 1/2in.

Summary of Pipe within Zone of Influence

2.5" CPVC (63.5 mm)	30 ft (9.1 m)
1.5" CPVC (38.1 mm)	116 ft (35.4 m)
1" CPVC (25.4 mm)	23 ft (7 m)

G-Factor Used 0.59

Allowance for Heads and Fittings 15%

Conclusions

Total Adjusted Load of Pipe in Zone of Influence	188 lbs (85 kg)
Material Capacity	1310 lbs (594 kg)
Fastener Capacity	200 lbs (91 kg)
Fig. 3000 Clamp	495 lbs (225 kg)
Fig.909 - 1/2" No-Thread Swivel	969 lbs (440 kg)
Structural Member	Wood Open-Web Truss

Calculations prepared by Brooke McDaniels

* The description of the Structural Member is for informational purposes only.
TOLBrace™ software calculates the brace assembly only, not the structure it is attached to.
Calculated with TOLBrace™ 8
Visit us at www.tolco.com

TOLBrace™ Seismic Bracing Calculations

V8.8.145

Project Address: WBP - Care Center
707 39th Ave SE, BLDG B
Puyallup, WA 98374
Job # 70120

Contractor: Red Hawk Fire Protection
Address: 801 Valley Ave NW, Suite D
Puyallup, WA 98371
Phone: 253-604-7311
License: REDHAHF901QP



Calculations based on 2019 NFPA Pamphlet #13

Brace Information		TOLCO™ Brace Components		
Maximum Brace Length	<u>7' 0" (2.134 m)</u>	TOLCO™ Component	Listed Load	Adjusted Load
Diameter of Brace	<u>1"</u>	Fig. 3000 Clamp	700 lbs (318 kg)	495 lbs (225 kg)
Type of Brace	<u>Sch.40</u>	Fig.909 - 1/2" No-Thread Swivel	1370 lbs (621 kg)	969 lbs (440 kg)
Angle of Brace	<u>45° Min.</u>	See Fastener Information		
Least Rad. of Gyration	<u>0.42" (11 mm)</u>	*Calculation Based on CONCENTRIC Loading		
L/R Value	<u>200</u>	*Please Note: These calculations are for TOLCO™ components only. Use of any other components voids these calculations and the listing of the assembly.		
Max Horizontal Load	<u>1310 lbs (594 kg)</u>			
Seismic Brace Assembly Detail				
Fastener Information		Brace Identification on Plans B9		
Orientation to Connecting Surface	<u>NFPA Type B</u>	Brace Type Lateral [X] Longitudinal [] 4-Way []		
Fastener Type	<u>1/2in. x 2 1/2in. Thru Bolt</u>			
Diameter	<u>1/2in.</u>			
Length	<u>2 1/2in.</u>			
Maximum Load	<u>200 lbs (91 kg)</u>			
Prying Factor	<u>N/A</u>			

Sprinkler System Load Calculation (Fpw = CpWp)					
Cp before reduction =		Reduction factor =		Cp =	
<u>0.59</u>		<u>N/A</u>		<u>0.59</u>	
Diameter	Type	Length	Total Length	Weight Per Unit Length	Total Weight
2.5" (65 mm)	CPVC	40 ft (12.2 m)	40 ft (12.2 m)	3.254449 lb/ft (4.84 kg/m)	130 lbs (59 kg)
				Subtotal Weight	130 lbs (59 kg)
				Wp (incl. 15%)	150 lbs (68 kg)
Main Size	Type/Sch.	Spacing (ft)	Total (Fpw)		88 lbs (40 kg)
2.5"	CPVC	40	Maximum Fpw per 18.5.5.2 (if applicable)		135 lb (61 kg)

TOLBrace™ Seismic Calculations

WBP - Care Center

Job # 70120

707 39th Ave SE, BLDG B



Brace Identification	B9
Brace Type (Per NFPA#13)	NFPA Type B
Braced Pipe (ft)	2.5" CPVC
Spacing of Brace	40' 0" (12.19 m)
Orientation of Brace	Lateral
Bracing Material	1" Sch.40
Maximum Brace Length	7' 0" (2.13 m)
Slenderness Ratio used for Load Calculation	200
True Angle of Brace for Calculation	45°
Type of Fastener	1/2in. x 2 1/2in. Thru Bolt
Length of Fastener	2 1/2in.

Summary of Pipe within Zone of Influence

2.5" CPVC (63.5 mm)	40 ft (12.2 m)

G-Factor Used 0.59

Allowance for Heads and Fittings 15%

Conclusions

Total Adjusted Load of Pipe in Zone of Influence	88 lbs (40 kg)
Material Capacity	1310 lbs (594 kg)
Fastener Capacity	200 lbs (91 kg)
Fig. 3000 Clamp	495 lbs (225 kg)
Fig.909 - 1/2" No-Thread Swivel	969 lbs (440 kg)
Structural Member	Wood Open-Web Truss

Calculations prepared by Brooke McDaniels

* The description of the Structural Member is for informational purposes only.
TOLBrace™ software calculates the brace assembly only, not the structure it is attached to.
Calculated with TOLBrace™ 8
Visit us at www.tolco.com

NFPA 13 2019 Seismic Bracing Calculations

Project Name: WBP - Care Center
 Address: 707 39th Ave SE
 City, State, Zip: Puyallup, WA 98374
 Prepared By: McDaniels, Brooke

Brace Design: B10
 Contractor Name: Red Hawk Fire Protection
 Address: 801 Valley Ave NW
 City, State, Zip: Puyallup, Washington 98371

Date: 09-Apr-2026

Fax:

Phone: 2538409900

Brace Information	Seismic Brace Attachments
Maximum Length of Brace: 7'-0"	Structure Attachment Fitting: Universal Structural Bracket, EG, 9/16" Hole
Size of Brace (in): 1" - Sch40	Make: CADDY Model: CSBU1
Type of Brace: Sch 40 Pipe	UL Load Rating (lbs): 2000 Adjusted Per 18.5.2.3 (lbs): 1414
Brace Angle Range: 45-59 Degrees	Structure Attachment Adapter: n/a
Maximum Brace Spacing (ft): 40.00	Make: CADDY Model: n/a
Least Radius of Gyration* (in): 0.421	UL Load Rating (lbs): n/a Adjusted Per 18.5.2.3 (lbs): n/a
<i>kl/r Value:</i> * 200	Sway Brace Fitting: Universal Sway Brace, EG, 1 1/2" Pipe
Maximum Horizontal Load (lbs): 1310	Make: CADDY Model: CSB0150
	UL Load Rating (lbs): 1800 Adjusted Per 18.5.2.3 (lbs): 1272
Fastener Information	
Fastener Orientation: H	
Structure: Wood - Lag Screw	
Fastener Qty: 1	
Fastener Type: Lag Screw	
Fastener Size: 1/2" x 4 1/2	
Fastener Embedment: 4 1/2"	
Fastener Max. Load (lbs): 230	
Brace Orientation: Lateral	
Brace I.D. (on plan): B10	

Sprinkler System Zone of Influence (ZOI) Load Calculation ($F_{pw} = C_p \times W_p$)

Pipe Size	Pipe Description	Wt/ft (lbs)	15% for Fittings	Total Wt/ft	Length (ft)	Total Wt	$C_p = 0.61$ per NFPA 13 2019 2018 IBC
1 1/2"	Sch 10	3.00	0.45	3.45	40.00	138.00	
							Sway Brace Attached to 1 1/2" Sch10 Pipe Max Fpw Based on 1 1/2" Sch10 Pipe
							Horizontal Earthquake Load $F_{pw} = C_p \times W_p$ $F_{pw} = 0.61 \times 138.00$ $F_{pw} = 84.00$ lbs
Weight of Misc. ZOI Valves and Fittings						0.00	
Total Zone of Influence (ZOI) Weight (W_p)						138.00	
Max Fpw per NFPA 13 2019, Section 18.5.5.2 including Section 18.5.5.2.4						114 lbs	

*Excludes tension-only bracing systems



© 2018 nVent All rights reserved

nVent, nVent CADDY, nVent ERICO, nVent ERIFLEX, and nVent LENTON are owned by nVent or its global affiliates. All other trademarks are the property of their respective owners. nVent reserves the right to change specifications without prior notice.

NFPA 13 2019 Seismic Bracing Calculations

Project Name: WBP - Care Center
 Address: 707 39th Ave SE
 City, State, Zip: Puyallup, WA 98374
 Prepared By: McDaniels, Brooke

Brace Design: B11
 Contractor Name: Red Hawk Fire Protection
 Address: 801 Valley Ave NW
 City, State, Zip: Puyallup, Washington 98371

Date: 09-Apr-2026

Fax:

Phone: 2538409900

Brace Information	Seismic Brace Attachments
Maximum Length of Brace: 7'-0"	Structure Attachment Fitting: Universal Structural Bracket, EG, 9/16" Hole
Size of Brace (in): 1" - Sch40	Make: CADDY Model: CSBU1
Type of Brace: Sch 40 Pipe	UL Load Rating (lbs): 2000 Adjusted Per 18.5.2.3 (lbs): 1414
Brace Angle Range: 45-59 Degrees	Structure Attachment Adapter: n/a
Maximum Brace Spacing (ft): 80.00	Make: CADDY Model: n/a
Least Radius of Gyration* (in): 0.421	UL Load Rating (lbs): n/a Adjusted Per 18.5.2.3 (lbs): n/a
<i>kl/r Value</i> : * 200	Sway Brace Fitting: Universal Sway Brace, EG, 1 1/2" Pipe
Maximum Horizontal Load (lbs): 1310	Make: CADDY Model: CSB0150
	UL Load Rating (lbs): 1000 Adjusted Per 18.5.2.3 (lbs): 707
Fastener Information	
Fastener Orientation: E	
Structure: Wood - Lag Screw	
Fastener Qty: 1	
Fastener Type: Lag Screw	
Fastener Size: 1/2" x 4 1/2"	
Fastener Embedment: 4 1/2"	
Fastener Max. Load (lbs): 400	
Brace Orientation: Longitudinal	
Brace I.D. (on plan): B11	

Sprinkler System Zone of Influence (ZOI) Load Calculation ($F_{pw} = C_p \times W_p$)

Pipe Size	Pipe Description	Wt/ft (lbs)	15% for Fittings	Total Wt/ft	Length (ft)	Total Wt	Cp = 0.61 per NFPA 13 2019 2018 IBC
1 1/2"	Sch 10	3.00	0.45	3.45	80.00	276.00	
							Sway Brace Attached to 1 1/2" Sch10 Pipe
							Horizontal Earthquake Load $F_{pw} = C_p \times W_p$ $F_{pw} = 0.61 \times 276.00$ $F_{pw} = 168.00$ lbs
Weight of Misc. ZOI Valves and Fittings						0.00	
Total Zone of Influence (ZOI) Weight (W_p)						276.00	

*Excludes tension-only bracing systems



IMPORTANT: READ CAREFULLY

Your use of the nVent CADDY® Bracing Systems Calculator (the “Calculator”) is subject to the Terms of Use (the “Agreement”) you accepted prior to your use of the Calculator software. Subject to the terms and conditions of the Agreement, nVent grants to you a nonexclusive, nontransferable license to use this software on only one computer at any one time. You may not copy, alter, decompile, disassemble, reverse engineer, sublicense, rent, lease, sell, loan, assign or otherwise distribute the software. nVent may terminate this Agreement and your license grant if you fail to comply with the terms and conditions of this Agreement, in which event you must destroy all copies of the software and your rights to use this software will immediately end.

This Calculator and other materials are provided as a design aid for use by qualified persons who take full responsibility for the design of seismic and other bracing systems. The Calculator is based on the parameters and the criteria specified in the applicable fire sprinkler codes, effective as of the date of software release, you select. You assume sole responsibility to review and confirm the accuracy and correctness of the formula, the accuracy, completeness and currentness of the applicable fire sprinkler codes, the information used in the calculations and all results from the calculations. nVent is not responsible to perform these actions for you. To assist you in checking your work, hard copies of the calculations can be printed for your review and acceptance. Failure by you to review the calculations to your satisfaction may result in improper design specifications that could adversely affect the integrity of the bracing system being designed and built. nVent shall not be responsible for, among other things and all things whatsoever, (a) errors in, and your failure to review and assure the correctness of, the Calculator’s formula, information, calculations or results; (b) modifications in the Calculator made by any person other than nVent; (c) the effect on the user’s computer hardware, software or systems; (d) providing future updates to the Calculator regardless of possible changes to existing codes; or (e) otherwise.

THE CALCULATOR AND OTHER MATERIALS, INFORMATION, SOFTWARE, PRODUCTS, SERVICES AND OTHER CONTENT CONTAINED IN THIS SOFTWARE OR PROGRAM ARE PROVIDED TO YOU "AS IS" AND WITHOUT REPRESENTATIONS, WARRANTIES OR CONDITIONS OF ANY KIND, WHETHER EXPRESS OR IMPLIED, INCLUDING, BUT NOT LIMITED TO, THE IMPLIED WARRANTIES OR CONDITIONS OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE, TITLE, NONINFRINGEMENT, SECURITY, CURRENTNESS OR ACCURACY. NVENT HAS MADE REASONABLE EFFORTS TO PROVIDE INFORMATION THAT IS CURRENT AND ACCURATE AS OF THE SOFTWARE RELEASE DATE ON THIS SOFTWARE OR PROGRAM, HOWEVER, NVENT ASSUMES NO RESPONSIBILITY FOR ANY ERRORS, OMISSIONS OR INACCURACIES WHATSOEVER. UNDER NO CIRCUMSTANCES WILL NVENT, ITS SUBSIDIARIES AND AFFILIATES, AND ITS OR THEIR OFFICERS, DIRECTORS, EMPLOYEES AND REPRESENTATIVES, BE LIABLE FOR ANY LOSS OR DAMAGE CAUSED BY YOUR USE OF THE SOFTWARE OR PROGRAM OR YOUR RELIANCE ON INFORMATION OBTAINED THROUGH THIS SOFTWARE, PROGRAM, MATERIALS, INFORMATION, SERVICES AND OTHER CONTENT. IT IS YOUR RESPONSIBILITY TO EVALUATE THE ACCURACY, COMPLETENESS, CURRENTNESS AND USEFULNESS OF ANY INFORMATION PROVIDED, AND USE OF THIS SOFTWARE OR PROGRAM IS SOLELY AT YOUR OWN RISK.

IN NO EVENT SHALL NVENT BE LIABLE FOR ANY SPECIAL, INCIDENTAL, DIRECT, INDIRECT, PUNITIVE OR CONSEQUENTIAL DAMAGES OF ANY KIND, OR ANY DAMAGES WHATSOEVER, WHETHER IN CONTRACT, TORT, STRICT LIABILITY OR OTHERWISE (INCLUDING, WITHOUT LIMITATION, THOSE RESULTING FROM (I) RELIANCE ON THE SOFTWARE, PROGRAM OR MATERIALS PROVIDED, (II) COSTS OF REPLACEMENT GOODS, (III) LOSS OF USE, DATA OR PROFITS, (IV) DELAYS OR BUSINESS INTERRUPTIONS, AND (V) ANY OTHER THEORY OF LIABILITY), ARISING OUT OF OR IN CONNECTION WITH THE USE OF, OR INABILITY TO USE THE CALCULATOR, WHETHER OR NOT NVENT HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES.

Upon reasonable request by nVent, you agree to defend, indemnify, and hold harmless nVent and its employees, contractors, officers and directors from any and all liabilities, losses, claims and expenses, including reasonable attorneys’ fees, that arise from your use or misuse of this Calculator, information, products, software, materials or program and/or any nVent services, your non-compliance or compliance with these Terms of Use, or your violation of any third-party rights. nVent reserves the right, at its own expense, to assume the exclusive defense and control of any matter otherwise subject to indemnification by you, in which event you will cooperate with nVent in asserting any available defenses.

Neither you nor anyone acting on your behalf, including your employees, acquire any intellectual property or other proprietary rights, including patents, designs, trademarks, copyright or trade secrets, relating to the Calculator, software, programs and materials, except as otherwise expressly granted herein. Any rights not expressly granted herein are reserved.

You agree to comply with all applicable laws, regulations, orders and rules, including those related to export of this software, programs or materials. Your use of other nVent products must be in accordance with the nVent documentation applicable to such products including instruction sheets, data sheets, warnings, application drawings and user manuals.

nVent CADDY, nVent ERICO, nVent ERIFLEX, and nVent LENTON are either registered trademarks or trademarks of nVent in the U.S. and/or other countries.

All contents of the software, program and other materials are © 2018 nVent. All rights reserved.



© 2018 nVent All rights reserved

nVent, nVent CADDY, nVent ERICO, nVent ERIFLEX, and nVent LENTON are owned by nVent or its global affiliates. All other trademarks are the property of their respective owners. nVent reserves the right to change specifications without prior notice.