



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Apr 27, 2026 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRMU20240285

Property Address: 206 27TH AVE SE, BLDG H, PUYALLUP, WA 98374

Contractor: RUSH COMMERCIAL CONSTRUCTION INC 6622 WOLLOCHET DR NW
GIG HARBOR, WA 98335-8325

To construct: SUBMITTED AS BLDG B - BRADLEY HEIGHTS APARTMENTS - ISSUED AS
206 27TH AVE SE, BLDG H

On this day we have inspected your construction for **Firewall/Firestop Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Building B behind tub/shower fire caulking approved.

Corrections:

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org



James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590