



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Apr 27, 2026

Inspection Result: NOT READY

Permit Number: PRRNTH20250333

Property Address: 1200 7TH AVE SE, PUYALLUP, WA 98372;

Contractor:

To construct: CONSTRUCT (3) TOWNHOUSE DWELLING UNITS (BLDG B)~ 1200 7th AVE TOWNHOUSES

On this day we have inspected your construction for **Energy (Insulation) Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

1. Dens glass not complete at time of inspection. 10:30am
2. Asked contractor to please call-in drywall inspection for next dens glass inspection.
- 2 1 ; complete slab insulation as per city approved plans at mechanical room slab

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684