



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Apr 29, 2026

Inspection Result: **PARTIAL PASS**

Permit Number: PRMU20240285

Property Address: 206 27TH AVE SE, BLDG H, PUYALLUP, WA 98374

Contractor: RUSH COMMERCIAL CONSTRUCTION INC 6622 WOLLOCHET DR NW
GIG HARBOR, WA 98335-8325

To construct: SUBMITTED AS BLDG B - BRADLEY HEIGHTS APARTMENTS - ISSUED AS
206 27TH AVE SE, BLDG H

On this day we have inspected your construction for **Energy (Insulation) Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Energy behind tub/showers approved. Unit 101 unfinished hold down behind tub/shower do not sheetrock till inspected.

Corrections:

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org



James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590