


LIGHTING COMPLIANCE SUMMARY

2021 WSEC Compliance Forms for Commercial Buildings including Group R2, R3 & R4 over 3 stories and all R1

Administered by: ©2026 NEEA, All rights reserved

Project & Applicant Information 	Project Title	Centeris L2 Expansion (Row D) - 2021 WSEC	For Building Department Use: PRCTI20260575	Date: May 05, 2026
	Project Address	1019 39th Avenue SE Puyallup, WA 98374		
	Applicant Name	Adam Lyons		
	Applicant Phone	206-494-5089		
	Applicant Email	adam.lyons@stantec.com		
For questions about this report, contact WSEC Commercial Technical Support at 360-539-5300 or via email at com.techsupport@waenergycodes.com				

General Occupancy	All Commercial		General Building Use Type	Technology, Data Center	Building Cond. Floor Area	2,500
General Project Types	Alteration	New Building or Addition Lighting Scope	Alteration Lighting Scope	Interior Lighting	Project Cond. Floor Area	2,500
					Floors Above Grade	3
					Compliance Method	General Prescriptive
Lighting Project Description						

Lighting Compliance Scope and Method	Project Type	Interior / Exterior (Interior includes both interior & parking)	Luminaire Replacement Scope	Compliance Method	LPA Calculation Adjustment	Compliance Verification
	Alteration	Interior Lighting	20% or more replaced	Space by space	No Calculation Adjustments allowed	COMPLIES
Additional Energy Efficiency (AEC) Measures Included	No lighting or electrical additional energy efficiency measures included in project		Load Management (LDM) Measures Included		No lighting or electrical load management measures included in project	

Project Title	Centeris L2 Expansion (Row D) - 2021 WSEC	Date	May 05, 2026	
Lighting Power Calculation	ALTERATION - INTERIOR LIGHTING (20% or more replaced)		Compliance Verification	COMPLIES
Compliance Method	Space by space	LPA Calculation Adjustment	none	

Interior Lighting Power Allowance - Space by Space						
General Space Type	Specific Space Type	Gross Interior Area (SF)	LPA (Watts/SF)	Total Watts Allowed (SF x LPA x 1)	Total Proposed Watts (LPD + Display LPD)	Compliance Status
Computer room/data center	General	2,423	0.94	2,278		
Proposed Total LPD					1,800	
Totals				2,278	1,800	COMPLIES

Proposed Lighting Power Density						
Fixture Type	Fixture ID	Quantity of Fixtures (#F)	Watts or Wattage Limit per Fixture (WpF)	Total Linear Feet (LF)	Watts per Linear Foot (WpLF)	Total Watts Proposed (#F x WpF) or (LF x WpLF)
Individual Fixtures						
Direct / indirect pendant	L1	30	60			1,800
Proposed Total LPD						1,800

Project Title	Centeris L2 Expansion (Row D) - 2021 WSEC	Date	May 05, 2026	
Proposed Fixtures Details	ALTERATION - INTERIOR LIGHTING (20% or more replaced)			
Fixture Type/Application	Fixture ID	Location in Documents	Lamp Type	New or Existing-to-Remain
Individual Fixtures				
Direct / indirect pendant	L1	A-105-27	LED	New

	Fixture Description: Linear Pendant Light	Are these fixtures located within a daylight zone?: No
	Do these fixtures require specific application lighting controls?: None required	