



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** May 19, 2026                      **Inspection Result:**     **NOT READY**

**Permit Number:** PRCTI20250853

**Property Address:** 4102 S MERIDIAN, Unit: E5, PUYALLUP, WA 98373; 4102 S MERIDIAN, Unit: D, PUYALLUP, WA 98373;

**Contractor:** Leibo Brothers Management LLC 700 State Street New Haven, CT 06511 (203) 456-4465

**To construct:** Tenant Fit-up within an existing demised tenant space. Demise work occurred as part of previous work by landlord. Level II Alteration (<50% of building). Planet Fitness (A-3) will occupy the space. Exterior facade improvement is to be performed by others, under separate permit and review. This permit is for the interior fit-up only. - PLANET FITNESS

On this day we have inspected your construction for **Sanitary Sewer Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** See corrections.

**Corrections:**

- 1 1. Need to see building connection prior to backfill.
2. Install a cap and adaptor on the c/o's.
3. Install an 8" sleeve around the 2 c/o's. (this will sit inside the casting flange)
4. Set the "SEWER" c/o casting on the sleeve prior to pouring the concrete walk .

Sincerely,



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Jason Little

Development Engineering Inspector

[JLittle@PuyallupWA.gov](mailto:JLittle@PuyallupWA.gov)

(253) 244-0387