



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

May 13, 2026

JMJ TEAM

905 MAIN STREET , SUITE 200

SUMNER, WA 98390

permitting@jmjteam.com

RE: Alternative Methods/Materials Request (AMR) Determination

Dear MJM TEAM,

The City of Puyallup reviewed the following AMR permit application:

Permit Application Number: PRAMR20260675

Project Name: Marcoe's Building Relocation

Corresponding Development Permit Number: PRCCP20260217

Applicant's AMR Description: The Fair is requesting deviation for private infrastructure from the City standards for the construction of Marcoe's candy building; please also refer to permit #PRCCP20260217. Work includes reconnecting utility services such as water, sewer, power, and gas to the new prefabricated building.

The AMR is hereby **approved** with the following conditions:

- Encase pipes or use DI where less than 3 feet of cover is unable to be achieved. Pipes shall still have a minimum 1 foot of cover.
Encase pipes where 10 foot building separation is unable to be achieved. Pipes shall meet a minimum 5 feet of separation to allow for maintenance.
- Inspect existing sewer lateral to confirm it is in a serviceable condition.
- Provide sewer pipe flow calculations showing minimum design velocities are a minimum 2 fps flowing full.

It is the applicant's responsibility to submit this AMR approval letter with the corresponding development permit application to evaluate during design review. This letter is also available to download directly from the online permitting portal under the Documents & Images section.

If you have any questions regarding this decision, or would like to further discuss your request, please contact me directly.

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Kenneth Cook
Development Engineering Manager
KCook@PuyallupWA.gov
(253) 864-4177