



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 22, 2026

Inspection Result: NOT READY

Permit Number: PRRNTH20250333

Property Address: 1200 7TH AVE SE, PUYALLUP, WA 98372;

Contractor:

To construct: CONSTRUCT (3) TOWNHOUSE DWELLING UNITS (BLDG B)~ 1200 7th AVE TOWNHOUSES

On this day we have inspected your construction for **Plumbing Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Discussed with contractor about moving plumbing Water-main location, and providing hub drain for heat pump Water heaters versus floor drain. Plumbing not on test and not done as of yet.

Corrections:

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org



James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590