



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 26, 2026 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRFUP20250685

Property Address: 3500 S MERIDIAN, Unit: 115, PUYALLUP, WA 98373;

Contractor: MASTEC NORTH AMERICA INC 806 Douglas Rd #1100 Coral Gables, FL 33134

To construct: JB0002054752 OSP DE - Comcast proposes to overlash 48ct fiber, proof and pull 48ct fiber thru conduit and riser, bore and place 2" hdpe sch, 40 conduits w/ 48ct fiber, overset proposed 24"x36" vault, repair and restore sidewalk and landscape bore pit, tie into existing aerial , and underground splice cases

On this day we have inspected your construction for **Comment Engineering Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Restoration for core drill is pending: Either CDF per city standard detail 01.01.20 or full depth street patch as laid out. The temporary patch shows significant settling.

Note: Full depth patch may require additional lane closure. Confirm that approved TCPs will fit the work zone.

Corrections:

Sincerely,

Cheryl Trimble
Engineer Technician III



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

CTrimble@PuyallupWA.gov

(253) 290-9834