



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** May 28, 2026                      **Inspection Result:**     **PARTIAL PASS**

**Permit Number:** PRCTI20260575

**Property Address:** 1023 39TH AVE SE, PUYALLUP, WA 98374;

**Contractor:** HOWARD S WRIGHT 415 1ST AVE N SEATTLE, WA 98109

**To construct:** Construct interior 2,424 s.f. expansion of existing server room. -  
CENTERIS, DATA CENTER

On this day we have inspected your construction for **Foundation/Rebar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Rebar inspection for Lv3 HK Pad for New Air Handler #20. 17'-8"L x 8'w x 9'H progressing with special inspection.

**Corrections:**

Sincerely,

Shannon King  
Building Inspector 2  
ShannonK@PuyallupWA.gov  
(253) 840-6684