



# AMEREX KP FIRE SUPPRESSION SYSTEM

U.L. 300 Listed

## NOZZLE BRANCH LINE LIMITATIONS:

ALL PIPE AND FITTINGS LEADING FROM THE SUPPLY BRANCH TEE TO A SYSTEM NOZZLE.

CYLINDER FLOW POINTS	PIPE SIZE	TOTAL LINEAR FEET OF PIPE	MAX. QTY. TEES	MAX. QTY. ELBOWS	MAX. QTY. BUSHINGS
KP275 = 8	3/8	32	5	10	0
KP375 = 11	3/8 OR 1/2	32	8	12	11
KP600 = 18	3/8	32	11	32	15
2-KP375 = 22	3/8	32	32	32	20
<b>MAX. PER NOZZLE BRANCH</b>		<b>7</b>	<b>3</b>	<b>6</b>	<b>4</b>

City of Puyallup  
Development & Permitting Services  
**ISSUED PERMIT**

Building	Planning
Engineering	Public Works
Fire	Traffic

K CLASS EXTINGUISHER REQUIRED  
 PENINSULA FIRE INC  
 371 LINDVIG WAY NW SUITE 107  
 POU LSBO WA 98370

LIC. # PENINF012B8

<b>AMEREX CORPORATION</b>	
<b>DRAWN</b>	<b>DATE</b>
Marcoc Candy Company	0000-0000
110 9th Ave S.W.	
Puyallup, WA 98371	
<b>SCALE</b>	<b>REV</b>
1/4"=1'	
	<b>SHEET 1 OF 1</b>