




 Expires DEC 31, 26	WASHINGTON STATE CERTIFICATE OF COMPETENCY FIRE SPRINKLER SYSTEMS
Derek Strickland 3408-0225-C Level 3 Patriot Fire Protection, Inc. PATRIFP099CF	
	06/16/2026
Signature	Date

PATRIOT FIRE PROTECTION
2707 70TH AVE. EAST
TACOMA, WA 98424
253-284-3449


Job Name : Centeris L2 Expansion
Drawing :
Location : 1023 39TH AVE SE PUYALLUP, WA 98374
Remote Area : L2 ROW D
Contract : 18-0181
Data File : Centeris L2 Expansion Area L2 DDC.WXF
Date/Time : 06/16/2026 - 11:04 PM

Water Supply Curve

PATRIOT FIRE PROTECTION
Centeris L2 Expansion

City Water Supply:
C1 - Static Pressure : 74
C2 - Residual Pressure: 67
C2 - Residual Flow : 2742

Demand:
D1 - Elevation : 8.432
D2 - System Flow : 327.949
D2 - System Pressure : 55.819
Hose (Demand) : 250
D3 - System Demand : 577.949
Safety Margin : 17.788



Fittings Used Summary

PATRIOT FIRE PROTECTION
Centeris L2 Expansion

Page 2
Date

Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
D	Dry Valve Rel FX						10	11.4	13.2		23.5		37								
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Ziw	Wilkins 350AST	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

PATRIOT FIRE PROTECTION
Centeris L2 Expansion

Page 3
Date

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
SRC	74.0	67	2742.0	73.607	577.95	55.819

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>	
A1	517.47	5.6	7.17	15.0	0.15	100
A2	517.42	5.6	7.32	15.15	0.15	100
A3	517.37	5.6	7.79	15.63	0.15	100
A4	517.33	5.6	8.77	16.58	0.15	100
A5	517.28	5.6	10.51	18.15	0.15	100
A6	517.23	5.6	13.27	20.4	0.15	100
A10	517.49	5.6	7.32	15.15	0.15	100
A11	517.44	5.6	7.47	15.31	0.15	100
A12	517.39	5.6	7.95	15.79	0.15	100
A13	517.34	5.6	8.95	16.76	0.15	100
A14	517.29	5.6	10.72	18.33	0.15	100
A15	517.25	5.6	13.54	20.6	0.15	100
A9	517.35	5.6	13.3	20.42	0.15	100
A8	517.3	5.6	13.53	20.6	0.15	100
A7	517.25	5.6	14.35	21.21	0.15	100
21	517.22		16.75			
22	517.24		17.09			
23	521.07		29.39			
24	519.61		35.36			
TOR	500.76		46.34			
BOR	484.34		55.13			
12	482.56		57.36			
FLG	481.0		58.11			
SRC	498.0		55.82	250.0		
A18	517.37	5.6	13.57	20.63	0.15	100
A17	517.32	5.6	13.81	20.81	0.15	100
A16	517.27	5.6	14.64	21.42	0.15	100

Final Calculations : Hazen-Williams

PATRIOT FIRE PROTECTION
Centeris L2 Expansion

Page 4
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
A1 to A2	517.47 517.42	5.60	15.00 15.0	1.5 1.682		11.420 11.420	100 0.0107	7.175 0.022 0.122		Vel = 2.17	
A2 to A3	517.42 517.37	5.60	15.15 30.15	1.5 1.682		11.420 11.420	100 0.0391	7.319 0.022 0.446		Vel = 4.35	
A3 to A4	517.37 517.33	5.60	15.63 45.78	1.5 1.682		11.420 11.420	100 0.0847	7.787 0.017 0.967		Vel = 6.61	
A4 to A5	517.33 517.28	5.60	16.58 62.36	1.5 1.682		11.420 11.420	100 0.1499	8.771 0.022 1.712		Vel = 9.00	
A5 to A6	517.28 517.23	5.60	18.15 80.51	1.5 1.682		11.420 11.420	100 0.2405	10.505 0.022 2.747		Vel = 11.62	
A6 to 21	517.23 517.22	5.60	20.41 100.92	1.5 1.682	T 7.065	2.440 7.066 9.506	100 0.3653	13.274 0.004 3.473		Vel = 14.57	
21			0.0 100.92					16.751		K Factor = 24.66	
A10 to A11	517.49 517.44	5.60	15.15 15.15	1.5 1.682		11.420 11.420	100 0.0109	7.323 0.022 0.125		Vel = 2.19	
A11 to A12	517.44 517.39	5.60	15.31 30.46	1.5 1.682		11.420 11.420	100 0.0398	7.470 0.022 0.454		Vel = 4.40	
A12 to A13	517.39 517.34	5.60	15.79 46.25	1.5 1.682		11.420 11.420	100 0.0863	7.946 0.022 0.985		Vel = 6.68	
A13 to A14	517.34 517.29	5.60	16.75 63.0	1.5 1.682		11.420 11.420	100 0.1528	8.953 0.022 1.745		Vel = 9.10	
A14 to A15	517.29 517.25	5.60	18.34 81.34	1.5 1.682		11.420 11.420	100 0.2451	10.720 0.017 2.799		Vel = 11.74	
A15 to 22	517.25 517.24	5.60	20.60 101.94	1.5 1.682	T 7.065	2.460 7.066 9.526	100 0.3722	13.536 0.004 3.546		Vel = 14.72	
22			0.0 101.94					17.086		K Factor = 24.66	
A9 to A8	517.35 517.3	5.60	20.42 20.42	1.5 1.682		11.420 11.420	100 0.0190	13.296 0.022 0.217		Vel = 2.95	
A8 to A7	517.3 517.25	5.60	20.60 41.02	1.5 1.682		11.420 11.420	100 0.0691	13.535 0.022 0.789		Vel = 5.92	
A7 to 21	517.25 517.22	5.60	21.21 62.23	1.5 1.682	T 7.065	8.950 7.066 16.016	100 0.1494	14.346 0.013 2.392		Vel = 8.99	

Final Calculations : Hazen-Williams

PATRIOT FIRE PROTECTION
Centeris L2 Expansion

Page 5
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
21 to 22	517.22 517.24		100.92 163.15	3 3.26			9.710 9.710	100 0.0354	16.751 -0.009 0.344		Vel = 6.27	
22 to 23	517.24 521.07		164.80 327.95	3 3.26	3E T	20.143 14.388	73.830 34.530 108.360	100 0.1288	17.086 -1.659 13.960		Vel = 12.61	
23 to 24	521.07 519.610		0.0 327.95	4 4.26	T 4E	18.795 37.589	96.250 56.384 152.634	100 0.0350	29.387 0.632 5.344		Vel = 7.38	
24 to TOR	519.610 500.76		0.0 327.95	4 4.26	2E	18.795	61.510 18.795 80.305	100 0.0350	35.363 8.164 2.811		Vel = 7.38	
TOR to BOR	500.76 484.34		0.0 327.95	4 4.26	E D	9.397 22.084	16.420 31.481 47.901	100 0.0350	46.338 7.112 1.676		Vel = 7.38	
BOR to 12	484.34 482.56		0.0 327.95	4 4.26	B T E	15.8 26.334 13.167	3.380 55.301 58.681	120 0.0250	55.126 0.771 1.466		Vel = 7.38	
12 to FLG	482.56 481		0.0 327.95	6 6.357	E	17.603	1.560 17.603 19.163	120 0.0035	57.363 0.676 0.068		Vel = 3.32	
FLG to SRC	481 498		0.0 327.95	8 8.27	E 2G Ziw	28.468 12.652 0.0	217.730 41.120 258.850	140 0.0007	58.107 -2.480 0.192		** Fixed Loss = 4.882 Vel = 1.96	
SRC			250.00 577.95						55.819		Qa = 250.00 K Factor = 77.36	
A18 to A17	517.37 517.32	5.60	20.63 20.63	1.5 1.682			11.420 11.420	100 0.0194	13.567 0.022 0.221		Vel = 2.98	
A17 to A16	517.32 517.27	5.60	20.81 41.44	1.5 1.682			11.420 11.420	100 0.0704	13.810 0.022 0.804		Vel = 5.98	
A16 to 22	517.27 517.24	5.60	21.42 62.86	1.5 1.682	T	7.065	8.950 7.066 16.016	100 0.1522	14.636 0.013 2.437		Vel = 9.08	
22			0.0 62.86						17.086		K Factor = 15.21	