



Any public facilities, i.e. utilities, curb, gutter, driveway approach, curb ramp, sidewalk, etc., broken now or during the course of construction shall be removed and replaced to current City Standard. Restoration limits and requirements shall be at the discretion of the City.

City of Puyallup
Development & Permitting Services
ISSUED PERMIT

Building	Planning
Engineering	Public Works
Fire	Traffic

The City of Puyallup does not review, authorize, inspect, or permit utility work on private property or areas outside Puyallup's jurisdictional authority.




3-800

TRANSFORMER REMOVAL	
Installed at site:	P01
Grid Number:	568024-156391
kVA Rating:	25kVA 120/240v
Material ID#:	6211250
Foreman to redline the following information	
Company ID#:	_____
Primary phase connected to:	_____
Tested Secondary Voltage	_____ / _____

Location		Usage	Wire Size & Type	Quantity of wires	Length (per wire)	Total
From	To					
P01	M01	SVC	SEC 4/0 OH TPX	1		1

FOREMAN (CHECK BOX WHEN COMPLETED)	
☐	PSE Equipment <u>LOCKED/SECURED</u> & Work Area <u>left in CLEAN/SAFE</u> Condition. Grid, Cable, and Surface numbers <u>INSTALLED & VERIFIED</u> .
☐	Field Changes <u>REDUCED</u> on As-Built.
☐	Material <u>VERIFIED</u> and <u>CHANGES</u> noted on Paperwork. Total <u>PRIMARY</u> Cable noted on As-Built.
☐	Company <u>WIRING</u> recorded in correct location on As-Built.
☐	Indicate correct <u>FUSE SIZE</u> on As-Built & <u>VERIFY</u> proper <u>PHASE</u> .
☐	Deviations noted on the As-Built and their reason.
☐	I certify that the work performed meets PSE's standards and procedures and that all quality requirements are met.
Foreman's Signature _____	
Print Name _____	Date _____



Owner / Developer Contact Info

ASH DEVELOPMENT
1001 SHAW ROAD
PUYALLUP, WA 98372
ATTN: GREG HELLE

253-606-6799 office

For contacts below dial 1-888-CALL PSE (225-5773)

Project Manager Contact Information:
Manager: Samantha Gese
Cell Phone: 253-259-0987
E-Mail: Samantha.Gese@pse.com

Developer Locates Req'd	No
PSE Locates Req'd	No
Outages Req'd	No
Flagging Req'd	Yes

3						FUNCTION	CONTACT	PHONE NO	DATE
2						PROJECT MGR	S.Gese	253-259-0987	05/15/24
1						ENGR - POWER	T.THORNHILL	253-904-7813	05/16/24
REV#	DATE	BY	DESCRIPTION			ENGR - GAS			
COUNTY		Emer Sect	Gas Wk Ctr	POWER WK CTR	DRAWN BY	T.THORNHILL	253-904-7813	05/16/24	
PERCE				QSWPRE	CHECKED BY	J.Welch		05/30/24	
1/4 Sec		OP MAP		PLAT MAP	APPROVED BY	D.Rickett	N/A	6/12/24	
SE4, Sect 26,T20,R04					FOREMAN #1				
U-MAP NO (POWER)		OH CKT MAP	UG CKT MAP	CIRCUIT NO	FOREMAN #2				
2004E104		2004E104	2004E104	GAR-16	MAPPING				

JOINT FACILITIES ARRANGEMENTS					
UTILITIES					
CONTACT					
PHONE#					
 PUGET SOUND ENERGY	EAST TOWN CROSSING CMRCL SPACES		AUD		
	INSTALL 1Ø OH TEMP XFMR			INCIDENT	MAOP
	727 SHAW RD			Gas Order	Elect Order
	POYALL, WA 98372			SCALE	PAGE
DESIGNED BY PSE			AS NOTED	1 of 1	