



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 29, 2026

Inspection Result: **PARTIAL PASS**

Permit Number: PRCTI20250548

Property Address: 401 15TH AVE SE, PUYALLUP, WA 98372;

Contractor: ABBOTT CONSTRUCTION 3408 1ST AVENUE SOUTH SEATTLE, WA 98134

To construct: This Tenant Improvement on Level 1 of the Good Samaritan Hospital Campus will expand the existing Nutrition Department in order to support the future Patient Care Tower expansion (WA DOH Certificate of Need 1980). Project will be reviewed by WA DOH under CRS# 61682265. Due to hospital requirements for continuous operation, this project is planned for construction in multiple phases in order to maintain Food Service and Dining operations for the hospital. Phase 1 will create new Storage, Ware wash, Cooking, and Office spaces to serve multiple departments. Scope also includes new infrastructure needed to support this added capacity. - MULTICARE GOOD SAMARITAN HOSPITAL KITCHEN PHASE 1 - REVISION (1) - RELOCATE MEDICAL GAS TO ALLOW FOR CONTINUED CONSTRUCTION

On this day, we have inspected your construction for **Plumbing Below Slab Inspection** and we find the following result of the inspection. If you have any questions, please contact the inspector below.

Comments: approved as noted on city approved plans.

Corrections:

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Shannon King

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684