



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jul 08, 2026

Inspection Result: **NOT READY**

Permit Number: PRCTI20250853

Property Address: 4102 S MERIDIAN, Unit: E5, PUYALLUP, WA 98373; 4102 S MERIDIAN, Unit: D, PUYALLUP, WA 98373;

Contractor: Leibo Brothers Management LLC 700 State Street New Haven, CT 06511 (203) 456-4465

To construct: Tenant Fit-up within an existing demised tenant space. Demise work occurred as part of previous work by landlord. Level II Alteration (<50% of building). Planet Fitness (A-3) will occupy the space. Exterior facade improvement is to be performed by others, under separate permit and review. This permit is for the interior fit-up only. - PLANET FITNESS

On this day, we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If you have any questions, please contact the inspector below.

Comments:

1. Provide bracing at bridging locations.
2. Provide drywall attachment at ductwork penetration upper southwest wall.
3. Provide header detail at doorway into locker room.
4. Provide wall detail at wall splicing at ductwork Southeast section of upper wall.
5. Complete bridging at Southeast corner of South facing wall.
6. Complete cross bracing on two hallway walls running north south from entry doorway

Corrections:

- 1 1. Provide bracing at bridging locations.
2. Provide drywall attachment at ductwork penetration upper southwest wall.
3. Provide header detail at doorway into locker room.
4. Provide wall detail at wall splicing at ductwork Southeast section of upper wall.
5. Complete bridging at Southeast corner of South facing wall.
6. Complete cross bracing on two hallway walls running north south from entry doorway into locker room area.



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Sincerely,

James LaVergne

James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590