



CITY OF PUYALLUP
Development & Permitting Services
333 S. Meridian, Puyallup, WA 98371
(253) 864-4165
www.cityofpuyallup.org

Permit No:
PRFS20260832

FIRE SPRINKLERS

Puyallup, WA

Job Address	Address: 3500 S MERIDIAN, Unit: 115, PUYALLUP, WA 98373 Parcel # 6021010051	ISSUED July 09, 2026
Owner CAFARO NORTHWEST PARTNERSHIP PO BOX 2227 YOUNGSTOWN, OH 44504		
Applicant farhang 25919 140 th ave se Kent, WA 98042 franksourish@yahoo.com		
Contractor FRANK FIRE PROTECTION 25919 140TH AVE SE KENT, WA 98042 WA L&I #:		
Description of Work new ul 300 fire system to hood - CLUCK AND STACK, UNIT 8008		
Permit Types	Fire Sprinklers	
Expiration Date: January 05, 2027		
Total ESU's		
REQUESTING REQUIRED INSPECTIONS A list of required inspections can be found on the permitting portal. Log in to your portal account, click on my items, and expand My Building Permit application, My Engineering Permit application, or My Fire Permit application depending on your permit type. Then locate your permit number and click on "request inspection". This will pull up a list of inspection types associated with your permit. Click on the desired inspection type and then click Next Step to begin the inspection request process.		

Building Components:

Quantity	Units	Description
1	QTY	Fire Suppression System other than Sprinklers
		Total Value of Work: \$0.00

Standard Conditions:

- Comply with 2021 IFC and IBC
 - Provide plans and permit on site for inspection.
 - Provide k-fire extinguishers according to IFC 904.11.5.
 - Hook to fire alarm system or provide audio or visual indication of system discharge. IFC 904.3.4
 - Provide manual activation in path of egress no closer than 10' nor no more than 20' from hood. IFC 904.11.1
- Schedule your inspection online through the city of puyallup online permit system. This is a request for inspection only. A date and time will be selected by Inspector depending on availability. Call morning of inspection between 7am - 8am for scheduled date and time. Fire Inspections are Monday - Thursday there will be no inspections on Fridays.
David Drake 253-864-4171 ddrake@puyallupwa.gov

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

Conditions

The items listed in the table below are outstanding conditions that need to be resolved prior to occupancy and/or final inspection.

Condition Category	Condition	Department	Condition Status
Standard Conditions	• Comply with 2021 IFC and IBC • Provide plans and permit on site for inspection. • Provide k-fire extinguishers according to IFC 904.11.5. • Hook to fire alarm system or provide audio or visual indication of system discharge. IFC 904.3.4 • Provide manual activation in path of egress no closer than 10' nor no more than 20' from hood. IFC 904.11.1 Schedule your inspection online through the city of puyallup online permit system. This is a request for inspection only. A date and time will be selected by Inspector depending on availability. Call morning of inspection between 7am - 8am for scheduled date and time. Fire Inspections are Monday - Thursday there will be no inspections on Fridays. David Drake 253-864-4171 ddrake@puyallupwa.gov		Open

I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.

Applicant:
farhang