

SANITARY SEWER

Plumbing Fixture Plan Review

System Development Charge Calculation Sheet Based on Fixture Unit Weight (FUW)

Appliances, Appurtenances or Fixtures	No Change to Existing Fixture	Existing Fixture Relocated or Replaced	Existing Fixture Removed Not Replaced	New Fixture Added Not a Replacement	FUW Count For Each Item	Total FUWs
Bathtub or combination bath/shower	X				2	
Bidet – 1 ¼"	X				1	
Bidet – 1 ½"	X				2	
Clothes washer, domestic, 2" standpipe	X				3	
Dental unit, cuspidor	X				1	
Dishwasher, domestic with independent drain	X				2	
Drinking fountain or water cooler – Private/Public	X				0.5	
Drinking fountain or water cooler – Assembly	X				1	
Floor drain (EMERGENCY SHOWER = 0 FUW)				1	0	
Food waste grinder – commercial	X				3	
Lavatory, (bathroom sink)	X				1	
Lavatory, (bathroom sink) sets of 2 or 3	X				2	
Pedicure basin	X				1	
Shower, single head	X				2	
Shower, multi-head each additional	X				1	
Wash fountain, 1 ½"	X				2	
Wash fountain, 2"	X				3	
SINKS						
Bar sink - Private	X				1	
Bar sink – Public/Assembly	X				2	
Clinic, 3" Public/Assembly	X				6	
Commercial, 1 ½" with food waste (SCIENCE SINKS)		1		10	3	30
Kitchen, domestic 1 ½" (with/without food waste grinder/dishwasher – Private/Public)	X				2	
Laundry, 1 ½"	X				2	
Service sink /Mop basin, 2"/3"	X				3	
Service sink, flushing rim 3"	X				6	
Wash, each set of faucets – Public/Assembly	X				2	
URINALS						
Urinal, 2" integral trap 1.0 GPF – Private/Public	X				2	
Urinal, 2" integral trap 1.0 GPF – Assembly	X				5	
Urinal, 2" integral trap greater than 1.0 GPF – Private/Public	X				2	
Urinal, 2" integral trap greater than 1.0 GPF – Assembly	X				6	
Urinal, 1 ½" exposed trap – Private/Public	X				2	
Urinal, 1 ½" exposed trap – Assembly	X				5	
WATER CLOSETS						
Water closet, 1.6 GPF Gravity tank / flushometer tank / flushometer valve – Private	X				3	
Water closet, 1.6 GPF Gravity tank / flushometer tank / flushometer valve – Public	X				4	
Water closet, 1.6 GPF Gravity tank / flushometer tank / flushometer valve – Assembly	X				6	
Water closet, <i>greater</i> than 1.6 GPF Gravity tank / flushometer valve – Private	X				4	
Water closet, <i>greater</i> than 1.6 GPF Gravity tank / flushometer valve – Public	X				6	
Water closet, <i>greater</i> than 1.6 GPF Gravity tank / flushometer valve – Assembly	X				8	
TOTALS						30

Contact Engineering Services for current System Development fee information

FORM PREPARED BY: Alma Castro DATE: 06/24/2026

TEL: 253.922.0446

EMAIL: adcastro@gftinc.com

**City of Puyallup
Development
Engineering
APPROVED**

See permit
conditions.

AHunt
07/15/2026
11:42:07 AM

