

WATER**Plumbing Fixture Plan Review****System Development Charge Calculation Sheet Based on Fixture Unit Weight (FUW)****All water systems shall have water hammer arrestors and shall be accessible - Sec: 609.10 UPC**

Appliances, Appurtenances or Fixtures	No Change to Existing Fixture	Existing Fixture Relocated or Replaced	Existing Fixture Removed Not Replaced	New Fixture Added Not a Replacement	FUW Count For Each Item	Total FUWs City to complete
Bathtub or combination bath/shower	X				4	
Bidet - Private	X				1	
Clothes washer	X				4	
Dental unit, cuspidor	X				1	
Dishwasher, domestic	X				1.5	
Drinking fountain or water cooler - Private/Public	X				0.5	
Drinking fountain or water cooler - Assembly	X				0.75	
Hose bib	X				2.5	
Hose bib, each additional	X				1	
Lavatory (bathroom sink)	X				1	
Pedicure basin	X				1	
Shower, per head (EMERGENCY SHOWER = 0 FUW)				1	0	
SINKS						
Bar sink - Private	X				1	
Bar sink - Public	X				2	
Clinic Faucet - Public	X				3	
Clinic flushometer valve with/without faucet - Public	X				8	
Kitchen, domestic (SCIENCE SINKS)		1		10	1.5	15
Laundry	X				1.5	
Service or mop basin - Private	X				1.5	
Service or mop basin - Public	X				3	
Wash-up, each set of faucets - Public	X				2	
Wash fountain, circular spray - Public	X				4	
URINALS						
Urinal, 1.0 GPF Flushometer valve - Public	X				4	
Urinal, 1.0 GPF Flushometer valve - Assembly	X				5	
Urinal, <i>greater</i> than 1.0 GPF Flushometer valve - Public	X				5	
Urinal, <i>greater</i> than 1.0 GPF Flushometer valve - Assembly	X				6	
Urinal, flush tank - Private or Public	X				2	
Urinal, flush tank - Assembly	X				3	
WATER CLOSETS						
Water closet, 1.6 GPF Gravity tank/Flushometer tank - Private/Public	X				2.5	
Water closet, 1.6 GPF Gravity tank/Flushometer tank - Assembly	X				3.5	
Water closet, 1.6 GPF Flushometer valve - Private/Public	X				2.5	
Water closet, 1.6 GPF Flushometer valve - Assembly	X				3.5	
Water closet, <i>greater</i> than 1.6 GPF Gravity tank - Private	X				3	
Water closet, <i>greater</i> than 1.6 GPF Gravity tank - Public	X				5.5	
Water closet, <i>greater</i> than 1.6 GPF Gravity tank - Assembly	X				7	
Water closet, <i>greater</i> than 1.6 GPF - Flushometer valve - Private	X				7	
Water closet, <i>greater</i> than 1.6 GPF - Flushometer valve - Public	X				8	
Water closet, <i>greater</i> than 1.6 GPF - Flushometer valve - Assembly	X				10	
TOTALS						15

Contact Engineering Services for current System Development fee information

FORM PREPARED BY: Alma Castro DATE: 06/24/2026

TEL: 253.922.0446

EMAIL: adcastro@gftinc.com

**City of Puyallup
Development
Engineering
APPROVED**

See permit conditions.

 AHunt
07/15/2026
11:42:16 AM
