



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jul 21, 2026

Inspection Result: **PASSED**

Permit Number: PRCTI20260049

Property Address: 3500 S MERIDIAN, Unit: 115, PUYALLUP, WA 98373;

Contractor: B&B HEATING & COOLING LLC 15405 87TH AVE E WV 98375 (253) 880-9005

To construct: Installation of a commercial kitchen exhaust hood and related mechanical components. Work includes hood installation, ductwork, exhaust fan, and fire suppression system as required. No structural changes. - CLUCK & STACK UNIT 8008

On this day, we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If you have any questions, please contact the inspector below.

Comments:

Corrections:

1. Provide makeup air balance report at next inspection.
2. Extend roof top plumbing vent 2' vertically above top of air intake.
3. Label rooftop units with mall space numbers.
4. Attach rooftop blocking 4x4 permanently to rooftop.

Sincerely,

Monty Johnson

Monty Johnson
Sr Building Inspector
Monty@PuyallupWA.gov
(253) 770-3326



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org