



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jul 24, 2026

Inspection Result: **FAILED**

Permit Number: PRROW20260770

Property Address: 941 S MERIDIAN, PUYALLUP, WA 98371; 427 N MERIDIAN, PUYALLUP, WA 98371;

Contractor: HOLT SERVICES INC 10621 TODD RD E PUYALLUP, WA 98372

To construct: The scope of this work is to complete two geotechnical borings and shallow utility potholes as part of the Downtown Puyallup Gateway and Wayfinding Signage project.

On this day, we have inspected your construction for **Comment Engineering Div Inspection** and we find the following result of the inspection. If you have any questions, please contact the inspector below.

Comments: See corrections. Please let me know when all work has been completed for permit close out.

All other restoration looks awesome, Thank you.

Corrections:

- 1 1. Utility pothole in the left SB lane needs to be sealed. (North Meridian)
2. Remove cones from sidewalk east and west on S. Meridian.

Sincerely,

Jason Little

Jason Little

Development Engineering Inspector

JLittle@PuyallupWA.gov

(253) 244-0387



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org