



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jul 24, 2026

Inspection Result: **PASSED**

Permit Number: PRCTI20260728

Property Address: 1115 E MAIN, PUYALLUP, WA 98372;

Contractor: L D SANDERS CONSTRUCTION LLC 24920 SE 369TH PL ENUMCLAW, WA 98022

To construct: This project consists of tenant improvements to an existing fast-food restaurant building to convert it into a drive-thru coffee café. Scope of work includes interior remodeling, updated finishes, new food-and-beverage service equipment, and reconfiguration of customer service areas to support coffee preparation and drive-thru operations. The existing building footprint and primary structural systems will remain unchanged. Improvements include modifications to plumbing, electrical, and mechanical systems as required to support the new equipment layout and occupancy needs. - TI FOR WOODS COFFEE

On this day, we have inspected your construction for **Gas Test Inspection** and we find the following result of the inspection. If you have any questions, please contact the inspector below.

Comments: Gas test approved pressure at 20 psi

Corrections:

Sincerely,

James LaVergne

James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org