



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 29, 2026 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRMU20240286

Property Address: 206 27TH AVE SE, PUYALLUP, WA 98374;

Contractor: RUSH COMMERCIAL CONSTRUCTION INC 6622 WOLLOCHET DR NW
GIG HARBOR, WA 98335-8325

To construct: SUBMITTED AS BLDG A - BRADLEY HEIGHTS APARTMENTS - ISSUED AS
206 27TH AVE SE, BLDG J

On this day, we have inspected your construction for **Comment Engineering Div Inspection** and we find the following result of the inspection. If you have any questions, please contact the inspector below.

Comments: Corrections are for occupancy original Building a

Corrections:

- 1 Complete all channelization, including no parking and fire lane signs
- 2 Connect all downspouts
- 3 Complete all hard surfaces
- 4 Fence off a lit pedestrian pathway
- 5 Carson boxes over backflow valve on sewer line

Sincerely,

Jeff Hill

Jeff Hill

Development Engineering Inspector

Jhill@PuyallupWA.gov

(253) 204-5633



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org