



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 29, 2026 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRMU20240285

Property Address: 206 27TH AVE SE, BLDG H, PUYALLUP, WA 98374

Contractor: RUSH COMMERCIAL CONSTRUCTION INC 6622 WOLLOCHET DR NW
GIG HARBOR, WA 98335-8325

To construct: SUBMITTED AS BLDG B - BRADLEY HEIGHTS APARTMENTS - ISSUED AS
206 27TH AVE SE, BLDG H * REVISION (1) - 6/112/2026 - BLDG B &
BLDG F UNABLE TO MEET MAX SLOPE FOR THE ACCESSIBLE ROUTE OF
TRAVEL, NEW SITE PLAN

On this day, we have inspected your construction for **Comment Engineering Div Inspection** and we find the following result of the inspection. If you have any questions, please contact the inspector below.

Comments:

Corrections:

- 1 Install carson boxes on the sewer backflow.
- 2 fix the gap between the wall and steps SW corner. Large chance of erosion.
- 3 Fence off a lit pedestrian path.
- 4 connect all rood drains.
- 5 complete all fire lane channelization.
- 6 complete or provide a temporary trash in closure.
- 7 Finish landscaping or stabilize soils.
- 8 install rock around yard drains.

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Jeff Hill

Jeff Hill

Development Engineering Inspector

Jhill@PuyallupWA.gov

(253) 204-5633