



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 03, 2026

Inspection Result: **PASSED**

Permit Number: PRMH20261209

Property Address: 1115 E MAIN, PUYALLUP, WA 98372;

Contractor: FIRESIDE OF WASHINGTON 21402 84TH AVE S KENT, WA 98032

To construct: INSTALL 1 AESTETIC ONLY GAS FIREPLACE IN NEW TI BUILDOUT PER
RECORD #PRCTI20260728, GAS PIPING BY OTHERS. - WOODS COFFEE

On this day, we have inspected your construction for **Gas Test Inspection** and we find the following result of the inspection. If you have any questions, please contact the inspector below.

Comments:

Corrections:

Sincerely,

James LaVergne

James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590