

PROJECT: CASCADE CHM LOBBY		SHEET NO. 1/1
BY: CF	DATE: 1/11/21	JOB NO. 20071

21169

TO: CITY OF PUYALLUP BLDG DEPT
RE: CASCADE CHRISTIAN MIDDLE SCHOOL

THE LOBBY & THE CLASSROOM BUILDINGS
HAVE BEEN DESIGNED TO ACT AS ONE
STRUCTURE DURING A WIND/SEISMIC
EVENT. THE LOBBY WAS DESIGNED
UNDER THE 2015 IBC CODE BUT IT
WILL STILL SUPPORT THE LOADS
UNDER THE IBC 2018. THEREFORE
SEISMIC ISOLATION IS NOT
REQUIRED.

B-21-0727 CITY OF
PUYALLUP

