



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Mar 02, 2022                      **Inspection Result:**      **PARTIAL PASS**

**Permit Number:** B-21-0727

**Property Address:** 815 21ST ST SE, PUYALLUP, WA 98372;

**Contractor:** ABSHER CONSTRUCTION CO PO BOX 280 PUYALLUP, WA 98371-0152

**To construct:** PHASE IIIA: INSTALL LOBBY ELEVATOR;CORE & SHELL FOR CLASSRMS;  
FINISH 1ST FL(5 CLASSRMS & ADMIN AREA)CCS  
BLDG

On this day we have inspected your construction for **Underfloor Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1 ; complete all rebar as per City Approved plans & install of holdowns with min. embed depth as per engineers correction approval letter as at grid line - (1-2,C.5-E) (A,2-5) (5,A-E) exterior walls only.
- 2 ;approved with special inspection approval.

Sincerely,

Shannon King  
Building Inspector 2  
ShannonK@PuyallupWA.gov  
(253) 840-6684



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)