



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 21, 2022 **Inspection Result:** **PASSED**

Permit Number: B-21-0727

Property Address: 815 21ST ST SE, PUYALLUP, WA 98372;

Contractor: ABSHER CONSTRUCTION CO PO BOX 280 PUYALLUP, WA 98371-0152

To construct: PHASE IIIA: INSTALL LOBBY ELEVATOR;CORE & SHELL FOR CLASSRMS;
FINISH 1ST FL(5 CLASSRMS & ADMIN AREA)CCS
BLDG

On this day we have inspected your construction for **Foundation/Rebar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: vapor barrier and insulation at slab - ok
interior footings - ok - progressing with special inspection

Corrections:

1 1 ; approved footings only at grid line - (1-2,a-d)

Sincerely,

Gary Webster

Building Inspector

GWebster@PuyallupWA.gov

(253) 841-5590