



City of Puyallup

**Fire Prevention**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## Comment Notice

### Permit Application # PRFA20220621

The City has completed the review of the above-mentioned permit submittal. Below please find the permit submittal review comments from your review team. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

**Fire Review** (Reviewed By: David Drake, (253)864-4171, [DDrake@PuyallupWA.gov](mailto:DDrake@PuyallupWA.gov))

- ◆ 1. Change heat detectors above ceiling to smoke detectors.
- 2. Change heat detectors in bathrooms to smoke detectors.
- 3. Heat detectors will only be allowed in attic spaces, kitchens depending on locations, elevator shafts, and locker rooms with showers. Heat detectors are not recognized by U.L.

To resubmit, you must address all comments and complete the [resubmittal form](#). Please note, partial resubmittals will be deemed incomplete and returned. When you are ready to resubmit, you can do so using the customer portal, by uploading a “new version” of the submittal requirement. In addition, you will need to pay your resubmittal fee at the time of resubmittal. Your resubmittal will not be processed until the fee has been paid. Please note, partial resubmittals will be deemed incomplete and returned.

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center

(253) 864-4165 option 1

[permitcenter@puyallupwa.gov](mailto:permitcenter@puyallupwa.gov)